



0151GBO, froid, novembre (depuis 2025-09-17)
30 journées, plaque 220 W + 220 W, 8 critères tenus sur 10

NRMSE 7,1 % $\leq$ 20,0	LDC 4,3 % $\leq$ 20,0	FFT 26,5 % $>$ 20,0	Énergie −1,6 % $\leq$ 20,0	Pointe −0,1 % $\leq$ 20,0
Fact. de charge −0,8 % $\leq$ 16,0	CORR_h 1,6 % $\leq$ 10,0	TVD_h 3,6 % $\leq$ 15,4	EXT_prof 9,7 % $\leq$ 50,0	Heure des pics 3,0 h $>$ 2,0
Forme 1 h 1,0 $\sigma \leq$ 3,2	Forme 2 h 0,7 $\sigma \leq$ 3,1	Pire écart 1 h 13,8 % $\leq$ 54,0	Verdict non vérifiable	Pointe jour. P95 383 / 554 W



Courbe classée, LDC 4,3 %



Harmoniques, FFT 26,5 %

