

0151GBO, froid, septembre (avant 2025-09-17)
11 journées, plaque 220 W, 10 critères tenus sur 10

NRMSE 7,0 % ≤ 20,0	LDC 4,5 % ≤ 20,0	FFT 7,0 % ≤ 20,0	Énergie −0,2 % ≤ 20,0	Pointe −2,4 % ≤ 20,0
Fact. de charge 1,0 % ≤ 20,0	CORR_h 0,7 % ≤ 10,0	TVD_h 3,6 % ≤ 20,0	EXT_prof 8,3 % ≤ 25,3	Heure des pics 0,8 h ≤ 1,0
Forme 1 h 2,5 σ ≤ 2,6	Forme 2 h 1,3 σ ≤ 2,6	Pire écart 1 h 9,9 % ≤ 93,0	Verdict non vérifiable	Pointe jour. P95 206 / 236 W

