

0154GBO, moulin à grains, aout

21 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 10,2 % $\leq$ 15,1	LDC 6,1 % $\leq$ 10,0	FFT 9,9 % $\leq$ 20,0	Énergie -5,5 % $\leq$ 10,0	Pointe -8,5 % $\leq$ 20,0
Fact. de charge 0,6 % $\leq$ 10,0	CORR_h 3,6 % $\leq$ 7,3	TVD_h 11,5 % $\leq$ 16,9	EXT_prof 17,7 % $\leq$ 25,0	Heure des pics 2,5 h $>$ 2,0
Forme 1 h 3,4 $\sigma >$ 3,3	Forme 2 h 3,0 $\sigma \leq$ 3,4	Pire écart 1 h 17,9 % $\leq$ 30,4	Verdict rejetée	Pointe jour. P95 4 505 / 3 658 W

