

0154GBO, moulin à grains, avril

46 journées, plaque 7 500 W, 8 critères tenus sur 10

NRMSE 7,7 % ≤ 10,9	LDC 6,1 % ≤ 10,0	FFT 22,2 % > 17,6	Énergie −0,3 % ≤ 18,4	Pointe −9,6 % ≤ 16,6
Fact. de charge 2,4 % ≤ 10,0	CORR_h 2,6 % ≤ 5,0	TVD_h 7,7 % ≤ 10,9	EXT_prof 16,0 % ≤ 25,0	Heure des pics 3,0 h > 2,0
Forme 1 h 2,6 σ ≤ 3,1	Forme 2 h 2,1 σ ≤ 3,1	Pire écart 1 h 15,3 % ≤ 24,2	Verdict rejetée	Pointe jour. P95 4 502 / 4 193 W

