

0154GBO, moulin à grains, fevrier
38 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 8,9 % ≤ 14,0	LDC 6,2 % ≤ 10,0	FFT 15,6 % ≤ 20,0	Énergie +0,9 % ≤ 16,0	Pointe +1,8 % ≤ 20,0
Fact. de charge -0,2 % ≤ 10,0	CORR_h 1,7 % ≤ 6,4	TVD_h 6,4 % ≤ 12,3	EXT_prof 15,5 % ≤ 25,0	Heure des pics 3,0 h > 2,0
Forme 1 h 2,8 σ ≤ 3,1	Forme 2 h 2,2 σ ≤ 2,9	Pire écart 1 h 14,8 % ≤ 33,2	Verdict rejetée	Pointe jour. P95 4 004 / 3 889 W

