

0154GBO, moulin à grains, mai
36 journées, plaque 7 500 W, 8 critères tenus sur 10

NRMSE 7,3 % ≤ 15,2	LDC 3,9 % ≤ 10,2	FFT 10,6 % ≤ 19,6	Énergie +0,9 % ≤ 19,5	Pointe −20,2 % > 20,0
Fact. de charge 6,3 % ≤ 10,0	CORR_h 1,0 % ≤ 6,5	TVD_h 4,4 % ≤ 12,6	EXT_prof 11,9 % ≤ 37,3	Heure des pics 3,0 h > 2,0
Forme 1 h 1,5 σ ≤ 3,4	Forme 2 h 1,6 σ ≤ 2,8	Pire écart 1 h 10,9 % ≤ 37,1	Verdict rejetée	Pointe jour. P95 3 506 / 3 942 W

