

0154GBO, moulin à grains, mars
41 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 8,5 % ≤ 17,2	LDC 5,4 % ≤ 10,2	FFT 19,2 % ≤ 20,0	Énergie −1,1 % ≤ 18,7	Pointe −6,5 % ≤ 20,0
Fact. de charge 1,6 % ≤ 11,1	CORR_h 1,8 % ≤ 9,2	TVD_h 6,1 % ≤ 14,3	EXT_prof 15,3 % ≤ 35,2	Heure des pics 3,0 h > 2,0
Forme 1 h 2,7 σ ≤ 3,3	Forme 2 h 1,6 σ ≤ 3,3	Pire écart 1 h 14,8 % ≤ 39,3	Verdict rejetée	Pointe jour. P95 3 506 / 4 118 W

