

0154GBO, moulin à grains, novembre
30 journées, plaque 7 500 W, 9 critères tenus sur 10

NRMSE 6,1 % ≤ 12,0	LDC 3,3 % ≤ 10,0	FFT 7,1 % ≤ 20,0	Énergie −0,1 % ≤ 20,0	Pointe −17,5 % ≤ 20,0
Fact. de charge 3,0 % ≤ 10,0	CORR_h 0,9 % ≤ 8,0	TVD_h 5,1 % ≤ 20,0	EXT_prof 13,0 % ≤ 25,0	Heure des pics 2,2 h > 2,0
Forme 1 h 1,8 σ ≤ 3,6	Forme 2 h 0,9 σ ≤ 3,8	Pire écart 1 h 10,8 % ≤ 35,9	Verdict rejetée	Pointe jour. P95 2 508 / 3 063 W

