

0154GBO, moulin à grains, octobre

29 journées, plaque 7 500 W, 10 critères tenus sur 10

NRMSE 5,9 % ≤ 12,5	LDC 2,3 % ≤ 10,0	FFT 10,3 % ≤ 20,0	Énergie −3,2 % ≤ 11,8	Pointe −1,5 % ≤ 20,0
Fact. de charge −0,3 % ≤ 10,0	CORR_h 0,9 % ≤ 6,0	TVD_h 6,8 % ≤ 19,3	EXT_prof 8,3 % ≤ 25,0	Heure des pics 0,2 h ≤ 1,0
Forme 1 h 2,6 σ ≤ 3,2	Forme 2 h 2,0 σ ≤ 3,0	Pire écart 1 h 8,5 % ≤ 35,5	Verdict validée	Pointe jour. P95 3 504 / 3 140 W

