

0097SAM, moulin à grains, mai

40 journées, plaque 7 350 W, 9 critères tenus sur 10

NRMSE 6,9 % ≤ 10,0	LDC 4,0 % ≤ 10,0	FFT 19,8 % ≤ 20,0	Énergie −5,0 % ≤ 15,8	Pointe −12,0 % ≤ 20,0
Fact. de charge 1,6 % ≤ 10,0	CORR_h 2,2 % ≤ 5,0	TVD_h 8,7 % ≤ 10,0	EXT_prof 14,9 % ≤ 25,0	Heure des pics 1,5 h > 1,0
Forme 1 h 3,1 σ ≤ 3,5	Forme 2 h 2,0 σ ≤ 3,2	Pire écart 1 h 12,8 % ≤ 23,6	Verdict rejetée	Pointe jour. P95 6 861 / 7 042 W

