

0097SAM, moulin à grains, pluies
128 journées, plaque 7 350 W, 9 critères tenus sur 10

NRMSE 6,1 % ≤ 10,0	LDC 4,9 % ≤ 10,0	FFT 16,3 % ≤ 20,0	Énergie +2,6 % ≤ 14,2	Pointe −8,6 % ≤ 16,2
Fact. de charge 3,6 % ≤ 10,0	CORR_h 1,1 % ≤ 5,0	TVD_h 5,3 % ≤ 10,0	EXT_prof 10,7 % ≤ 25,0	Heure des pics 3,0 h > 2,0
Forme 1 h 2,5 σ ≤ 3,3	Forme 2 h 2,4 σ ≤ 3,2	Pire écart 1 h 9,7 % ≤ 20,3	Verdict rejetée	Pointe jour. P95 4 905 / 6 591 W

