

0154GBO, moulin à grains, mai
36 journées, plaque 7 500 W, 8 critères tenus sur 10

NRMSE 7,3 % ≤ 14,3	LDC 3,9 % ≤ 10,0	FFT 10,6 % ≤ 19,9	Énergie +0,9 % ≤ 19,4	Pointe −20,2 % > 20,0
Fact. de charge 6,3 % ≤ 10,0	CORR_h 1,0 % ≤ 6,2	TVD_h 4,4 % ≤ 12,6	EXT_prof 11,9 % ≤ 34,8	Heure des pics 3,0 h > 2,0
Forme 1 h 1,6 σ ≤ 3,2	Forme 2 h 1,8 σ ≤ 3,0	Pire écart 1 h 10,9 % ≤ 36,7	Verdict rejetée	Pointe jour. P95 3 506 / 3 942 W

