

0154GBO, moulin à grains, pluies
138 journées, plaque 7 500 W, 10 critères tenus sur 10

NRMSE 4,8 % ≤ 10,0	LDC 2,3 % ≤ 10,0	FFT 8,8 % ≤ 20,0	Énergie −0,8 % ≤ 16,0	Pointe +2,5 % ≤ 20,0
Fact. de charge −0,7 % ≤ 10,0	CORR_h 0,7 % ≤ 5,0	TVD_h 5,3 % ≤ 10,0	EXT_prof 5,7 % ≤ 25,0	Heure des pics 0,5 h ≤ 1,2
Forme 1 h 2,6 σ ≤ 3,1	Forme 2 h 2,1 σ ≤ 2,9	Pire écart 1 h 8,7 % ≤ 24,2	Verdict validée	Pointe jour. P95 3 506 / 3 897 W

