

Date: 25.08.2024

Sir/ Madam

At 11:20Hrs ICTs at RTPS are getting overloaded due to consequent to increase in RE generation and reduced state demand, it is informed to 220kV stations of Shahapur,kustagi, Lingasagur, Mallat, Sedum, Ramasamudra and Bagewadi to curtail RE generation to avoid further overloading of RTPS ICTs.

Hence, It is requested to curtail 20 to 30% of present RE (wind &solar) generation effectively from 11:20 hrs to 15:45 hrs in the interest of grid security.

Regards,
Shift Charge Engineer,
State Load Despatch Centre,
KPTCL-Bangalore