


GENERAL NOTES  
(APPLY TO ALL "E" DRAWINGS)

LIGHTING				POWER AND TELECOMMUNICATION				ELECTRICAL ABBREVIATIONS			
	LED LIGHTING FIXTURE AND OUTLET BOX. HALF SHADED FIXTURE OR "EM" INDICATES FIXTURES WITH INTEGRAL BATTERY PACK FOR EMERGENCY SERVICE, U.O.N.			JUNCTION BOX WITH BLANK COVER PLATE,		A	AMPERES	EA	EACH		
	LUMINAIRE TYPE (INDICATE BY UPPERCASE LETTER SEE LIGHTING FIXTURE SCHEDULE).			DUPLEX CONVENIENCE RECEPTACLE.		A/C, AC	ABOVE COUNTER	EC	EMPTY CONDUIT/ ELECTRICAL CONTRACTOR		
	PANEL NAME : CIRCUIT NUMBER (INDICATED BY NUMBER)			GFI DUPLEX CONVENIENCE RECEPTACLE.		AF	AMPERE FRAME/AMP FUSE	EF	EXHAUST FAN		
	SWITCHING INDICATED BY LOWER CASE LETTERS.			QUAD RECEPTACLE - 20A-1P, 125V, NEMA 5-20R.		AFF	ABOVE FINISHED FLOOR	EM	EMERGENCY		
				FLOOR/ CEILING QUAD RECEPTACLE - 20A-1P, 125V, NEMA 5-20R.		AS	AMP SWITCH	EMT	ELECTRICAL METALLIC TUBING		
				SPECIAL RECEPTACLE 220V		AIC	AMPS INTERRUPTING CAPACITY	EQUIP	EQUIPMENT		
				DATA OUTLET - (1) PORT UNO, +18" AFF, UNO TEL / DATA OUTLET TO BE PROVIDED WITH 1" CONDUIT U.O.N. TO H.C. AND TERMINATED WITH 90 DEGREE ELBOW AND BUSHING. TEL / DATA OUTLET PLATE SHALL BE PROVIDED WOTH 1-1/4" DIAMETER GROMMETED OPENING.		AT	AMP TRIP	ER	EXISTING TO BE RELOCATED		
				CABLE TV OUTLET, WALL-MOUNTED.		ATS	AUTOMATIC TRANSFER SWITCH	ETR	EXISTING TO REMAIN		
SWITCHES AND CONTROLS											
\$	20A WALL SWITCH			30A/240V NON FUSED DISCONNECT SWITCH		C	CONDUIT	FA	FIRE ALARM		
\$OS	WALL MOUNTED OCCUPANCY SWITCH			60A/240V NON FUSED DISCONNECT SWITCH		C/B,CB	CIRCUIT BREAKER	FBO	FURNISHED BY OTHERS, INSTALLED & WIRED BY EC		
\$D	DIMMER WALL SWITCH U.N.O "a" DENOTES LIGHTING FIXTURE CONTROLLED.			MANUAL MOTOR SWITCH		CKT	CIRCUIT	FDR	FEEDER		
WIRING SYSTEMS											
	POWER OR LIGHTING CIRCUITRY HOMERUN WITH PANELBOARD DESIGNATION, NUMBER WHERE USED INDICATES CIRCUIT NUMBER. IT SHALL CONSISTS OF 1#12 Ø, 1#12 N. & 1#12 G. IN 3/4"C, UNLESS OTHERWISE NOTED.		+24"	INDICATES MOUNTING HEIGHT, CENTER LINE TO FINISHED FLOOR.		CLG	CEILING	FBO	FURNISHED & INSTALLED BY OTHERS, WIRED BY EC		
	POWER OR LIGHTING CIRCUITRY HOMERUN WITH PANELBOARD DESIGNATION, NUMBER WHERE USED INDICATES CIRCUIT NUMBER. IT SHALL CONSISTS OF 2#12 Ø, 1#12 N. & 1#12 G. IN 3/4"C, UNLESS OTHERWISE NOTED.			KEYED NOTE REFERENCE		COMM	COMMUNICATION	FIXT	FIXTURE		
	POWER OR LIGHTING CIRCUITRY HOMERUN WITH PANELBOARD DESIGNATION, NUMBER WHERE USED INDICATES CIRCUIT NUMBER. IT SHALL CONSISTS OF 3#12 Ø, 1#12 N. & 1#12 G. IN 3/4"C, UNLESS OTHERWISE NOTED.			DETAIL REFERENCE: DETAIL NUMBER INDICATED ON TOP; DRAWING NUMBER INDICATED ON BOTTOM		CT	CURRENT TRANSFORMER	FL	FLOOR		
ELECTRICAL DRAWING LIST											
E-001	ELECTRICAL SYMBOL LIST, ABBREVIATIONS			DISTRIBUTION PANELBOARD, 120/240V-SURFACE OR FLUSH MOUNTED.		CU	COPPER	FLUOR	FLUORESCENT		
E-002	ELECTRICAL SPECIFICATIONS (SHEET 1 OF 2)					°C	DEGREE CELSIUS	G	GROUND		
E-003	ELECTRICAL SPECIFICATIONS (SHEET 2 OF 2)					°F	DEGREE FAHRENHEIT	GFI	GROUND FAULT INTERRUPTER		
E-101	ELECTRICAL LIGHTING PLAN					DIA	DIAMETER	GP	GENERAL PURPOSE		
E-102	ELECTRICAL POWER PLAN					DISC	DISCONNECT	HC	HUNG CEILING		
E-201	ELECTRICAL DETAILS-1					DN	DOWN	HP	HORSEPOWER		
E-301	ELECTRICAL RISER DIAGRAM, ENERGY COMPLIANCE & PANEL SCHEDULE					DP	DISTRIBUTION PANEL	HWH	HOW WATER HEATER		
CODE COMPLIANCE											
ALL WORK AND MATERIAL SHALL BE PERFORMED AND INSTALLED IN COMPLIANCE WITH THE FOLLOWING CODES AS ADOPTED AND AMENDED BY THE INSPECTING AUTHORITY. NOTHING IN THESE DRAWINGS IS TO BE CONSTRUCTED TO PERMIT WORK NOT CONFORMING TO THESE CODES OR OTHERS APPLICABLE TO THESE PROJECT:											
a. 2021 INTERNATIONAL BUILDING CODE											
b. 2021 INTERNATIONAL MECHANICAL CODE											
c. 2021 NATIONAL STANDARD PLUMBING CODE, NEW JERSEY EDITION											
d. 2020 NATIONAL ELECTRICAL CODE											
e. 2021 INTERNATIONAL FUEL GAS CODE											
f. ENERGY CODE - ASHRAE 90.1-2019											

**CODE COMPLIANCE**

ALL WORK AND MATERIAL SHALL BE PERFORMED AND INSTALLED IN COMPLIANCE WITH THE FOLLOWING CODES AS ADOPTED AND AMENDED BY THE INSPECTING AUTHORITY. NOTHING IN THESE DRAWINGS IS TO BE CONSTRUCTED TO PERMIT WORK NOT CONFORMING TO THESE CODES OR OTHERS APPLICABLE TO THESE PROJECT:

- a. 2021 INTERNATIONAL BUILDING CODE
- b. 2021 INTERNATIONAL MECHANICAL CODE
- c. 2021 NATIONAL STANDARD PLUMBING CODE, NEW JERSEY EDITION
- d. 2020 NATIONAL ELECTRICAL CODE
- e. 2021 INTERNATIONAL FUEL GAS CODE
- f. ENERGY CODE - ASHRAE 90.1-2019



## ELECTRICAL SPECIFICATIONS

1. GENERAL:
- A. THE "GENERAL CONDITIONS OF THE CONTRACT FOR CONSTRUCTION," AIA DOCUMENT A201, LATEST EDITION, AND THESE SPECIFICATIONS AS APPLICABLE ARE PART OF THIS CONTRACT.
  - B. DRAWINGS ARE DIAGRAMMATIC AND INDICATE GENERAL ARRANGEMENT OF SYSTEMS AND WORK. CONDUIT ROUTING IS SHOWN DIAGRAMMATICALLY AND DOES NOT SHOW ALL OFFSETS, DROPS AND RISES OF RUNS. THE CONTRACTOR SHALL ALLOW IN HIS PRICE FOR ROUTING OF CONDUIT TO AVOID OBSTRUCTIONS. COORDINATION WITH EXISTING SERVICES, INCLUDING THOSE OF OTHER TRADES, IS REQUIRED, MAINTAIN HEADROOM AND SPACE CONDITIONS.
  - C. BIDDERS, BEFORE SUBMITTING PROPOSALS, SHALL VISIT AND CAREFULLY EXAMINE THE AREA AFFECTED BY THIS WORK TO FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS AND THE DIFFICULTIES THAT WILL ATTEND THE EXECUTION OF THIS WORK. SUBMISSION OF A PROPOSAL WILL BE CONSTRUED AS EVIDENCE THAT SUCH AN EXAMINATION HAS BEEN MADE, AND LATER CLAIMS WILL NOT BE RECOGNIZED FOR EXTRA LABOR, EQUIPMENT, OR MATERIALS, REQUIRED BECAUSE OF DIFFICULTIES ENCOUNTERED WHICH COULD HAVE BEEN FORESEEN HAD SUCH AN EXAMINATION BEEN MADE.
  - D. DISCONNECT, REMOVE AND/OR RELOCATE EXISTING MATERIAL, EQUIPMENT AND OTHER WORK AS NOTED OR REQUIRED FOR PROPER INSTALLATION OF NEW WORK.
  - E. THE CONTRACTOR SHALL KEEP ALL EQUIPMENT AND MATERIALS, AND ALL PARTS OF THE BUILDING EXTERIOR SPACES AND ADJACENT STREETS, SIDEWALKS AND PAVEMENTS, FREE FROM MATERIAL AND DEBRIS RESULTING FROM THE EXECUTION OF THIS WORK. EXCESS MATERIALS WILL NOT BE PERMITTED TO ACCUMULATE EITHER ON THE INTERIOR OR THE EXTERIOR.
  - F. SEAL OPENINGS THROUGH PARTITIONS, WALLS AND FLOORS WITH MINERAL WOOL OR OTHER NONCOMBUSTIBLE MATERIAL, UNLESS OTHERWISE NOTED.
  - G. PROVIDE ALL NECESSARY FLASHING AND COUNTER FLASHING TO MAINTAIN THE WATERPROOFING INTEGRITY OF THE BUILDING AS REQUIRED BY THE INSTALLATION OR REMOVAL OF CONDUIT AND EQUIPMENT; PROVIDE EQUIPMENT CURBS AS REQUIRED.
  - H. ALL EXISTING MATERIAL, EQUIPMENT AND CONSTRUCTION DEBRIS TO BE REMOVED UNDER THIS CONTRACT SHALL BECOME THE PROPERTY OF THE CONTRACTOR WITH THE EXCEPTION OF SPECIFIC EQUIPMENT AND APPARATUS REQUESTED BY THE BUILDING REPRESENTATIVE, ARCHITECT OR AS NOTED TO BE RELOCATED ON THE DRAWINGS. REMOVED EQUIPMENT SHALL BE PROPERLY DISPOSED OF BY THIS CONTRACTOR.
  - I. THE CONTRACTOR'S PROPOSAL FOR ALL WORK SHALL BE PREDICATED ON THE PERFORMANCE OF THE WORK DURING REGULAR WORKING HOURS. WHEN SO DIRECTED, HOWEVER, THE CONTRACTOR SHALL INSTALL WORK DURING OVERTIME HOURS AND THE ADDITIONAL COST TO BE CHARGED THEREFORE SHALL BE ONLY THE "PREMIUM" PORTION OF THE WAGES PAID.
  - J. UNLESS OTHERWISE SPECIFICALLY NOTED OR SPECIFIED, INCLUDE ALL CUTTING AND PATCHING OF EXISTING FLOORS, WALLS, PARTITIONS AND OTHER MATERIALS IN THE EXISTING BUILDING. THE CONTRACTOR SHALL RESTORE THESE AREAS TO ORIGINAL CONDITION.
  - K. ALL MATERIAL AND EQUIPMENT SHALL BE NEW UNLESS OTHERWISE NOTED AND SHALL BE IN ACCORDANCE WITH BUILDING STANDARDS.
  - L. INSURANCE: PROVIDE IN ACCORDANCE WITH OWNER/BUILDING REQUIREMENTS AND SHALL INCLUDE A HOLD HARMLESS CLAUSE FOR OWNER AND ENGINEER.
  - M. THE FINAL ACCEPTANCE SHALL BE MADE AFTER THE CONTRACTOR HAS ADJUSTED HIS EQUIPMENT, TESTED THE VARIOUS SYSTEMS, DEMONSTRATED THAT IT FULFILLS THE REQUIREMENTS OF THE DRAWINGS AND SPECIFICATIONS AND HAS FURNISHED ALL THE REQUIRED CERTIFICATES OF INSPECTION AND APPROVAL.
2. GENERAL PROVISIONS FOR ELECTRICAL WORK:
- A. DEFINITIONS:
    - 1) "PROVIDE": TO FURNISH, INSTALL AND CONNECT UP COMPLETE AND READY FOR SAFE AND REGULAR OPERATION THE PARTICULAR WORK REFERRED TO UNLESS SPECIFICALLY OTHERWISE NOTED.
    - 2) "INSTALL": TO ERECT, MOUNT AND CONNECT COMPLETE WITH RELATED ACCESSORIES.
    - 3) "FURNISH" OR "SUPPLY": TO PURCHASE, PROCURE, ACQUIRE, AND DELIVER COMPLETE WITH RELATED ACCESSORIES.
    - 4) "WORK": LABOR, MATERIALS, EQUIPMENT, APPARATUS, CONTROLS, ACCESSORIES AND OTHER ITEMS REQUIRED FOR PROPER AND COMPLETE INSTALLATION.
    - 5) "WIRING": RACEWAY, FITTINGS, WIRE, BOXES, AND RELATED ITEMS.
    - 6) "CONCEALED": EMBEDDED IN MASONRY OR OTHER CONSTRUCTION, INSTALLED IN FURRED SPACES, WITHIN DOUBLE PARTITIONS OR HUNG CEILINGS, IN TRENCHES, IN CRAWL SPACES, OR IN ENCLOSURES.
    - 7) "EXPOSED": NOT INSTALLED UNDERGROUND OR "CONCEALED" AS DEFINED ABOVE.
    - 8) "SIMILAR" OR "EQUAL": EQUAL IN MATERIALS, WEIGHT, SIZE, DESIGN AND EFFICIENCY OF SPECIFIED PRODUCT.
  - B. TEMPORARY LIGHT AND POWER: PROVIDE TEMPORARY LIGHT AND POWER SYSTEMS AT EARLIEST POSSIBLE DATE WITHIN THE CONSTRUCTION AREAS FOR THE REQUIREMENTS OF ALL TRADES AS HEREIN DESCRIBED. EXTEND SYSTEMS TO NEW CONSTRUCTION AS SOON AS PHYSICALLY POSSIBLE. MAINTAIN SYSTEM DURING WORKING OWNER. PROVIDE ALL REQUIRED MAINTENANCE, INCLUDING LAMPS AND SOCKETS.
  - C. QUALITY ASSURANCE
    - 1) QUALITY OF MATERIALS: ALL EQUIPMENT SHALL BE NEW SPECIFICATION GRADE, FREE FROM DEFECTS AND LISTED BY APPROVED TESTING AGENCY AND BEARING THEIR LABEL MATERIALS AND EQUIPMENT OF SIMILAR APPLICATION SHALL BE OF SAME MANUFACTURER, EXCEPT AS NOTED.
    - 2) GUARANTEE: ALL MATERIALS AND WORKMANSHIP SHALL BE GUARANTEED AS DEFINED IN PARAGRAPH 2.C.
    - 3) CURRENT CHARACTERISTICS:
      - a. SERVICE: 120/208 VOLT, 3 PHASE, 4 WIRE, 60 HERTZ WITH GROUNDED NEUTRAL.
      - b. DISTRIBUTION: 120/208 VOLT, 3 PHASE, 4 WIRE, 60 HERTZ WITH GROUNDED NEUTRAL.
    - 4) HEIGHTS OF OUTLETS:
      - a. FROM FINISHED FLOOR TO CENTERLINE OF OUTLETS FOR: RECEPTACLES AND TELEPHONES: 1 FT-4 IN.
3. SCOPE OF WORK:
- A. SCOPE OF WORK SHALL CONSIST OF PROVIDING LABOR, MATERIALS, EQUIPMENT, SERVICES AND FEES NECESSARY FOR COMPLETE AND SAFE INSTALLATION IN CONFORMING WITH NATIONAL AND LOCAL CODES AND AUTHORITIES HAVING JURISDICTION, AS INDICATED ON DRAWINGS AND HEREIN SPECIFIED.
  - B. ALL DRAWINGS, PLANS, DETAILS, SPECIFICATIONS AND SPECIFICATION ADDENDA ARE MADE PART OF THIS CONTRACT AND SHALL APPLY TO ALL WORK UNDER THE CONTRACT UNLESS OTHERWISE AMENDED, MODIFIED, SUPPLIED OR SPECIFIED HEREIN.
  - C. THE CONTRACTOR SHALL FURNISH A WRITTEN GUARANTEE TO REPLACE OR REPAIR PROMPTLY AND ASSUME RESPONSIBILITY FOR ALL EXPENSES INCURRED FOR ANY WORKMANSHIP AND EQUIPMENT IN WHICH DEFECTS DEVELOP WITHIN ONE YEAR FROM THE DATE OF FINAL CERTIFICATE FOR PAYMENT AND/OR FROM DATE OR ACTUAL USE OF EQUIPMENT OR OCCUPANCY OF SPACES BY OWNER INCLUDED UNDER THE VARIOUS PARTS OF THE WORK, WHICHEVER, DATE IS EARLIER. THIS WORK SHALL BE DONE AS DIRECTED BY THE OWNER. THIS GUARANTEE SHALL ALSO PROVIDED THAT WHERE DEFECTS OCCUR, THE CONTRACTOR WILL ASSUME RESPONSIBILITY OF OTHER TRADES AFFECTED BY DEFECTS, REPAIRS OR REPLACEMENTS IN EQUIPMENT SUPPLIED BY THE CONTRACTOR.
  - D. THE CONTRACTOR SHALL GIVE NECESSARY NOTICE, FILE DRAWINGS AND SPECIFICATIONS WITH ALL DEPARTMENTS HAVING JURISDICTION, WORK AND PAY ALL FEES THEREFORE. THE CONTRACTOR SHALL ARRANGE FOR INSPECTION AND TESTS OF ANY OR ALL PARTS OF THE WORK IF SO REQUIRED BY AUTHORITIES AND PAY ALL CHARGES FOR SAME. THE CONTRACTOR SHALL PAY ALL COSTS FOR, AND FURNISH TO THE OWNER BEFORE FINAL BILLING, ALL CERTIFICATES NECESSARY AS EVIDENCE THAT THE WORK INSTALLED CONFORMS WITH ALL REGULATIONS WHERE THEY APPLY TO THIS WORK.
  - E. CONTRACTOR SHALL PERFORM ALL CONTROLLED INSPECTIONS IN ACCORDANCE WITH THE INTERNATIONAL BUILDING CODE. SECURE ALL REQUIRED PERMITS AND APPROVALS AND TRANSMIT SAME TO OWNER. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL FEES.
  - F. AREAS WITH NO ELECTRICAL WORK SHALL REMAIN AS IS. CONTRACTOR SHALL MAINTAIN CONTINUITY OF ALL ELECTRICAL SYSTEMS TO ALL AREAS NOT COVERED BY THIS RENOVATION AND SHALL PROVIDE 48 HOUR NOTICE TO LANDLORD OF ANY PLANNED POWER INTERRUPTIONS OR SIGNAL SYSTEM OUTAGES.
4. SHOP DRAWINGS
- A. PRIOR TO THE INSTALLATION OF ANY WORK AND PROCUREMENT OF EQUIPMENT, CONTRACTOR SHALL PROVIDE COMPLETE SETS OF COORDINATED SHOP DRAWINGS OF ALL NEW AND EXISTING EQUIPMENT, INDICATING CAPACITY, DIMENSIONS AND SEQUENCE OF OPERATION FOR WRITTEN APPROVAL BY THE ARCHITECT AND ENGINEER.
  - B. INDICATE ON EACH SHOP DRAWINGS SUBMITTED:
    - 1) PROJECT NAME AND LOCATION
    - 2) NAME OF ARCHITECT AND ENGINEER
    - 3) ITEM IDENTIFICATION
    - 4) APPROVAL STAMP OF PRIME CONTRACTOR
  - C. SUBMISSIONS:
    - 1) SUBMISSIONS 11 IN. X 17 IN. OR SMALLER: IF THE SUBMISSION IS A CATALOG CUT, THEN THE CONTRACTOR SHALL SUBMIT ONE ORIGINAL AND TWO COPIES. OTHERWISE, HE SHALL SUBMIT THREE COPIES. THE ARCHITECT WILL FORWARD THE ORIGINAL AND ONE COPY (TWO COPIES WHEN NO ORIGINAL IS RECEIVED) TO THE ENGINEER. ALL CATALOG CUTS SHALL BE COMPLETE.
    - 2) SUBMISSIONS LARGER THAN 11 IN. X 17 IN.: SUBMIT TWO PRINTS AND ONE PAPER SEPIA TO THE ARCHITECT. THE ARCHITECT WILL FORWARD ONE PRINT AND THE PAPER SEPIA TO THE ENGINEER.
  - D. SUBMIT SHOP DRAWINGS FOR THE FOLLOWING:
    - 1) SAFETY/DISCONNECT SWITCHES
    - 2) FUSES
    - 3) CIRCUIT BREAKERS
    - 4) PANELBOARDS/LOADCENTER (INCLUDING DIMENSIONS, SCHEDULES, AND CATALOG CUTS)
    - 5) RACEWAYS
    - 6) WIRE AND CABLE
    - 7) WALL SWITCHES
    - 8) INSERTION RECEPTACLES
    - 9) MOMENTARY CONTACT SWITCHES
    - 10) TIME SWITCHES
    - 11) LIGHTING FIXTURES
  - E. ASSIST AND PROVIDE ALL NECESSARY INFORMATION, DIAGRAMS, SKETCHES, ETC. TO THE HVAC CONTRACTOR, FOR THE PREPARATION OF COORDINATED SHOP DRAWINGS INDICATING ROUTING OF FEEDERS, CONTROL CONDUITS, RECESSED FIXTURES AND ADJACENT NEARBY PIPING AND DUCTWORK WHERE APPLICABLE, CERTIFIED BY ALL TRADES THAT COORDINATION HAS BEEN ESTABLISHED. SUBMIT FOUR(4) BOOKBOUND OPERATING AND SERVICE MANUALS WHICH SHALL INCLUDE COPIES OF ALL SHOP DRAWING, PROVIDE SHOP DRAWINGS FOR PANELS, FIXTURES, WIRING DEVICES, CONDUIT, CABLE, DISCONNECT SWITCH, RELAYS, CONTRACTORS, AND OTHER SYSTEMS AS DIRECTED BY THE ENGINEER.
  - F. AS-BUILT DRAWINGS AND EQUIPMENT OPERATIONAL INSTRUCTIONS
    - A. UPON COMPLETION AND ACCEPTANCE OF WORK, CONTRACTOR SHALL FURNISH WRITTEN INSTRUCTIONS AND EQUIPMENT MANUALS AND DEMONSTRATE TO THE OWNER THE PROPER OPERATION AND MAINTENANCE OF ALL EQUIPMENT AND APPARATUS FURNISHED UNDER THIS CONTRACT.
      - B. THESE INSTRUCTIONS SHALL BE TYPED ON 8-1/2 IN. X 11 IN. PAPER AND BOUND IN THREE RING BINDERS WITH CLEAR ACETATE COVERS. CONTRACTOR SHALL GIVE THREE COPIES OF THE INSTRUCTIONS TO THE OWNER AND ONE COPY TO THE ENGINEER.
    - C. THE INSTRUCTION BOOKLET SHALL BEAR THE NAME, ADDRESS AND TELEPHONE NUMBER OF THE PROJECT, ARCHITECT AND ENGINEER.
    - D. REPRODUCIBLE "AS-BUILT" DRAWINGS SHALL BE PROVIDED INDICATING THE AS INSTALLED CONDITIONS OF THE WORK. "AS-BUILT" DRAWINGS SHALL BE PROVIDED TO THE ARCHITECT AFTER COMPLETION OF THE INSTALLATION.
  - G. LOW-VOLTAGE DISTRIBUTION EQUIPMENT:
    - A. PROVIDE COMPLETE EQUIPMENT INCLUDING: SWITCHES, FUSES, CIRCUIT BREAKERS, PANELS AND TRANSFORMERS.
    - B. ALL EQUIPMENT SHALL CONFORM TO NEMA, ANSI AND IEEE STANDARDS.
    - C. DISCONNECT SWITCHES SHALL BE FUSED OR NONFUSED AS NOTED. VOLTAGE SHALL BE AS REQUIRED. SWITCHES SHALL BE HEAVY DUTY, EXCEPT AS NOTED, AND HORSEPOWER RATED FOR MOTOR LOADS. TOGGLE TYPE SWITCHES SHALL BE NONFUSED, LOAD BREAK, HAVING MAXIMUM RATINGS OF 20 AMP AT 600 VOLTS AND 30 AMP AT 240 VOLTS. TWO-POLE SWITCHES SHALL BE SIMILAR TO HART AND HEGEMAN NO. 6808F. THREE-POLE SWITCHES SHALL BE SIMILAR TO HART AND HEGEMAN NO. 7810F. KNIFE-BLADE TYPE SWITCHES SHALL BE LOAD BREAK, QUICK-MAKE-QUICK-BREAK, UL CLASS R UP TO 600 AMP, MAXIMUM RATING EXCEPT AS NOTED SHALL BE 800 AMP. ARC QUENCHERS SHALL BE PROVIDED. SWITCHES SHALL BE SIMILAR TO GENERAL ELECTRIC QMR. ALL SWITCH ENCLOSURES SHALL BE DEAD FRONT, NEMA TYPE 1, EXCEPT AS NOTED.
  - H. FUSES:
    - A. CIRCUITS 0 TO 600 AMPERES SHALL BE PROTECTED BY FUSES SIMILAR TO CURRENT LIMITING BUSSMAN LOW-PEAK DUAL-ELEMENT TIME-DELAY LPN-RK (AMP)SP (250V) /LPS-RK (AMP)SP (600V) OR LPJ (AMP)SP (600V) (UL CLASS RK1 OR CLASS J), AND BE LISTED BY UL WITH AN INTERRUPTING RATING OF 300,000 AMPERES RMS SYMMETRICAL.
    - B. MOTOR CIRCUITS - ALL INDIVIDUAL MOTOR CIRCUITS WITH FULL LOAD AMPERE RATINGS (FLA) OF 480 AMPERES OR LESS SHALL BE PROTECTED BY FUSES SIMILAR TO CURRENT LIMITING BUSSMANN LOW-PEAK DUAL-ELEMENT TIME-DELAY LPN-RK (AMP)SP (250V) /LPS-RK (AMP)SP (600V) OR LPJ (AMP)SP (600V) (UL CLASS RK1 OR CLASS J), AND BE LISTED BY UL WITH AN INTERRUPTING RATING OF 300,000 AMPERES RMS SYMMETRICAL.
    - C. ALL FUSES SHALL BE PROVIDED BY SAME MANUFACTURER.
    - D. PROVIDE 1 SPACE MATCHING FUSE FOR EACH SET OF 3.
    - E. CIRCUIT BREAKERS: MOLDED CASE BREAKERS SHALL BE THERMAL-MAGNETIC, QUICK-MAKE-QUICK-BREAK, BOLT-ON TYPE, MANUALLY OPERATED WITH INSULATED TRIP-FREE HANDLE. MULTI-POLE TYPE BREAKERS SHALL CONTAIN INTERNAL TRIP BAR. TERMINALS SHALL BE SUITABLE FOR COPPER OR ALUMINUM CABLE. FURNISH AUXILIARY DEVICES WHERE REQUIRED FOR SHUNT-TRIPPING, OPEN AND CLOSE MOTOR OPERATOR AND ALARM INDICATION. ENCLOSURES SHALL BE DEAD FRONT, NEMA TYPE 1, EXCEPT AS NOTED. FRAMES, AND INTERCHANGEABLE TRIPS SHALL BE AS FOLLOWS, UNLESS OTHERWISE NOTED:
      - 1) 120 VOLTS, 100-AMP FRAME: 10,000 AMPS, 1 POLE.
      - 2) 120/240 VOLTS, 225-AMP FRAME: 22,000 AMPS MINIMUM
  - I. DISTRIBUTION PANELBOARDS, SWITCH AND FUSE:
    - H. THREE PHASE, 3 OR 4 WIRE WITH COPPER BUS BARS. ALL THROUGH BUS SHALL BE INSULATED.
    - I. NEMA CLASS 1 CONSTRUCTION TO ACCOMMODATE FUSIBLE, INDIVIDUALLY ENCLOSED SWITCHES, FRONT REMOVABLE, SWITCH AND DOOR INTERLOCKS. COVERS TO BE PAD-LOCKABLE.
    - J. PANELBOARD SHALL BE CONSTRUCTED OF CODE-GAUGE STEEL, GRAY FINISH OVER RUST INHIBITOR, FOR SURFACE MOUNTING. BOX AND PANEL FRAME SHALL BE FLANGED AND REINFORCED FOR RIGID SUPPORT OF INTERIOR AND ACCURATE ALIGNMENT OF INTERIOR WITH FRONT. TRIMS TO BE FASTENED TO BACK BOX WITH SCREWS.
    - K. ALL BRANCH SWITCHES SHALL HAVE INDIVIDUAL ENGRAVED LAMICOID NAMEPLATES (BLACK WITH WHITE CORE).
    - L. DISTRIBUTION PANELBOARD CONSTRUCTION MINIMUM SHORT CIRCUIT RATING 25,000 AMPERES. REMS SYMMETRICAL FOR ALL 120/208V APPLICATIONS. APPLICATIONS.
    - M. DISCONNECTS
      - 1) DISCONNECT SWITCHES SHALL CONFORM TO NEMA AND UL STANDARDS, AND SHALL BE HORSEPOWER RATED.
      - 2) SWITCHING MECHANISM SHALL BE QUICK-MAKE, QUICK-BREAK, SINGLE THROW WITH EXTERNAL OPERATING HANDLE MECHANICALLY INTERLOCKED WITH ENCLOSURE COVER TO PROVIDE ACCESS TO INTERIOR WHEN DISCONNECT IS IN OFF POSITION ONLY. PROVIDE MEANS TO LOCK OPERATING HANDLE IN THE OPEN AND CLOSED POSITION. DESIGNATE ON THE ENCLOSURE THE OPEN AND CLOSED POSITION OF THE OPERATING HANDLE.
      - 3) SWITCHES SHALL BE OF THE DOUBLE STATIONARY CONTACT TYPE.
      - 4) SWITCHES SHALL BE EQUIPPED WITH REJECTION TYPE FUSE HOLDERS, FUSIBLE AS SHOWN ON THE DRAWINGS; PROVIDE COMPLETE WITH FUSES AS SCHEDULED.
    - G. INSTALLATION
      - 1) DISTRIBUTION PANELBOARD SHALL BE MOUNTED TO STRUCTURAL STEEL CHANNEL (KINDORF) WHICH SHALL BE BOLTED TO THE WALL USING EXPANSION ANCHORS FOR LARGE PANELS.
    - H. IDENTIFICATION
      - 1) PROVIDE NAMEPLATE AT EACH SWITCH IDENTIFYING THE LOAD SERVED.
      - 2) NAMEPLATES SHALL BE MOUNTED ON THE FRONT COVER SECURED WITH SELF-TAPPING SCREWS OR NUTS AND BOLTS. NAMEPLATES SHALL BE LAMINATED PHENOLIC, BLACK WITH A MINIMUM OF 1/4" HIGH WHITE LETTERING.
    - I. DISTRIBUTION AND SUB-DISTRIBUTION PANELBOARDS SHALL BE A MINIMUM OF 30" WIDE AND 10" DEEP.
    - J. POWER PANELBOARDS SHALL BE SIMILAR TO GENERAL ELECTRIC TYPE "OMP", AS MANUFACTURED BY ATLAS SWITCH COMPANY, ELECTRIC SWITCHBOARD COMPANY OR APPROVED EQUAL.
    - K. PANELBOARD SHALL HAVE MAIN CIRCUIT BREAKER OR MAIN LUGS AS INDICATED ON THE DRAWINGS. QUANTITY, POLES AND TRIP RATINGS OF BRANCH CIRCUIT BREAKERS TO BE AS INDICATED ON DRAWINGS.
    - L. PANELBOARD SHALL HAVE ENGRAVED WHITE CORE, BLACK LAMICOID NAMEPLATE SCREWED ON PANE TRIM WITH DESIGNATION LISTED (PANELBOARD NAME, VOLTAGE, RATING OR MAINS IN AMPS).
    - B. MATERIALS
      - 1) RACEWAYS:
        - a. RIGID STEEL CONDUIT: FULL-WEIGHT PIPE, GALVANIZED, THREADED.
        - b. ELECTROMETALLIC TUBING (EMT): THIN WALL PIPE, GALVANIZED, THREADLESS.
        - c. FLEXIBLE STEEL CONDUIT: CONTINUOUS SINGLE STRIP, GALVANIZED.
        - d. WIREWAYS: WIRE SHALL BE AS NOTED, MINIMUM NO. 16 GAUGE STEEL WITH GROUND CONTINUITY. FINISH SHALL BE BAKED ENAMEL. COVERS SHALL BE SCREW-ON.
      - 2) FITTINGS AND ACCESSORIES:
        - a. RIGID STEEL: NONSPLIT, THREADED, STEEL OR MALLEABLE IRON. ZINC DIE CAST NOT PERMITTED.
        - b. ELECTROMETALLIC TUBING: COMPRESSION TYPE, GALVANIZED RIGID STEEL ELBOWS, 2 IN. OR LARGER.
        - c. FLEXIBLE METALLIC CONDUIT: ANGLE WEDGE TYPE WITH INSULATED THROAT.
        - d. BUSHINGS: METALLIC INSULATED TYPE.

*All rights reserved*

## ELECTRICAL SPECIFICATIONS (CONT.)

- 3) BOXES:
- a. OUTLET BOXES: EXCEPT AS OTHERWISE REQUIRED BY CONSTRUCTION, DEVICES OR WIRING BOXES SHALL BE STAMPED STEEL, 4 IN. SQUARE OR OCTAGON FOR FIXTURES. BOXES ABOVE CEILING SHALL BE 1-1/2 IN. DEEP. BOXES IN CEILING OR SLAB SHALL BE 3 IN. DEEP. BOXES IN WALL FOR FIXTURES SHALL BE 2-3/4 IN. DEEP. BOXES IN WALL FOR RECEPTACLES AND SWITCHES SHALL BE 1-1/2 IN. DEEP. FURNISH WITH RAISED COVERS AND FIXTURE STUDS WHERE REQUIRED. WITHOUT FIXTURE OR DEVICE: FURNISH BLANK COVER. OFFSET BACK-TO-BACK OUTLETS WITH MINIMUM 6 IN. SEPARATION.
  - b. JUNCTION AND PULL BOXES: GALVANIZED SHEET STEEL WITH SCREW-ON COVERS, EXCEPT AS NOTED. FURNISH WITH INSULATED SUPPORTS FOR CABLES. LOCATIONS SHALL BE AS NOTED OR REQUIRED AND ACCESSIBLE. PROVIDE BARRIERS IN NEW AND RENOVATED BOXES BETWEEN 120/208 VOLT AND 265/460 VOLT WIRING AND BETWEEN EMERGENCY AND NORMAL WIRING. FLOOR BOXES SHALL BE SUITABLE FOR CONDUIT AND DEVICES NOTED. RAISED OUTLETS SHALL BE HUBBELL #B2414 SERIES WITH ABOVE FLOOR FITTING. TELEPHONE: BUSHED HOLE, POWER: DUPLEX RECEPTACLE OR OTHER AS NOTED. INCREASE SIZE TO SUIT AS NECESSARY. FLUSH OUTLETS SHALL BE HUBBELL #B2414 SERIES WITH FLUSH FLOOR FITTING FOR TELEPHONE AND FLUSH DUAL FLAP COVER WITH DUPLEX RECEPTACLE FOR POWER AS NOTED. INCREASE SIZE TO SUIT AS NECESSARY.
  - c. PROVIDE RACEWAYS ONLY AS HEREIN SPECIFIED, EXCEPT AS NOTED. RACEWAYS SHALL BE RUN CONCEALED, EXCEPT AS NOTED.
- PROVIDE RACEWAY SUPPORT UTILIZING CEILING TRAPEZE, STRAP HANGERS, OR WALL BRACKETS. PROVIDE U-BOLTS AT EACH FLOOR LEVEL OF RISER RACEWAYS AND CONNECTED TO ACCEPTABLE SUPPORTS. PROVIDE RISER CLAMPS AT EACH FLOOR LEVEL OF RISER RACEWAYS AND RESTING ON SLAB. FOR THROUGH-THE-FLOOR SYSTEMS, UTILIZE AN ASSEMBLY SIMILAR TO HUBBELL FIRE RATED POKE-THROUGH-FLOOR BOX SYSTEM. FOR ABOVE FLOOR FITTINGS, TELEPHONE SHALL BE BUSHED HOLE AND POWER SHALL BE DUPLEX RECEPTACLE OR OTHER AS NOTED. PROVIDE SEPARATION BARRIER BETWEEN POWER AND TELEPHONE COMPARTMENTS. PROVIDE JUNCTION BOX ON UNDERSIDE OF FLOOR. PACK FITTING TO RESTORE FIRE RATING OF FLOOR.
- SECURE ALL RACEWAYS TO SUPPORTS WITH PIPE STRAPS OR U-BOLTS. SPACING OF SUPPORTS SHALL BE A MINIMUM OF 10 FT ON CENTER FOR METALLIC RACEWAY AND AS REQUIRED FOR NONMETALLIC RACEWAY. SPACING SHALL BE 5 FT ON CENTER FOR WIRES AND PIER CODE AND AS NOTED FOR OTHERS. MOUNT SUPPORTS TO STRUCTURE MASONRY WITH TOGGLE BOLTS ON HOLLOW MASONRY, EXPANSION SHIELDS OR INSERTS IN CONCRETE AND BRICK, MACHINE SCREWS ON METAL, BEAM CLAMPS ON FRAMEWORK, WOOD SCREWS ON WOOD, AND PAN THROUGH STRAPS IN METAL DECK. NAILS, RAWL PLUGS OR WOOD PLUGS SHALL NOT BE PERMITTED. WHERE REQUIRED BY STRUCTURE, FURNISH THROUGH BOLTS AND FISHPLATES.
- EXPOSED RACEWAYS SHALL BE RUN PARALLEL WITH OR AT RIGHT ANGLES TO WALLS. PROVIDE CLEARANCE WITH WATER, STEAM OR OTHER PIPING (MINIMUM 3 IN. SEPARATION FROM STEAM AND HOT WATER PIPES, EXCEPT 1 IN. FROM PIPE COVER AT CROSSINGS AND 18 IN. FOR PARALLEL RUNS). FOR HUNG CEILING OUTLETS, RUN IN HUNG CEILING AND CONNECT TO CEILING SUPPORT CHANNELS IN MASONRY AND Poured CONCRETE, RUN VERTICALLY ONLY.
- Maintain Grounding Continuity of interrupted metallic raceways with ground conductor, and in flexible conduit for feeders and motor terminal connections.
- Empty raceways over 10 ft long: provide fish or pull wire, galvanized or nylon rope.
- Rigid steel conduit shall be permitted for feeders and branch circuits. Paint male threads of field-threaded conduit with graphite-base pipe compound and butt conduit ends. Touch up marred surfaces and field-cut threads. CRC-COLD GALVANIZED EMT SHALL BE PERMITTED FOR BRANCH CIRCUITS ONLY, IN DRY LOCATIONS, DRY WALLS, HUNG CEILINGS, HOLLOW BLOCK WALLS AND FURRED SPACES. EMT SHALL NOT BE PERMITTED IN RAISED FLOORS.
- Flexible steel conduit shall be utilized for short connections where rigid conduit is impractical. From outlet box to recessed lighting fixture: provide minimum 4 ft and maximum 6 ft lengths. For final connection to motor terminal box, transformer and other vibrating equipment: provide with polyvinyl sheathing and ground conductor. Minimum length: 18 in. with slack. Connect ground conductor to enclosure or raceway at each end, for expansion joint crossings, cross at right angles and anchor ends.
- Cut conduit ends square. Ream smooth. Paint male threads of field threaded raceways with graphite base pipe compound. Draw up tight with raceway coupling.
- All couplings shall be compression type. No set screw fittings.
- Expansion fittings shall be installed at right angles with clip joint centered in expansion joint. Provide a length of run in accordance manufacturer's recommendations. Preset fittings shall allow for temperature variation.
- Raceways passing through fire-rated construction: seal opening with fire sealant.
- D. PROVIDE CABLE SUPPORTS IN ACCORDANCE WITH NATIONAL ELECTRIC CODE ARTICLE 300.19. CABLE SUPPORTS SHALL UTILIZE A ONE-PIECE PLUG WITH POZI-GRIP WEDGING PLUG AS MANUFACTURED BY OZ-GEDNEY. TYPE SF SHALL BE USED FOR ARMORED CABLE.
- Install cable supports at the top of a vertical rise and provide intermediate additional supports as required to limit supported conductor lengths to not greater than those specified in table 300.19(a).
- A. ERECT WALL AND SWITCH OUTLETS IN ADVANCE OF FUllING AND FIREPROOFING. OUTLET BOXES SHALL BE SET SQUARE AND TRUE WITH BUILDING FINISH. SECURE TO BUILDING STRUCTURE BY ADJUSTABLE STRAP IRON OR GROUT IN WITH MASONRY. VERIFY OUTLET LOCATIONS IN FINISHED SPACES WITH ARCHITECTURAL DRAWINGS OF INTERIOR DETAILS AND FINISHES. PROVIDE BARRIERS BETWEEN SWITCHES CONNECTED TO DIFFERENT PHASES FOR VOLTAGES EXCEEDING 150 VOLTS TO GROUND.
- D. PANEL, JUNCTION AND PULL BOXES SHALL BE LOCATED CLEAR OF OTHER TRADES. CONCEAL JUNCTION AND PULL BOXES IN FINISHED SPACES. WHERE NECESSARY, REROUTE RACEWAYS OR MAKE OTHER ARRANGEMENTS FOR CONCEALMENT. BOXES SHALL BE ACCESSIBLE. SUPPORT BOXES FROM BUILDING STRUCTURE, INDEPENDENT OF CONDUIT. PROVIDE FLOOR-TO-CEILING CHANNELS FOR MOUNTING ON DRYWALL AND LIGHTWEIGHT CONSTRUCTION. OUTLET BOXES FOR FIXTURES RECESSED IN HUNG CEILINGS SHALL BE ACCESSIBLE THROUGH OPENING CREATED BY REMOVAL OF FIXTURE. SECURE TO BLACK IRON SUPPORT. MOTOR TERMINAL BOXES: COORDINATE WITH MOTOR BRANCH CIRCUIT CONDUIT AND WIRING; ADD BOX VOLUME WHERE REQUIRED.
- E. FIRE SEALANTS: PROVIDE FOR RACEWAYS AND WIRE PASSING THROUGH FLOOR SLOTS, SLEEVES OR OPENINGS IN FIRE-PARTITION ROOMS.
- F. PERFORM CONTINUITY TESTS OF RESISTANCE OF FEEDER CONDUITS FROM SERVICE TO POINT OF FINAL DISTRIBUTION USING 1 CONDUCTOR RETURN. MAXIMUM RESISTANCE SHALL BE 25 OHMS.
9. WIRE AND CABLE:
- A. PROVIDE WIRE AND CABLE COMPLETE WITH ACCESSORIES. SIZE REFERENCE SHALL BE AWG EXCEPT AS NOTED.
- B. CONDUCTORS SHALL BE COPPER, ASTM STANDARD SOLID (NO. 10 AND SMALLER) OR STRANDED (NO. 8 AND LARGER). GENERAL USE CABLENING SHALL BE NO. 12 MINIMUM. AT 120 VOLTS AND OVER 100 FT CIRCUIT LENGTH PROVIDE NO. 10 MINIMUM. AT 265 VOLTS AND OVER 200 FT CIRCUIT LENGTH PROVIDE NO. 10 MINIMUM.
- C. CONTROL AND ALARM CABLING, EXCEPT AS NOTED, SHALL BE NO. 14 MINIMUM. AT 120 VOLTS AND OVER 200 FT CIRCUIT LENGTH PROVIDE NO. 12 MINIMUM. OTHER VOLTAGES AND PHASES: ADJUST CABLE SIZING AS REQUIRED TO MAINTAIN VOLTAGE DROP. INCREASE RACEWAY SIZES FOR LARGER WIRE AS REQUIRED.
- D. INSULATION SHALL BE RUBBER AND THERMOPLASTIC MEETING ASTM AND IEC60068-2-20: TYPE THW OR THWN SHALL BE UTILIZED FOR FEEDERS AND BRANCH CIRCUITS EXCEPT AS NOTED. TYPE SFF-2 SHALL BE UTILIZED FOR BRANCH CIRCUITS LOCATED IN WIRING CHANNELS OF CONTINUOUS FLUORESCENT FIXTURES AND IN AMBIENT TEMPERATURES OVER 90 DEG C. FOR UNGROUNDED ISOLATED BRANCH CIRCUITS PROVIDE CROSS-LINKED POLYETHYLENE INSULATION (TYPE XHHW).
- E. ARMORED CABLE (BX) SHALL BE UTILIZED FOR BRANCH CIRCUITS IN DRY HOLLOW LOCATIONS, HUNG CEILINGS, AND BLOCK WALLS WHEN USED IN LIEU OF WIRING IN CONDUIT. STATE IN PROPOSAL THAT PRICE IS BASED UPON THE USE OF HOSPITAL GRADE 'BX'.
- F. COLOR CODING SHALL BE AS FOLLOWS:
- 120/208 VOLT SYSTEM:  
BLACK FOR A PHASE  
RED FOR B PHASE  
BLUE FOR C PHASE
- 1) NEUTRAL WIRE SHALL UTILIZE WHITE OUTER COVERING THROUGHOUT. EQUIPMENT GROUND WIRE SHALL UTILIZE GREEN OUTER COVERING THROUGHOUT.
- WHERE COLOR-CODED CABLE IS NOT AVAILABLE, CERTIFY IN WRITING AND REQUEST PERMISSION TO OVERLAP CONDUCTORS WITH 6 IN. OF COLOR TAPE IN ACCESSIBLE LOCATIONS.
- G. PROVIDE FLAMEPROOF LINEN OR FIBER TAGS IN ACCESSIBLE LOCATIONS. FOR FEEDERS INDICATE FEEDER NUMBER, SIZE, PHASE, AND POINTS OF ORIGIN AND TERMINATIONS. FOR CONTROL AND ALARM WIRING INDICATE TYPE (CONTROL OR ALARM), SIZE OF WIRE, AND POINTS OF ORIGIN AND TERMINATIONS.
- H. TERMINATIONS, SPLICES AND TAPS UNDER 600 VOLTS: COPPER CONDUCTORS NO. 10 AND SMALLER SHALL UTILIZE COMPRESSION-TYPE OF TWIST-ON SPRING-LOADED CONNECTORS AND CLEAR NYLON-INSULATED COVERING. COPPER CONDUCTORS NO. 8 AND LARGER SHALL UTILIZE MECHANICAL BOLTED PRESSURE OR HYDRAULIC COMPRESSION TYPE USING MANUFACTURER'S RECOMMENDED TOOLING. CABLE LUGS AND CONNECTORS SHALL UTILIZE COMPRESSION TYPE OF SAME METAL AS CONDUCTOR. PROVIDE TO MATCH CABLE, WITH MARKING INDICATING SIZE AND TYPE. COPPER LUG CONNECTIONS TO BUS BARS: USE ANTISEIZE COMPOUND ON TANG.
- NOT MORE THAN 3 LIGHTING OR CONVENIENCE OUTLET CIRCUITS SHALL BE INSTALLED IN ONE CONDUIT UNLESS OTHERWISE INDICATED. PULL NO THERMOPLASTIC WIRES AT TEMPERATURES LOWER THAN 32 DEG F. PROVIDE SEPARATE RACEWAYS FOR CONDUCTORS OF 120/208 AND 265/460 VOLT SYSTEMS, EXCEPT 460 VOLT MOTOR BRANCH CIRCUIT WIRING AND RELATED 120 VOLT CONTROL WIRING. THERMOPLASTIC WIRES SHALL NOT BE INSTALLED IN COMPUTER AREA RAISED FLOORS.
- J. LEAVE WIRES WITH SUFFICIENT SLACK TO PERMIT MAKING FINAL CONNECTIONS.
- K. PERFORM CONTINUITY AND INSULATION TESTS. MEGGER TEST 100 PERCENT OF FEEDERS, 10 PERCENT OF BRANCH CIRCUITS AND ALL MOTOR BRANCH CIRCUITS OVER 25 HP.
- PERFORM TESTS PRIOR TO CONNECTING EQUIPMENT AND IN PRESENCE OF AUTHORIZED REPRESENTATIVES. SUBMIT WRITTEN REPORT OF RESULTS. CORRECT OR REPLACE CABLE TESTING BELOW MANUFACTURER'S STANDARDS.
11. WIRING DEVICES:
- A. WIRING DEVICES SHALL BE SPECIFICATION GRADE UNLESS OTHERWISE SPECIFIED. ALL DEVICES SHALL BE FLUSH MOUNTED, UNLESS OTHERWISE NOTED. PROVIDE COMPLETE MATERIAL AND ACCESSORIES AS NOTED.
- B. LOCAL WALL SWITCHES SHALL BE ROCKER TYPE, QUIET OPERATING, RATED 20 AMP, 120/208 VOLT, AC. SIMILAR TO LEVITON DECORA SERIES A5621 (SINGLE POLE), A5623 (3-WAY) AND A5624 (4-WAY).
- C. STRAIGHT BLADE RECEPTACLES SHALL BE COMMERCIAL SPECIFICATION GRADE DUPLEX CONVENIENCE 125 VOLTS, 2 POLE, 3 WIRE, U GROUND SLOT, DECORA SERIES BY LEVITON. GROUNDED, EXCEPT AS NOTED.
- 1) SINGLE GANG, RECESSED, DUPLEX RECEPTACLE: TAMPER RESISTANT, 2-POLE, 3-WIRE GROUNDING, 15A, 125V, NEMA 5-20R; LEVITON 689 SERIES (COLOR AS SPECIFIED BY ARCHITECT).
- 2) USB CHARGER/ DUPLEX TAMPER-RESISTANT RECEPTACLE: TAMPER RESISTANT,
- E. DEVICE PLATES: SEE ARCHITECT FOR TYPE. FOR RECEPTACLES WITH OTHER THAN 120 VOLT, INSCRIBED VOLTAGE AVAILABLE.
- F. COLORS: COORDINATE COLORS WITH ARCHITECT.
- G. MOUNTING ORIENTATION OF RECEPTACLES (HORIZONTAL OR VERTICAL): COORDINATE WITH ARCHITECT.
12. LIGHTING FIXTURES:
- A. FIXTURES TO BE AS SPECIFIED BY ARCHITECT AND SHALL BE COMPLETELY FACTORY ASSEMBLED, WIRED AND EQUIPPED WITH ALL NECESSARY SOCKETS, BALLASTS, SUPPORTING HARDWARE AND ACCESSORIES. REFER TO DRAWINGS FOR INDIVIDUAL FIXTURE DESCRIPTIONS.
- B. FIXTURE CATALOG NUMBERS USED TO ILLUSTRATE EQUIPMENT TYPE DO NOT NECESSARILY DENOTE REQUIRED MOUNTING EQUIPMENT OR ACCESSORIES. PROVIDE ACCESSORIES TO SUIT.
- C. BALLAST: CLASS P, HIGH POWER FACTOR, LOWEST AVAILABLE NEMA RATED NOISE LEVEL, ETI AND CBM APPROVED. ENERGY SAVING TYPE: TRIGGER START FOR 24-INCH LAMPS AND RAPID START FOR 48-INCH TWO LAMP BALLASTS; NO THREE LAMP BALLASTS. BALLASTS SHALL BE ADVANCE MAGNETEK, UNIVERSAL OR EQUAL.
- D. LED DRIVERS SHALL BE ELECTRONIC TYPE, LABELED AS COMPLIANT WITH RADIO FREQUENCY INTERFERENCE (RFI) REQUIREMENTS OF FCC TITLE 47, PART 15 AND COMPLY WITH NEMA SSL-1 "ELECTRONIC DRIVERS FOR LED DEVICES, ARRAYS OR SYSTEMS". LED DRIVERS SHALL HAVE A SOUND RATING OF "A", HAVE A MINIMUM EFFICIENCY OF 85% AND BE RATED FOR A THD OF LESS THAN 20% AT ALL INPUT VOLTTAGES.
- E. DIMMABLE LED DRIVERS SHALL BE CAPABLE OF DIMMING WITHOUT LED STROBING OR FLICKER ACROSS THEIR FULL DIMMING RANGE. PROVIDE TYPE OF LED DRIVER AS PER LIGHTING FIXTURE SPECIFICATION. DIMMABLE LED DRIVERS SHALL BE 0-10V WHERE NOT INDICATED.
- F. CONTINUOUS ROW, TWO LAMP STRIP FIXTURES SHALL BE STAGGERED TYPE.
- G. EXIT SIGNS SHALL BE PRECISION DIE-CAST ALUMINUM HOUSING WITH LASER-FORMED ACRYLIC LEGEND. EXIT SIGNS SHALL COMPLY WITH UL 924 AND BE MEA APPROVED FOR USE. AC POWERED WITH PREMIUM LONG-LIFE NICKEL CADMIUM BATTERY WITH STANDARD UL LISTED 3-HOUR RUN TIME. PROVIDE WITH INTEGRAL AUTOMATIC CHARGER IN A SELF CONTAINED POWER PACK. LED INDICATOR WITH PUSH TO TEST SWITCH.
13. TELEPHONE CONDUIT SYSTEM:
- A. PROVIDE COMPLETE SYSTEM OF: RACEWAYS AND ACCESSORIES, OUTLET BOXES, SLEEVES AND FISHWIRES.
- B. EQUIPMENT SHALL CONFORM TO REQUIREMENTS OF TELEPHONE COMPANY.
- C. OUTLETS SHALL BE:
- 1) WALL: 4 IN. SQUARE WITH BUSHED COVER PLATE.
- D. PROVIDE FISHWIRES, IN RACEWAYS OVER 10 FT LONG.
- E. CONDUIT SHALL BE 3/4 IN. MINIMUM. FURNISH EMPTY CONDUIT FROM OUTLET BOX TO BUSHED END THRU WALL 6" BELOW THE PLASTER CEILING.
- F. FACE RACEWAYS IN ROOMS SHALL HUBBELL HBL500, HBL750 OR HBL2000 SERIES OR AS ACCEPTABLE.
14. GROUNDING AND BONDING:
- A. PROVIDE GROUNDING SYSTEM IN ACCORDANCE WITH (2020 NATIONAL ELECTRICAL CODE), AND THESE SPECIFICATIONS. THE WIRING SYSTEM SHALL BE INSTALLED AS REQUIRED TO PROVIDE A CONTINUOUSLY GROUNDED SYSTEM. WHERE FLEXIBLE CONDUIT IS USED FOR PART OF A CONDUIT RUN, EXCEPT LIGHTING BRANCH CIRCUITS, AN INSULATED GROUNDING CONDUCTOR SHALL BE PROVIDED IN THE CONDUIT AND CONNECTED TO GROUNDING BUSHINGS AT EACH END OF THE RUN.
- B. USE EXOTHERMIC WELDING PROCESS FOR INACCESSIBLE CONNECTIONS.
- C. EXTEND EXISTING SYSTEM GROUND TO INCLUDE ALL THE ELECTRICAL EQUIPMENT IN THE SCOPE OF WORK.
- D. WHERE FLEXIBLE METALLIC CONDUIT IS USED AS INTERNAL BONDING CONDUCTOR SHALL BE INSTALLED.
- E. IN ADDITION, FURNISH A SEPARATE INSULATED GREEN EQUIPMENT GROUND CONDUCTOR WHERE INDICATED ON DRAWINGS AND FOR THE FOLLOWING BRANCH CIRCUITS: CIRCUITS SERVING ANY WALL BOX DIMMER.
- 1) CIRCUITS SERVING ANY ISOLATED GROUND RECEPTACLES. TERMINATE GROUND DIRECTLY AT AN EQUIPMENT GROUNDING CONDUCTOR TERMINAL OF THE SOURCE AT THE SOURCE, OR AS OTHER WISE NOTED ON DRAWINGS.
- 3) CIRCUITS SERVING ANY DUPLEX OR SIMPLEX COMPUTER RECEPTACLES.
- 4) ANY CIRCUIT SERVED VIA AN ISOLATION TRANSFORMER OR COMPUTER POWER DISTRIBUTION UNIT.
15. PANELBOARDS:
- A. PANELBOARDS SHALL BE OF THE DEAD FRONT TYPE MANUFACTURED IN CODE GAUGE AND SIZE BOXES FOR MOUNTING AS INDICATED ON PLANS COMPLETE WITH TRIM, DOORS AND LOCKS. ALL LOCKS SHALL BE KEYED ALIKE.
- B. CIRCUIT BREAKERS SHALL BE OF THE BOLT-ON THERMAL MAGNETIC MOLDED CASE TYPE, AND SHALL HAVE THE TRIP RATINGS AND NUMBER OF POLES SHOWN IN SCHEDULES ON THE CONTRACT DRAWINGS. FOR BLANK (SPACE) COMPARTMENTS, PROVIDE FULL RATED BUS. MINIMUM GUTTER SPACES SHALL BE 5-3/4". SIDES, TOP AND BOTTOM, INCREASE FOR THROUGH FEEDERS. PROVIDE 25% COPPER GROUND BUS AND 100% COPPER NEUTRAL BUS AND INCREASE NEUTRAL BUS INDICATED. LOCKING TABS SHALL BE PROVIDED ON ALL CIRCUIT BREAKERS SERVING EMERGENCY LIGHTING, FIRE ALARM SYSTEM, SECURITY SYSTEMS AND OTHER EMERGENCY OR CRITICAL EQUIPMENT AND AS NOTED ON THE CONTRACT DRAWINGS. A TOTAL OF 5 SPARE LOCKING TABS SHALL BE FURNISHED TO THE OWNER.
- C. BUSES SHALL BE HARD DRAWN COPPER OF 98 PERCENT CONDUCTIVITY AND SHALL HAVE CROSS SECTIONAL AREAS LARGE ENOUGH TO LIMIT THE TEMPERATURE RISE, WHEN CARRYING FULL LOAD, TO 35 DEGREES C. ABOVE AN AMBIENT INSIDE THE ENCLOSURE OF 55 DEGREES C. AS DEFINED IN IEEE STANDARD RULES. MAIN BUS CAPACITY SHALL BE AS SHOWN ON THE CONTRACT DRAWINGS.
- D. ENCLOSURES SHALL BE SURFACE OR FLUSH AS INDICATED. TRIMS SHALL BE SECURED TO PANEL WITH MACHINE SCREWS. COVERS SHALL BE HINGED DOOR-IN-DOOR CONSTRUCTION WITH CYLINDER LOCKS AND CATCHES. LOCKS MUST BE COMPATIBLE WITH BUILDING STANDARD KEY SYSTEM AND WHEN NONE EXISTS, THEY SHALL BE SIMILAR TO A YALE NO. 911 KEY.
- E. DISTRIBUTION AND SUB-DISTRIBUTION PANELBOARD SHALL BE A MINIMUM OF 30" WIDE AND 10" DEEP.
- F. ALL STANDARD PANELBOARDS SHALL BE A MINIMUM OF 20" WIDE AND 5 3/4" DEEP.
- G. FURNISH ALL PANELBOARDS WITH FEED-THRU LUGS UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
- H. ALL NEW PANELBOARDS SHALL BE PROVIDED WITH AN ENGRAVED WHITE CORE LAMACOID NAMEPLATE, WITH 3/4 IN. WHITE LETTERING ON A BLACK BACKGROUND, WITH DESIGNATION LISTED (PANELBOARD NAME), FASTENED WITH EPOXY CEMENT OR OVAL HEAD CHROME PLATED MACHINE SCREWS.
- I. THE CIRCUIT DIRECTORY SHALL BE TYPEWRITTEN AND PROVIDED INSIDE EACH PANEL DOOR TO INDICATE EQUIPMENT AND/OR AREA SERVED. DIRECTORY HOLDER SHALL BE METAL FRAME WITH CLEAR PLASTIC, TRANSPARENT COVER. THE TYPEWRITTEN LIST INDICATING CIRCUIT NUMBERS, OUTLETS SUPPLIED AND THEIR LOCATIONS SHALL BE PROVIDED.
- J. TIE-BARS SHALL NOT BE USED TO CREATE MULTI-POLE CIRCUITS. MAXIMUM 42 CIRCUITS ALLOWED.
- L. ONLY ONE WIRE SHALL BE INSTALLED UNDER EACH CIRCUIT BREAKER LUG.
- M. SHORT CIRCUIT RATING OF PANELBOARDS SHALL NOT BE LESS THAN AS INDICATED ON THE CONTRACT DRAWINGS OR SPECIFIED HEREIN, WHERE NOT INDICATED OR SPECIFIED THE MINIMUM SHORT CIRCUIT RATING SHALL BE EQUAL TO THE INTERRUPTING CAPACITY OF THE LOWEST RATED CIRCUIT BREAKER IN THE PANELBOARD, BUT IN NO CASE LESS THAN 10,000 AMPERES R.M.S. SYMMETRICAL FOR 208/120 VOLT SYSTEM. SERIES RATED PANELBOARDS SHALL BE USED TO ACHIEVE REQUIRED SHORT CIRCUIT RATINGS.
- N. FOR ALL EXISTING PANELBOARDS, CONTRACTOR SHALL PROVIDE NEW CIRCUIT BREAKERS TO REPLACE EXISTING AS REQUIRED AS INDICATED ON DRAWINGS.




ELECTRICAL LIGHTING PLAN KEY NOTES:	
①	CONNECT NEW EMERGENCY AND EGRESS LIGHTING FIXTURES TO THE NEAREST LIGHTING CIRCUIT AHEAD OF ALL SWITCHING AND CONTROLS PER STATE AND LOCAL CODES.
②	COORDINATE EXACT LOCATION OF THE SWITCHES WITH OWNER/ARCHITECT.
③	PROVIDE TIME CLOCK FOR THE BUILDING SIGNAGE. E.C SHALL COORDINATE WITH THE ARCHITECT/OWNER FOR THE EXACT LOCATION. BASE BID ACCORDINGLY.
④	PROVIDE A DISCONNECT SWITCH AT FEEDER OR BRANCH CIRCUIT ENTERS THE SIGN PER NEC. VERIFY EXACT MOUNTING HEIGHT AND LOCATION FOR SIGNAGE POWER WITH ARCHITECTURAL ELEVATIONS, SIGN VENDOR, AND LANDLORD. ROUTE CIRCUIT TO PANEL VIA TIME CLOCK.
⑤	LIGHTING NEAR ELECTRICAL PANELS SHALL NOT BE CONTROLLED BY ANY AUTOMATIC MEANS AND SHALL BE COMPILED AS PER NEC 110.26(D).
⑥	INTERCONNECT EXHAUST FANS EF-1, 2, 3 & 4(N) WITH ROOM LIGHTS. E.C. TO COORDINATE WITH MECHANICAL DRAWINGS.

NOTES:(APPLY TO ALL FIXTURES WHERE APPLICABLE)	
A.	EMERGENCY FIXTURES - ALL FIXTURES INDICATED AS EMERGENCY SHALL BE PROVIDED WITH A 90-MINUTE BATTERY PACK AND ALL FLUORESCENT FIXTURES.
B.	VERIFY VOLTAGES - E.C SHALL VERIFY VOLTAGES ON DRAWINGS PRIOR TO ORDERING OR ANY WORK. THE ENGINEER SHALL BE NOTIFIED OF ANY DISCREPANCIES IN THE VOLTAGE OF THE CIRCUITING ON THE DRAWINGS AND THE LUMINAIRE SCHEDULE PRIOR TO ANY PURCHASE OR WORK.
C.	VERIFY LAMPING - E.C SHALL VERIFY LAMPING WITH THE MANUFACTURER PRIOR TO ORDERING AND NOTIFY THE ENGINEER OF ANY LAMPING DISCREPANCIES.
D.	PROVIDE A COMPLETE INSTALLATION - E.C SHALL PROVIDE ALL LABOR AND MATERIAL TO PROVIDE A COMPLETE AND FUNCTIONAL SYSTEM PER THE DESIGN INTENT AS DICTATED BY THE SWITCHING TYPE AND LOCATION (INCLUDING DIMMER SWITCHES AND COMPATIBLE BALLASTS OR TRANSFORMERS), CEILING TYPE AND LOCATION, CIRCUITING, VOLTAGES, AND LAMPING TYPES.

ELECTRICAL LIGHTING PLAN GENERAL NOTES:	
A.	CONTRACTOR ARE ADVISED TO UPDATE THE EMERGENCY LIGHT FIXTURES LOCATIONS/QUANTITY PER SITE REQUIREMENT UP ON FINAL INSPECTION OR PER LOCAL AHJ REQUIREMENT. ONE FOOT CANDLE OF EMERGENCY ILLUMINATION SHALL BE PROVIDED ALONG ALL EGRESS PATHWAYS AND EMERGENCY SIGN SHALL BE INSTALLED AT ALL INTERSECTIONS, EXIT CORRIDORS, PATHWAYS AND EXIT EGRESS OPENINGS IN ACCORDANCE WITH THE IBC 1008.3.1 MEANS OF EGRESS ILLUMINATION. THE EMERGENCY POWER SYSTEM SHALL PROVIDE POWER FOR A DURATION OF ≥90MINUTES AND SHALL CONSIST OF STORAGE BATTERIES.

Fixture Type	Description	Manufacturer	Model Number	Quantity	Fixture Wattage
A	1'X4' LIGHT FIXTURE	TBD	TBD	34	45W
B	SURFACE MOUNT CEILING LIGHT FIXTURE	TBD	TBD	9	75W
C	CHANDELIER DECORATIVE CANDLELABRA LAMPS	TBD	TBD	4	150W
D	PENDANT LIGHT FIXTURE	TBD	TBD	3	75W
E	UNDER CABINET STRIP LIGHTING	TBD	TBD	15FT	2W/FT
EX	EXIT LIGHT FIXTURE WITH EMERGENCY LIGHT COMBO. W/ BATTERY BACK-UP	TBD	TBD	5	4W






**ELECTRICAL LIGHTING PLAN KEY NOTES:**


- ① NEW 400A 20/208V, 3-PHASE, 4-WIRE ELECTRICAL METER, THE DISCONNECT & CT CABINET FOR THE PROJECT SPACE. E.C SHALL COORDINATE WITH UTILITY FOR CT CABINET EQUIPMENT & PROVIDE ONLY IF REQUIRED. PROVIDE PER UTILITY SPECIFICATIONS. E.C. SHALL ALSO COORDINATE WITH OWNER/LANDLORD/UTILITY COMPANY FOR LOCATION AND EQUIPMENT INSTALLATION. BASE BID ACCORDINGLY.
- ② NEW 400A(MCB), 120/208V, 3-PHASE, 4-WIRE ELECTRICAL PANEL "A". E.C. SHALL COORDINATE EXACT LOCATION WITH ARCHITECT/OWNER.
- ③ E.C. SHALL VERIFY/PERFORM THE INSTALLATION OF ELECTRICAL PANELS IN COMPLIANCE WITH NEC ARTICLE 110.26(A) AND (B). E.C. SHALL FIELD VERIFY THAT THE PANELS ARE UNOBSTRUCTED AND THE AREA WHERE THE PANELS ARE PLACED SHALL NOT BE USED AS A STORAGE SPACE.
- ④ ELECTRICAL CONTRACTOR SHALL COORDINATE ELECTRICAL CONNECTION TYPE AND POWER REQUIREMENT WITH EQUIPMENT & DISPLAY MANUFACTURER. REPORT ENGINEER ON RECORD FOR ANY DISCREPANCY. BASE BID ACCORDINGLY.
- ⑤ ELECTRICAL CONTRACTOR SHALL COORDINATE DISCONNECT AND FUSE REQUIREMENT FOR MECHANICAL UNIT WITH MECHANICAL CONTRACTOR AND EQUIPMENT MANUFACTURER PRIOR TO ROUGH-IN AND PROVIDE AS REQUIRED. LOCATE AS REQUIRED TO MAINTAIN NEC CLEARANCES. ELECTRICAL CONTRACTOR SHALL COORDINATE WITH THE MECHANICAL CONTRACTOR FOR EXACT LOCATION OF THE MECHANICAL UNITS IN THE FIELD.
- ⑥ ELECTRICAL CONTRACTOR SHALL COORDINATE WITH MECHANICAL CONTRACTOR FOR EXACT LOCATION AND POWER REQUIREMENT OF THE MECHANICAL UNIT IN FIELD. PROVIDE CIRCUIT AND CONTROL AS REQUIRED.
- ⑦ E.C. SHALL INTERCONNECT ONE HALF OF EACH DUPLEX RECEPTACLE TO THE ASSOCIATED OCCUPANCY SENSOR OR AUTOMATIC CONTROL DEVICE. RECEPTACLES SHALL BE PERMANENTLY MARKED "CONTROLLED" IN COMPLIANCE WITH ASHRAE 90.1 REQUIREMENTS. REPORT ANY DISCREPANCIES TO THE ENGINEER OF RECORD PRIOR TO BIDDING. BASE BID ACCORDINGLY.
- ⑧ INTERCONNECT EF-1(N) WITH AC-7(N) & AC-8(N). REFER TO MECHANICAL DRAWINGS FOR THE MORE DETAILS.
- ⑨ INTERCONNECT OAF-1(N) WITH AC-1(N) TO AC-8(N). REFER TO MECHANICAL DRAWINGS FOR THE MORE DETAILS.
- ⑩ PROVIDE POWER AND DATA CONNECTIONS FOR TELEVISION AT LOCATION SHOWN. VERIFY EXACT REQUIREMENTS PRIOR TO BID. COORDINATE WITH LOCATION AND MOUNTING HEIGHT WITH ARCHITECT AND OWNER PRIOR TO BID, ROUGH-IN AND INSTALL.
- ⑪ PROVIDE POWER FOR THE WORKSTATIONS. E.C. SHALL PROVIDE NECESSARY MOUNTING ARRANGEMENT FOR THE OUTLETS IN FIELD PER FIELD CONDITION. BASE BID ACCORDINGLY.
- ⑫ PROVIDE USB OUTLETS BELOW THE TABLE. E.C. SHALL RUN THE ELECTRICAL CONDUITS ON THE TABLE SUPPORTS PER THE FIELD CONDITION AND MAKE NECESSARY ARRANGEMENT FOR MOUNTING PER FIELD CONDITIONS. BASE BID ACCORDINGLY.

**ELECTRICAL FLOOR POWER PLAN GENERAL NOTES:**

- A. GENERAL USE CABLING SHALL BE OF #12 AWG MINIMUM AT 120V FOR CABLE UPTO 80 FEET. FOR CABLE ABOVE 80 FEET USE #10 AWG CABLES. ADJUST WIRE SIZE FOR A MAXIMUM VOLTAGE DROP OF 3%.
- B. CONTRACTOR TO COORDINATE WITH ARCHITECT FOR EXACT HEIGHT OF OUTLETS.
- C. E.C SHALL VERIFY ANY THIRD PARTY INSPECTION REQUIRED BY THE LOCAL JURISDICTION PRIOR TO BIDDING THIS PROJECT.
- D. ALL LOW VOLTAGE WIRING TO BE IN CONDUIT U.N.O. BY AHJ.
- E. E.C TO COORDINATE WITH MECHANICAL CONTRACTOR FOR MECHANICAL EQUIPMENTS, ITS SENSORS AND THERMOSTAT LOCATION.







PANEL: A(N)										MOUNTING:	REFER TO EL. POWER PLAN (EL. SHEET E)			
208Y/120 VOLTS,		3	PHASE,	4	WIRE	MAIN CB: 400A		MLO: NA	BUS: 400A MIN,	PANEL LOCATION:	REFER TO EL. POWER PLAN (EL. SHEET E)			
NOTE: L : LIGHTING, R : RECEPTACLES, H : HVAC LOAD, M : MOTOR LOAD, E : EQUIPMENT, O : OTHER/MISC. (TYPICAL)												FED FROM: REFER TO EL. RISER DIG. (EL. SHEET E30)		
CKT NO.	TRIP AMPS	DESCRIPTION OF LOAD	LOAD TYPE	LOAD (KVA)	MINIMUM BRANCH CIRCUIT	PER PHASE (KVA)			LOAD (KVA)	LOAD TYPE	DESCRIPTION OF LOAD	TRIP AMPS	CKT NO.	
1	20	LIGHTING-MANUFACTURING	L	1.00	2#12, #12G, 3/4"	2.20			2#12, #12G, 3/4"	1.20	E	DISHWASHER	20	2
3	20	LIGHTING - SALES/CIGAR LOUNGE & STORAGE CLOSET	L	1.30	2#12, #12G, 3/4"		2.40		2#12, #12G, 3/4"	1.10	E	MICROWAVE	20	4
5	20	LIGHTING- PHOTO/VIDEO SUITE & OFFICE 1, 2 & 3	L	0.79	2#12, #12G, 3/4"			1.99	2#12, #12G, 3/4"	1.20	E	REFRIGERATOR	20	6
7	20	BUILDING SIGNAGE	L	1.00	2#12, #12G, 3/4"	2.87			2#10, #10G, 3/4"	1.87	E	AUTOMATIC L-BAR SEALER	30/2P	8
9	20	RECEPTACLE - DISPLAY LIGHTING	R	1.00	2#12, #12G, 3/4"		2.87		2#10, #10G, 3/4"	1.87	E		10	
11	20	RECEPTACLE - ENGRAVING MACHINE	R	1.00	2#12, #12G, 3/4"			7.12	2#14, #12G, 1"	6.12	H		12	
13	20	RECEPTACLE - CIGAR AIR PUMP	R	1.00	2#12, #12G, 3/4"			7.12	2#14, #12G, 1"	6.12	H	HP-1(N) DISCONNECT-1	80/3P	14
15	20	RECEPTACLE - WORKSTATION	R	1.08	2#12, #12G, 3/4"		7.20		2#14, #12G, 1"	6.12	H		16	
17	20	RECEPTACLE - MANUFACTURING	R	1.08	2#12, #12G, 3/4"			7.20	2#14, #12G, 1"	6.12	H		18	
19	20	RECEPTACLE - PROJECTOR/TV	R	0.36	2#12, #12G, 3/4"	6.48			3#4, #12G, 1"	6.12	H	HP-1(N) DISCONNECT-2	80/3P	20
21	20	RECEPTACLE - CIGAR HUMIDOR CASE	R	1.08	2#12, #12G, 3/4"			7.20	2#14, #12G, 1"	6.12	H		22	
23	20	RECEPTACLE - LOW VOLTAGE/SECURITY	R	0.72	2#12, #12G, 3/4"	1.10		0.74	2#12, #12G, 3/4"	0.02	H	AC-1(N)	15/2P	24
25	20	RECEPTACLE - UNDER COUNTER USB	R	1.08	2#12, #12G, 3/4"				2#12, #12G, 3/4"	0.02	H	AC-2(N)	15/2P	26
27	20	GARBAGE DISPOSAL	E	0.78	2#12, #12G, 3/4"	0.80			2#12, #12G, 3/4"	0.02	H	AC-3(N)	15/2P	28
29	20	RECEPTACLE - COUNTER TOP	R	0.54	2#12, #12G, 3/4"	1.28		0.56	2#12, #12G, 3/4"	0.02	H	AC-4(N)	15/2P	30
31	20	RECEPTACLE - CORRIDOR	R	1.26	2#12, #12G, 3/4"				2#12, #12G, 3/4"	0.02	H	AC-5(N)	15/2P	32
33	20	RECEPTACLE - OFFICE 1	R	0.72	2#12, #12G, 3/4"	0.74			2#12, #12G, 3/4"	0.02	H	AC-6(N)	15/2P	34
35	20	RECEPTACLE - OFFICE 2	R	0.72	2#12, #12G, 3/4"		0.74		2#12, #12G, 3/4"	0.02	H	AC-7(N)	15/2P	36
37	20	RECEPTACLE - OFFICE 3	R	0.72	2#12, #12G, 3/4"	0.74			2#12, #12G, 3/4"	0.02	H	AC-8(N)	15/2P	38
39	20	RECEPTACLE - SALES/CIGAR LOUNGE & JANITOR CLOSET	R	0.54	2#12, #12G, 3/4"			0.56	2#12, #12G, 3/4"	0.02	H	EDH-1(N)	70/3P	40
41	20	RECEPTACLE - PHOTO/VIDEO SUITE 1	R	0.72	2#12, #12G, 3/4"			0.74	2#12, #12G, 3/4"	0.02	H	SPARE	20	42
43	20	RECEPTACLE - PHOTO/VIDEO SUITE 2	R	0.72	2#12, #12G, 3/4"	0.85			2#12, #12G, 3/4"	0.13	H	SPARE	20	44
45	15	ESE-1(N)	H	0.39	2#12, #12G, 3/4"			0.52	2#12, #12G, 3/4"	0.13	H	SPARE	20	46
47	15	ESE-2(N)	H	0.39	2#12, #12G, 3/4"			0.74	2#12, #12G, 3/4"	0.35	H	SPARE	20	48
49	15	HHS-1(N)	H	0.50	2#12, #12G, 3/4"	0.85			2#12, #12G, 3/4"	0.35	H	SPARE	20	50
51	15	HHS-2(N)	H	0.50	2#12, #12G, 3/4"	0.85			2#12, #12G, 3/4"	0.35	H	SPARE	20	52
53	20/2P	OAF-1(N)	M	0.62	2#12, #12G, 3/4"			0.98	2#12, #12G, 3/4"	0.69	H	SPARE	20	54
55	20/2P	EF-1(N)	M	0.62	2#12, #12G, 3/4"	7.22			3#4, #12G, 1"	6.59	H	EDH-1(N)	70/3P	56
59	20/2P		M	0.62	2#12, #12G, 3/4"		7.22		2#12, #12G, 3/4"	6.59	H	MOTORISED DAMPERS	20	60
61	20	RECEPTACLE - EXTERIOR	R	0.18	2#12, #12G, 3/4"	0.68			2#12, #12G, 3/4"	0.50	M	SPARE	20	62
63	20/2P	CONVEYER BELT	E	0.05	2#12, #12G, 3/4"			0.05	2#12, #12G, 3/4"			SPARE	20	64
67	20	SPARE	F	0.05				0.00				SPARE	20	66
69	20	SPARE						0.00				SPARE	20	68
71	20	SPARE						0.00				SPARE	20	70
									31.41	30.43	28.10			72

LOAD CLASSIFICATION	CONNECTED LOAD (KVA)	DEMAND FACTOR	DEMAND LOAD (KVA)	PANEL TOTAL LOAD
TOTAL LIGHTING	L	4.09	125%	5.11
TOTAL RECEPTACLE	R	14.52	100%	14.52
TOTAL HVAC	H	60.22	100%	60.22
TOTAL MOTOR	M	3.00	100%	3.00
TOTAL KITCHEN/EQUIPMENTS	E	8.11	100%	8.11
TOTAL OTHER/MISCELLANEOUS	O	0.00	100%	0.00
TOTAL CONNECTED LOAD		89.91	KVA	
TOTAL DEMAND LOAD		91.68	KVA	
TOTAL CONNECTED CURRENT		249.57	AMP	
TOTAL DEMAND CURRENT		254.47	AMP	
SYSTEM VOLTAGE				120/208V

**COMcheck Software Version COMcheckWeb**  
**Interior Lighting Compliance Certificate**

**Project Information**

Energy Code: 90.1 (2019) Standard  
Project Title: 1 WEST FOREST AVENUE  
Project Type: Alteration

Owner/Agent: Designer/Contractor:

**Allowed Interior Lighting Power**

A Area Category	B Floor Area (ft <sup>2</sup> )	C Allowed Watts / ft <sup>2</sup>	D Allowed Watts
1-Retail	2670	0.84	2243
Total Allowed Watts =			2243

**Proposed Interior Lighting Power**

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixture	D Watt.	E (C X D)
LED: A: 1'x4' LIGHT FIXTURE: Other: LED: B: SURFACE MOUNT CEILING LIGHT FIX: Other: LED: C: CHANDELIER DECORATIVE CANDLELABR: Other: Exemption:Lighting Sales or Educational Demonstration Systems LED: D: PENDANT LIGHT FIXTURE: Other: Exemption:Lighting Sales or Educational Demonstration Systems LED: E: UNDER CABINET STRIP LIGHTING: Other:	1	34	45	1530
	1	9	75	675
	1	4	150	Exempt
	1	3	75	Exempt
	1	15	2	30</td