



Project Name:

LTDXF

Client Name:

Id

Capacity:

ltd

1. Mechanical Screen

Sec01: General Data

Field	Value
Manufacturer	Ietos Factory
Service	Inlet Area
Fluid	Sewage
Operation	Automatic & Manual
Quantity of Units	1
Country of Origin	Egypt

Sec02: Design Data

Field	Value
Type	Mechanical Coarse Screen-Multi rack
Channel Height (mm)	400
Screen Width (mm)	250
Water Level (mm)	200
Bar Th (mm)	2.5
Bar Width (mm)	20
Bar Spacing (mm)	10
Inclination Degree (Deg)	25

Sec03: Gearmotor Data

Field	Value
Power Required (Wat)	514.29
Power Supply	380/3/50
Driving Unit Service Factor	2

Motor Insulation Protection	IP 65
Isolation / Temp. Class	Class F/B

Sec04: Control panel Data

Field	Value
Voltage	380
Phase	3
Frequency	50
Insulation Protection	IP 65
Panel Thickness	2

Sec05: Material Data

Field	Value
Screen Bars	Stainless Steel 316
Frame	Stainless Steel 316
Rack	Stainless Steel 316
Rack (Teeth)	Artelon
Sprockets	Stainless Steel 316

Sec06: Other Data

Field	Value
One Rack	Yes
Two sets of bearings	Yes

2. Manual Screen

Sec01: General Data

Field	Value
Manufacturer	Ietos Factory
Service	Inlet Area
Fluid	Sewage
Operation	Manual
Quantity of Units	1
Country of Origin	Egypt

Sec02: Design Data

Field	Value
Type	Bar Coarse Screen
Chanel Height (m)	2.5
Channel Width (m)	2
Water Level (m)	1.5
Bar Thickness (m)	0.25
Bar Width (m)	0.25
Bar Spacing (m)	0.25
Angle	45
Hand Rack Qty	2

Sec03: Material Data

Field	Value
Frame	Stainless Steel 316
Bars	Stainless Steel 316

Rake Tube	Stainless Steel 316
Rake Plate	Stainless Steel 316
Bolts & Nuts	A4