


SIMPSON CS16 STRAP X 22"
(11" EA. SIDE OF JOINT) OVER
TOP OF PLATE & BEAM W/ (20)
10D X 2 1/2" EA. SIDE,
INSTALL PER MFR. (IRC
R602.3.2)*

DBL. 2X4 TOP PLATE,
INTERRUPTED AT BEAM
OFFSET TOP PLATE END JOINTS
24" MIN. AWAY FROM BEAM (IRC
R602.3.2)*

2X4 STUDS @ 16" O.C.
(2) 2X4 KING STUDS, END NAIL
TO BEAM W/ (4) 16D (IRC
R602.7.5)*

(2) 2X4 JACK STUDS



FLUSH BEAM AT TOP PLATE – ELEVATION

SCALE: 1" = 1'-0"

DETAIL	PROJECT	SCALE	DRAWN	DATE	DETAIL NO
FLUSH BEAM AT TOP PLATE – ELEVATION		1" = 1'-0"	KERF REFERENCE	2026-10-05	1/S-502