ENERGYMIND TUNISIA · TSYP CHALLENGE

Human–AI Escalation and Governance

Technical report section: research foundations, formal escalation model, conceptual design and evaluation of the governance layer

---

Prototype on a simulated, Tunisia-calibrated network · all thresholds are prototype parameters, not STEG values
Grounded in Corvelo Benz & Gomez Rodriguez (2024) and Mozannar & Sontag (ICML 2020)
October 2026

Contents

3. Human–AI Escalation and Governance
3.1 Objectives and design principles
3.2 Research foundations
3.3 Conceptual design
3.4 Risk and confidence assessment
3.5 Human–AI escalation policy
3.6 Operator interaction
3.7 Auditability and feedback
3.8 Future learning-to-defer extension (Version 2)
3.9 Evaluation strategy
3.10 Prototype implementation
3.11 Research traceability
3.12 Limitations
References

3. Human–AI Escalation and Governance

EnergyMind Tunisia, TSYP challenge. Technical report section.

> **Scope and status.** This section describes the governance layer of EnergyMind: the component that decides whether the AI may act on a diagnosed event or must defer to a human operator. The prototype runs on a simulated, Tunisia-calibrated network and does not control real STEG equipment. All numerical thresholds are **prototype parameters** chosen for the simulation; none is an official STEG value. Statements attributed to the two reference papers [1], [2] are limited to what those papers state; everything else is identified as an EnergyMind design decision.

3.1 Objectives and design principles

The detection layer of EnergyMind answers *"is something abnormal?"* and the diagnosis layer answers *"what is the most likely explanation?"*, choosing among `NORMAL`, `GENUINE_EVENT`, `METER_FAULT` and `SUSPICIOUS_DATA`. Neither answers the governance question: **who should decide or act, and under which conditions?**

That question cannot be reduced to model confidence. An anomaly score measures how unusual data look, not why. A correct diagnosis says nothing about the cost of being wrong: the same diagnosis on a residential meter and on a hospital feeder has very different consequences. And the right level of autonomy depends on the action: requesting another measurement is harmless if the diagnosis is wrong, while switching a feeder or declaring a customer fraudulent is not.

The governance layer is therefore designed around five principles:

#	Principle	Consequence in the design
P1	**Autonomy is granted per action, not per event**	One event may trigger safe automatic actions while its consequential action stays locked behind approval
P2	**Escalation is monotone**	Rules may raise the governance level, never lower it; high confidence cannot override critical risk
P3	**Independent human judgement first**	In reviewed cases the operator records a diagnosis and confidence *before* seeing the AI output
P4	**No default privilege**	Neither AI nor operator wins a disagreement by default; strong disagreement triggers evidence gathering and a second review
P5	**Optimise the human + AI system**	Success is measured on the combined system (accuracy, safety, workload), not on AI accuracy alone

The objective is **appropriate reliance**: the AI handles the large volume of routine, low-consequence events by itself, and operators spend their attention where they add value or where the stakes require human authority. Full automation is explicitly *not* the goal.

3.2 Research foundations

3.2.1 Human-aligned calibration (Corvelo Benz & Gomez Rodriguez [1])

Setting. A decision maker observes features (x, v), where v may be available only to the human, forms her own confidence H that the binary label is $Y = 1$ **before** seeing the AI, then observes the classifier's confidence $B = f_B(X, H) \in [0, 1]$ and takes a decision $T \in \{0, 1\}$ with utility $u(T, Y)$. The paper models this as a structural causal model:

$$H = f_H(X, V, Q), \qquad B = f_B(X, H), \qquad T = \pi(H, B, W), \qquad U = u(T, Y)$$

where Q and W are the decision maker's individual noise terms. Following behavioural studies, H takes values in a small ordered set; the experiments use three levels (low, mid, high).

Monotone (rational) policies. A policy is *monotone* if more confidence, human or AI, never yields a less positive decision:

$$b \le b',\ h \le h' \implies \pi(h, b, w) \le \pi(h', b', w).$$

Calibration is not sufficient. The usual requirement is that the AI's confidence be calibrated, $P(Y = 1 \mid f_B(Z) = b) = b$. The paper's **Theorem 3** shows that there exist processes in which f_B is *perfectly calibrated* and f_H is monotone, yet **every monotone policy is suboptimal**. The reason is that calibration holds on average over human confidence levels but can fail, or even reverse, *within* a given level $H = h$.

Human-alignment. The fix is to require that the positive rate increases jointly in both confidences. Informally, f_B is α-aligned with f_H if, for $b' \le b''$ and $h' \le h''$ (on all but a small fraction of each level),

$$P\big(Y = 1 \mid f_B = b',\, H = h'\big) - P\big(Y = 1 \mid f_B = b'',\, H = h''\big) \ \le\ \alpha.$$

Under alignment there exists a monotone policy that is near-optimal (**Theorem 5**), and **multicalibration** of f_B with respect to the human confidence levels $\{S_h\}_h$ is a sufficient condition for alignment (**Theorem 8**). It can be implemented by running a calibration method separately for each human confidence level.

Empirical evidence. On the Human–AI Interactions dataset (15,063 predictions from 471 US participants, four tasks), participants recorded confidence before (h) and after (h_{+AI}) the AI advice. The shift $h_{+AI} - h$ increased **monotonically with the AI's confidence** in all four tasks: people treat higher AI confidence as stronger evidence, whatever their own prior. Human+AI decisions beat human-only decisions in all four tasks, but beat AI-only decisions in only one, the task with the fewest alignment violations. The authors note the data are observational and that a controlled study is still needed.

What EnergyMind takes from [1]. (i) Operator and AI confidence are treated jointly, never one in isolation; (ii) operator confidence is elicited on three ordinal levels **before** the AI output is shown; (iii) both h and h_{+AI} are logged; (iv) the paper's alignment metrics are used to audit the system (§3.9). Multicalibration with respect to operator confidence is deferred until outcome-labelled operator data exist.

Limits for EnergyMind. The theory is binary while EnergyMind has four classes; it was tested with lay participants on non-safety tasks; and sequential, time-pressured decisions are listed by the authors as open. The paper does **not** discuss deferral, escalation, interfaces or disagreement as a governance signal; those are EnergyMind interpretations.

3.2.2 Learning to defer (Mozannar & Sontag [2])

Setting. A predictor $\hat{Y} : \mathcal{X} \to \mathcal{Y} \cup \{\perp\}$ either predicts a label or defers ($\perp$) to an expert M who may hold side information. It is built from a **classifier** $h : \mathcal{X} \to \mathcal{Y}$ and a **rejector** $r : \mathcal{X} \to \{0, 1\}$ ($r = 1$ means defer). The objective is the loss of the **combined system**:

$$L(h, r) \;=\; \mathbb{E}_{(x,y)\sim P,\; m\sim M|(x,y)}\Big[\,\ell(x, y, h(x))\,1_{r(x)=0} \;+\; \ell_{\exp}(x, y, m)\,1_{r(x)=1}\Big].$$

With 0–1 losses this becomes

$$L_{0\text{-}1}(h, r) = \mathbb{E}\big[1_{h(x)\neq y}\,1_{r(x)=0} + 1_{m\neq y}\,1_{r(x)=1}\big],$$

and the paper notes that an additive per-instance cost of querying the expert, $\ell_{\exp} = 1_{m\neq y} + c(x)$, fits the same analysis.

Bayes-optimal deferral (Proposition 2). With $\eta_y(x) = P(Y = y \mid X = x)$:

$$h^B(x) = \arg\max_y\, \eta_y(x), \qquad r^B(x) = 1\Big[\max_y\, \eta_y(x) \;\leq\; P(M = Y \mid X = x)\Big].$$

In words: **defer exactly when the expert is at least as likely to be right as the classifier's best guess.**

Consistent surrogate. The deferral decision is added as an extra output $g_\perp$ of the network, and the paper proposes the convex, consistent loss

$$L_{CE}(g, x, y, m) = -\log \frac{e^{g_y(x)}}{\sum_{y'\in\mathcal{Y}\cup\{\perp\}} e^{g_{y'}(x)}} \;-\; 1_{m=y}\,\log \frac{e^{g_\perp(x)}}{\sum_{y'\in\mathcal{Y}\cup\{\perp\}} e^{g_{y'}(x)}},$$

with a variant L^α_{CE} that reweights cases where the expert is correct. Training requires samples (x_i, y_i, m_i): **input, ground truth, and the expert's decision.** The paper's generalisation bound depends on the expert's error rate and indicates that learning to defer is more sample-intensive than plain rejection learning.

Coverage. The fraction of cases the classifier handles alone,

$$\text{coverage} = \frac{1}{N}\sum_{i=1}^{N} 1\big[r(x_i) = 0\big],$$

is the central trade-off variable. The paper plots classifier accuracy on non-deferred cases and system AU-ROC against coverage, obtaining a target coverage by thresholding a deferral score, and finds that the combined system outperforms both the classifier and the expert alone. Most of its experts are **synthetic** (perfect on some classes, or correct with probability p or q depending on subgroup).

What EnergyMind takes from [2]. The explicit defer outcome; the classifier + rejector decomposition as the target architecture (Version 2); the system-level objective; coverage as a primary metric; the coverage-sweep experiment; the (x, y, m) logging requirement; synthetic experts for prototyping.

Limits for EnergyMind. [2] has no notion of safety constraints, irreversible actions or asset criticality, and a learned rejector may choose to automate anything. It models a single expert distribution, while a control room has several operators. Its deferred expert decides alone, without seeing the AI. These gaps are handled by EnergyMind's own design (§3.5, §3.8).


3.2.3 Summary

Paper	Key contribution	EnergyMind implication	Version 1 (now)	Version 2 (future)
Corvelo Benz & Gomez Rodriguez [1]	Calibrated AI confidence can mislead a human who has her own confidence; human-aligned confidence supports optimal monotone decisions; humans move toward higher AI confidence	Treat operator and AI confidence jointly; capture operator confidence before AI advice; audit alignment	Blind-first review, 3-level operator confidence, agreement states, logging of h and h_{+AI}	Multicalibrate AI confidence per operator confidence level
Mozannar & Sontag [2]	Classifier + rejector trained on the system loss; Bayes rule defers when the expert is more likely right; coverage trade-off	Deferral is a first-class output; automation level is an operating point	Rule-based deferral; coverage measured; coverage sweep with synthetic operators	Learned rejector trained on logged (x, y, m), inside a rule-based safety envelope


3.3 Conceptual design

3.3.1 End-to-end architecture

(a) Runtime decision flow



(b) Logging and learning loop



Three features are deliberate. The **epistemic** and **consequence** paths stay separate until the policy is applied, so confidence cannot dilute risk. The **blind judgement sits before the final routing**, because the agreement state is an input to the decision. The **learned rejector plugs into the policy rather than replacing it**, so the safety rules keep bounding what it can automate.

3.3.2 Five quantities that must not be merged

Quantity	Question	Scale	Source
Anomaly score $s(x)$	How unusual are the data?	detector-specific, **not a probability**	detection layer
AI confidence $p(\hat{c} \mid x)$	How sure is the diagnosis?	calibrated probability $[0, 1]$ + band	diagnosis model + calibrator
Severity σ	How significant is the event technically?	LOW < MEDIUM < HIGH < CRITICAL	severity assessor
Asset criticality κ	How important is the asset?	LOW < MEDIUM < HIGH < CRITICAL	static asset registry
Risk ρ	What happens if the governance decision is wrong?	LOW < MEDIUM < HIGH < CRITICAL	derived, §3.4

A high anomaly score does not imply a confident diagnosis, a confident diagnosis does not imply low risk, and a severe event may be well understood. Only risk is derived from the others, by an explicit rule.

3.3.3 Governance levels

Level	Route	Who decides	What may run automatically	Typical case
G0	`MONITOR`	AI	nothing	NORMAL, confident, familiar
G1	`AUTO_SAFE_ACTION`	AI	whitelisted reversible, non-physical actions	confident meter freeze on a residential meter
G2a	`AI_RECOMMENDATION`	AI proposes, operator acknowledges	G1 actions only	probable meter fault, inspection suggested
G2b	`HUMAN_REVIEW`	operator, after blind judgement	G1 actions only	moderate uncertainty, disagreement, OOD, suspicious data, high risk

Level	Route	Who decides	What may run automatically	Typical case
G3	`HUMAN_APPROVAL_REQUIRED`	named operator with written justification (two people if risk is CRITICAL)	G1 actions only; locked actions never run on timeout	breaker or switching operation, disconnection, control-setting change, fraud declaration, critical asset

`REQUEST_MORE_DATA` and `SECOND_REVIEW` are **procedures** that overlay G2a–G3, not levels. In learning-to-defer terms, G0–G1 are "AI handles" and G2a–G3 are "defer".

3.4 Risk and confidence assessment

3.4.1 Confidence bands

Let $\hat{c} = \arg\max_c p(c \mid x)$ be the diagnosis and $p^\star = p(\hat{c} \mid x)$ its calibrated probability. With class-specific prototype thresholds $\tau_c^{\text{low}} < \tau_c^{\text{high}}$:

$$\text{band}(x) = \begin{cases} \text{HIGH} & p^\star \geq \tau_{\hat{c}}^{\text{high}} \\ \text{LOW} & p^\star < \tau_{\hat{c}}^{\text{low}} \\ \text{MEDIUM} & \text{otherwise} \end{cases} \qquad \text{margin}(x) = p_{(1)} - p_{(2)}.$$

The band is **capped at MEDIUM** if the input is not in distribution, data quality is not GOOD, or calibration is not validated for that class, because calibrated probabilities cannot be trusted at face value in those situations.

Prototype values: $\tau^{\text{high}} = 0.90$ (0.85 for GENUINE_EVENT), $\tau^{\text{low}} = 0.60$, minimum margin 0.30.

3.4.2 Risk derivation

Risk has two sides: acting when we should not, and not acting when we should.

Wrong-action risk of a proposed action a on an asset with criticality κ:

$$\rho_{\text{act}}(a) = \begin{cases} \max\big(\beta(a) \oplus 1_{\text{irrev}(a)},\ \kappa\big) & \text{if } a \text{ is physical or customer-affecting} \\ \beta(a) \oplus 1_{\text{irrev}(a)} & \text{otherwise} \end{cases}$$

where $\beta(a)$ is the base risk of the action class (LOW for informational and data handling, MEDIUM for operational, HIGH for physical, customer-affecting and accusatory actions) and $\oplus 1$ raises a level by one step.

Missed-event risk uses the severity of the **most severe plausible hypothesis**, so a confident METER_FAULT diagnosis does not hide a plausible GENUINE_EVENT:

$$\sigma^\star(x) = \max_{c\,:\,p(c|x) \geq \rho_{\text{plaus}}} \sigma(c), \qquad \rho_{\text{miss}} = \mathbf{M}\big[\kappa,\ \sigma^\star\big],$$

with $\rho_{\text{plaus}} = 0.05$ (prototype) and the ordinal matrix

Criticality \ Severity	LOW	MEDIUM	HIGH	CRITICAL
LOW	LOW	LOW	MEDIUM	HIGH
MEDIUM	LOW	MEDIUM	MEDIUM	HIGH
HIGH	MEDIUM	MEDIUM	HIGH	CRITICAL
CRITICAL	MEDIUM	HIGH	CRITICAL	CRITICAL

Case risk is the worst of both:

$$\rho_{\text{case}} = \max\left(\rho_{\text{miss}},\ \max_{a \in A} \rho_{\text{act}}(a)\right).$$

Why a maximum and not a weighted sum. The scales are ordinal, so multiplying or averaging their ranks has no meaning. More importantly, a low value on one dimension must never compensate for a high value on another: "low severity" must not cancel "hospital feeder". The price is conservatism (more escalations), which is measured by the false-escalation rate (§3.9) rather than assumed acceptable.

3.5 Human–AI escalation policy

3.5.1 Routing as a maximum of rule floors

Order the routes $G0 \prec G1 \prec G2a \prec G2b \prec G3$. Each rule R_k maps an event e to a floor $f_k(e)$, with $f_k(e) = G0$ when the rule does not apply. The route is

$$\text{route}(e) \ = \ \max_{k}\ f_k(e).$$

Rule	Condition	Floor / effect	Tunable
R0 Input validity	missing inputs, unregistered asset, unapproved model version	≥ G2b	no
R1 Hard action	action physical, customer-affecting, accusatory or irreversible	action locked; G3	no
R2 Consequence	ρ_{case} = CRITICAL, or κ = CRITICAL with a non-NORMAL diagnosis	≥ G2b, consequential actions locked, two-person approval if CRITICAL risk	no
R2b	ρ_{case} = HIGH	≥ G2b	no
R3 Agreement	strong disagreement	≥ G2b + second review + more data + freeze	no
R3b	partial disagreement / weak agreement	≥ G2b	no
R4 Familiarity	out of distribution / insufficient data	≥ G2b + more data (+ freeze if OOD)	thresholds
R5 Confidence	LOW band or strong evidence conflict	≥ G2b + more data	yes

Rule	Condition	Floor / effect	Tunable
R5b	MEDIUM band, small margin or partial conflict	≥ G2a	yes
R6 Diagnosis default	NORMAL → G0; METER_FAULT → G1 (G2b if high severity); GENUINE_EVENT → G2a (G2b if severity ≥ MEDIUM); SUSPICIOUS_DATA → G2b	floor	yes
R7 Recurrence	too many automatic actions on the same asset in a window	≥ G2b	yes
R8 Workload	queue strained or overloaded	**priority and deadlines only, never the route**	yes
R9 Consistency	a locked action exists → G3; a proposed action exists → ≥ G2a	floor	no

Proposition (critical consequence dominates confidence). Fix the diagnosis label $\hat{c} \neq$ NORMAL, the asset and the proposed actions. Then, **for every value of the AI confidence** $p^\star$: (a) every hard action (physical, customer-affecting, accusatory or irreversible) is locked and $\text{route}(e) = G3$; (b) if the asset criticality is CRITICAL, $\text{route}(e) \succeq G2b$ and every proposed non-whitelisted action is locked, so $\text{route}(e) = G3$ whenever one is proposed.

Proof. The hard-action condition of R1 depends only on the action catalogue, and the criticality branch of R2 depends only on κ and the label $\hat{c}$; neither depends on $p^\star$. R1 locks hard actions; the R2 criticality branch sets a G2b floor and locks every proposed non-whitelisted action; R9 then sets G3 whenever an action is locked. Because the route is a maximum of floors, a change in $p^\star$ can lower only the floors that depend on it (R4b, R5, and R3 through the band), never these. Hence (a) and (b) hold for all $p^\star$. □

The confidence does influence the *missed-event* part of the risk, through the plausible hypotheses in $\sigma^\star$: a more confident diagnosis can rule out a severe alternative. That is intended. Confidence is allowed to resolve doubt about *what happened*, never to change *what is at stake if the action is wrong*.

This is the formal version of the requirement that a 98%-confident diagnosis on a hospital feeder must not trigger automatic action. The property is also checked by property-based tests on 400 random events in the prototype code.

3.5.2 Two-pass evaluation

1. **Pass 1** applies all rules except R3. If the route is G2b or above, or the case is drawn for the audit sample, the operator is asked for a blind judgement.
2. **Pass 2** adds R3. Since R3 can only raise floors, $\text{route}_2(e) \succeq \text{route}_1(e)$, so the blind phase never has to be undone.

3.5.3 Agreement states

Let (d_A, b) be the AI's diagnosis and band, and (d_H, h) the operator's blind diagnosis and level, with ranks LOW = 0, MEDIUM/MID = 1, HIGH = 2. A pair of classes is **critical** if confusing them changes the type of response; in the prototype, the critical pairs are

{GENUINE_EVENT, METER_FAULT}, {GENUINE_EVENT, SUSPICIOUS_DATA} and {GENUINE_EVENT, NORMAL}.

$$\text{agree}(e) = \begin{cases} \text{NOT_ASSESSED} & \text{no blind judgement} \\ \text{AGREEMENT} & d_H = d_A,\ \min(b,h) \geq 1 \\ \text{WEAK_AGREEMENT} & d_H = d_A,\ \min(b,h) = 0 \\ \text{PARTIAL} & d_H \neq d_A,\ p(d_H \mid x) \geq \rho_{\text{partial}} \\ \text{STRONG} & d_H \neq d_A,\ p(d_H \mid x) < \rho_{\text{partial}},\ \Gamma(e) \\ \text{PARTIAL} & \text{otherwise} \end{cases}$$

where $\Gamma(e) \equiv \big(b = h = 2\big) \vee \big(\{d_A, d_H\} \text{ is a critical pair} \wedge b \geq 1 \wedge h \geq 1\big)$, and $\rho_{\text{partial}} = 0.20$ (prototype).

State	Routing effect	Why
AGREEMENT	none, **never lowers the route**	two concordant judgements may share a blind spot
WEAK_AGREEMENT	≥ G2b + more data	same label, but someone is guessing
PARTIAL	≥ G2b	competing hypotheses
STRONG	≥ G2b + second review + more data + **freeze**	one party is confidently wrong; resolve by evidence, not authority

The use of disagreement as an escalation signal is an EnergyMind design decision. It is motivated by [1], which shows that both confidences carry information and that people move toward the AI's stated confidence, so the operator's view is only independent if it is captured first.

3.5.4 Request-more-data loop

When neither party is confident, the engine schedules information-gathering actions matched to the competing hypotheses: neighbour measurements and electrical-consistency checks (GENUINE_EVENT vs. sensor or data problems), history windows and redundant reads (METER_FAULT), consistency checks (SUSPICIOUS_DATA). All of these are G1 actions. The case is then re-evaluated with the new evidence. The loop is bounded (≤ 2 rounds in the prototype); when the budget is exhausted, the case goes to a supervisor with no consequential action taken. New evidence may raise the route but never lowers an escalated case: only a human closes it.

3.6 Operator interaction

The console presents a reviewed case in two phases.

```
PHASE 1 - BLIND ASSESSMENT                PHASE 2 - REVEAL AND DECIDE
+-----------------------------------+   +-----------------------------------------+
| Evidence only: trends, neighbours,  |   | Your view (locked)  |  AI view          |
| data quality, severity, criticality |   | GENUINE_EVENT HIGH  |  METER_FAULT HIGH |
| (AI diagnosis hidden)               |   |                     |  ~9 in 10 correct |
|                                     |   |                     |  in validation    |
| Your diagnosis: [GENUINE_EVENT]     |   | !! STRONG DISAGREEMENT - actions locked |
| Your confidence: LOW / MID / HIGH   |   | Why here: R3, R6    Data requested: ... |
|            [Submit, show AI view]   |   | [APPROVE] [OVERRIDE] [MORE DATA] [2ND]  |
+-----------------------------------+   +-----------------------------------------+
```

Against over-trust (automation bias): blind-first judgement; confidence shown as a band plus a validated frequency ("right about 9 in 10 in validation, simulated, n = 412") instead of false-precision percentages, and no frequency at all when calibration is not validated or the input is unfamiliar; the runner-up hypothesis always shown; neutral, equal-size buttons with no default; written justification for G3 approvals and all overrides; two-person approval for CRITICAL risk; monitoring of approvals that are implausibly fast or frequent.

Against under-trust: most routine events never reach the operator (G0/G1), so review load stays proportionate; per-event-type track records of both AI and operators; outcome feedback showing operators where the AI was right and they were not, and vice versa; similar past incidents from the log; an explicit list of situations the model was not validated for; a consistent layout across all cases.

Why the operator is not asked about everything. The blind judgement is requested only for escalated cases (G2b, G3) and for a small random **audit sample** of automatically handled cases (5% in the prototype). Escalated cases need a person anyway, so the extra step costs seconds. The audit sample is what makes errors in the automated region observable at all.

3.7 Auditability and feedback

Every decision and human action is appended to a **hash-chained** JSON log. Record k stores $\text{hash}_k = \text{SHA256}(\text{record}_k \,\|\, \text{hash}_{k-1})$, so any later edit or deletion breaks the chain. Each record contains the AI outputs (anomaly score, class probabilities, confidence, band, OOD status), the assessed consequence (severity, criticality, per-action risk and gate), the operator's blind and post-reveal judgements, the agreement state, the route and every rule that fired, data requests, the final decision with its justification, the ground truth and its source when available, and the model, policy and threshold versions.

From the log, the feedback store builds one training record per case with verified outcome:

$$\left(x_i,\ y_i,\ \hat{y}_i^{AI},\ p_i^{\star},\ m_i,\ h_i,\ m_i^{+AI}\right),$$

with correctness indicators $a_i = 1[\hat{y}_i^{AI} = y_i]$ and $o_i = 1[m_i = y_i]$.

Three rules keep these data valid:

1. The operator's **final decision is not ground truth**; y comes from simulation labels, field inspection or later confirmation.
2. The expert label m used for learning is the **blind** judgement. The post-reveal judgement m^{+AI} is influenced by the AI, as [1] shows, and would teach a rejector to defer to an echo of itself.
3. Automatically handled cases are labelled through the audit sample, so the classifier's error in the region where it acts alone can be estimated.

3.7.1 Operator calibration phase

Before learned deferral can be trained, EnergyMind needs operator decisions with known outcomes. A dedicated **calibration phase** collects them efficiently: the console replays simulated events with known ground truth, and operators give a blind diagnosis and confidence with no AI output shown, then see the correct answer (which also serves as training). This produces, for each operator *o* and event class *c*, an accuracy estimate

$$\hat{a}_o(c) = \frac{1}{n_{o,c}} \sum_{i\,:\,\mathrm{op}(i)=o,\ y_i=c} 1[m_i = y_i],$$

reported with a confidence interval (e.g. Wilson) because $n_{o,c}$ will be small for rare events. A known operator weakness does **not** by itself justify handing those cases to the AI. That follows only if the AI is more accurate on the same cases ($\hat{a}_{AI}(c) > \hat{a}_o(c)$ with non-overlapping intervals) **and** the safety rules R0–R3 allow automation. Where both are weak, the answer is more data or better sensors, not automation.


3.8 Future learning-to-defer extension (Version 2)

Version 1 is rule-based because EnergyMind has no historical STEG operator decisions. Version 2 replaces only the tunable rules (R5–R6) with a learned rejector following [2]. The immutable rules R0–R3 remain above it as a **safety envelope**:

$$\mathrm{route}_{V2}(e) \;=\; \max\Big(\,E(e),\;\; \phi\big(r_\theta(x)\big)\Big), \qquad E(e) = \max_{k\in\{R0,R1,R2,R3,R9\}} f_k(e) \;\;\text{(safety envelope)},$$

$$\phi(r) = \begin{cases} G1 & r = 0 \;(\texttt{AI_HANDLE}) \\ G2b & r = 1 \;(\texttt{DEFER_TO_OPERATOR}) \end{cases} \qquad \text{(learned rejector } r_\theta)$$

Because of the maximum, the learned rejector can only move cases between automatic handling and review **inside the region the rules already permit to automate**. It can never automate a hard action or a critical case.



Risk-weighted costs (EnergyMind adaptation). [2] permits general costs; EnergyMind uses

$$\ell(x, y, \hat{y}) = C[y, \hat{y}], \qquad \ell_{\text{exp}}(x, y, m) = C[y, m] + c(x),$$

where C penalises dangerous confusions more (e.g. predicting METER_FAULT when the truth is GENUINE_EVENT), and $c(x)$ represents operator time, growing with queue load and urgency. The matrix values are project choices, not literature.

Staged roadmap.

1. **V2-sim (possible now):** train on simulated events with synthetic operators of varying expertise, as [2] did. This validates the pipeline; it says nothing about real operators.
2. **V2a:** a confidence-score rejector, estimating $P(M = Y \mid x)$ from calibration-phase and audit data and deferring when it exceeds $p^\star$ (the empirical version of r^B).
3. **V2b:** joint training of classifier and rejector with L_{CE}, once data suffice.
4. **Shadow mode** before any switch: the learned rejector runs beside V1, decisions are logged but not used, and it is promoted only if it matches or improves V1 on system error and missed escalations at equal or lower review load.

Data requirements. Tuples (x, y, m) with blind m; coverage of all four classes and main asset types; enough operator errors per class (the bound in [2] depends on the expert error rate); labels in the automated region; a stable operator population. Neither paper gives a minimum sample size for this domain, and none is claimed here.

3.9 Evaluation strategy

The governance layer is evaluated as a human–AI system on simulated event streams with known ground truth, with synthetic operator profiles and, where possible, a small user study. Let D be the set of deferred cases (G2a–G3) and A the automated cases (G0–G1), $N = |A| + |D|$.

Metric	Definition
Coverage	$\lvert A\rvert / N$
Review rate	cases at G2b or G3 / N
Approval rate	approved G3 actions / G3 actions
Override rate	overrides / reviewed cases
Strong-disagreement rate	STRONG / cases with blind judgement
False-escalation rate	deferred cases where the AI was right and true risk was below the review level / $\lvert D\rvert$
Missed-escalation rate	automated cases where the AI was wrong or true risk required review / $\lvert A\rvert$
Unsafe automatic-action rate	inappropriate automatic actions / automatic actions; **policy violations must be exactly 0**
AI accuracy on non-deferred	$\frac{1}{\lvert A\rvert}\sum_{i \in A} a_i$

Metric	Definition
Operator accuracy on deferred	$\frac{1}{\lvert D\rvert}\sum_{i\in D} o_i$ (blind) and final-decision accuracy
System accuracy	$\frac{1}{N}\Big(\sum_{i\in A} a_i + \sum_{i\in D} 1[\text{final}_i = y_i]\Big)$
Cost-weighted system loss	$\frac{1}{N}\sum_i \big(\ell_i + c_i\, 1[i\in D]\big)$ with ℓ from the cost matrix C
Reliance	over-reliance: accepted when AI wrong; under-reliance: overridden when AI right; switch rate $m \neq m^{+AI}$
Response time, workload	median and 90th-percentile decision time per level; cases per operator-hour

Coverage vs. performance experiment (after [2]). Sort cases by a deferral score $q(x)$ (V1: $q = \tau_{\hat{c}} - p^{\star}$; V2-sim: $g_{\perp} - \max_y g_y$), sweep a threshold to obtain coverage from 0 up to the **coverage ceiling** (the share of cases not forced to review by R0–R3), and plot system accuracy, AI accuracy on non-deferred cases, cost-weighted loss and missed-escalation rate against coverage, one curve per synthetic operator profile, with the V1 policy as a marked point and operator capacity as a workload line. *Hypotheses, not results:* AI accuracy on non-deferred cases falls as coverage rises; system accuracy peaks at intermediate coverage when operator and AI strengths differ; a V1 point far below the curve means thresholds are misplaced.

Alignment audit (after [1]). One class at a time, with outcome $1[y = c]$, AI confidence $p(c \mid x)$ in 8 bins and operator level in {LOW, MID, HIGH}, estimate the positive rate per cell (cells with at least 30 samples) and count alignment violations: pairs of cells with higher AI and operator confidence but a lower positive rate. Summaries:

$$\mathrm{EAE} = \frac{1}{N_{\text{pairs}}} \sum_{h\le h',\, b\le b'} \Big[P(Y{=}1 \mid h, b) - P(Y{=}1 \mid h', b')\Big]_{+},$$

$$\mathrm{MAE} = \max_{h\le h',\, b\le b'} \Big[P(Y{=}1 \mid h, b) - P(Y{=}1 \mid h', b')\Big].$$

Also plot $h_{+AI} - h$ against AI confidence to check whether operators move toward the AI. Many violations would make multicalibration per operator level a priority for V2. Mapping operator confidence to the one-vs-rest proposition (their level if they chose c, LOW otherwise) is an EnergyMind approximation.

Complementarity matrix. Per event class, asset type, severity and operator profile:

	Operator correct ($o = 1$)	Operator wrong ($o = 0$)
AI correct ($a = 1$)	both reliable: review adds little; automation candidate if rules allow	AI better: deferral wastes effort; automation candidate if rules allow
AI wrong ($a = 0$)	operator better (often side information): must stay deferred; what a rejector must learn	neither reliable: more data or sensors; never automate

The "operator better" cell contains the positive examples for learned deferral; the "neither" cell is a data-collection target, not a routing problem. This is the empirical

counterpart of the complementarity argument in [2].

3.10 Prototype implementation

The Version 1 engine is implemented in Python (Pydantic models, YAML policy configuration, hash-chained JSONL audit log) in `governance/prototype/`. The six reference scenarios run end to end as automated tests, and five safety invariants are verified with property-based tests on 400 random events each.

Scenario	AI output	Key inputs	Outcome
S1 Residential meter freeze	METER_FAULT 0.95 (HIGH)	criticality LOW, severity LOW	`AUTO_SAFE_ACTION`: quarantine data, re-read, ticket
S2 Hospital feeder voltage sag	GENUINE_EVENT 0.98 (HIGH)	criticality CRITICAL, transfer to backup feeder proposed	`HUMAN_APPROVAL_REQUIRED`, two-person; sampling and alert run automatically
S3 Feeder-head meter drift	METER_FAULT 0.92 (HIGH); operator agrees, HIGH	criticality HIGH, severity HIGH	`HUMAN_REVIEW`; agreement does not lower it; quick approval
S4 Industrial load step	METER_FAULT 0.93 (HIGH); operator GENUINE_EVENT, HIGH	plausible GENUINE_EVENT of high severity	`STRONG_DISAGREEMENT`: second review, more data, freeze; evidence confirms the operator
S5 Unfamiliar oscillation	SUSPICIOUS_DATA 0.46 (LOW), OOD	operator GENUINE_EVENT, LOW	`HUMAN_REVIEW`, two data rounds, supervisor escalation, no consequential action
S6 Suspected meter fraud	SUSPICIOUS_DATA 0.94 (HIGH); operator agrees	fraud flag and disconnection proposed	`HUMAN_APPROVAL_REQUIRED`, two-person; operator overrides and orders an inspection

S2 and S6 illustrate the central claim of the design: **high AI confidence, even combined with human agreement, does not authorise a consequential or accusatory action.**

3.11 Research traceability

A = stated in the paper; **B** = EnergyMind engineering decision; **C** = future extension.

Design decision	Source	What the paper actually says	EnergyMind adaptation	Category
Explicit defer outcome	[2]	predictor outputs a label or $\perp$	G2a–G3 are deferral	A
Optimise the combined system	[2]	system loss over classifier and expert	system accuracy, cost-weighted loss	A
Coverage and coverage sweep	[2]	coverage = fraction non-deferred; performance vs. coverage	sweep up to a safety ceiling	A / B

Design decision	Source	What the paper actually says	EnergyMind adaptation	Category
Defer when the expert is more likely right	[2]	Bayes rejector, Proposition 2	V1 approximates with bands; V2a estimates it	A / B
Classifier + rejector, L_{CE}	[2]	joint training with a consistent surrogate	V2b	C
(x, y, m) data requirement	[2]	training samples of expert decisions	audit log and calibration phase	A / B
Synthetic experts	[2]	used in experiments	synthetic operator profiles, labelled as simulation	A / B
Calibration alone insufficient	[1]	Theorem 3	operator confidence considered jointly	A
Operator confidence before AI advice	[1]	H formed before observing B; data record h and h_{+AI}	blind-first console	A / B
Three operator confidence levels	[1]	few discrete levels; experiments use three	LOW / MID / HIGH	A
People move toward higher AI confidence	[1]	observed in all four tasks (observational data)	motivates blind-first and band display	A / B
Alignment metrics	[1]	violations, EAE, MAE	one-vs-rest audit	A / B
Multicalibration per operator level	[1]	Theorem 8	when data allow	C
Disagreement states and their effects	neither	not stated	§3.5.3	B
Governance levels, risk, criticality, action classes, thresholds	neither	not stated	§3.3–3.5	B
Monotone escalation, safety envelope over learned deferral	neither	[2]'s rejector is unconstrained	§3.5, §3.8	B
Calibration phase, audit sample	neither	not stated	§3.6–3.7	B

3.12 Limitations

1. **No real operator data.** Thresholds, the risk matrix and agreement rules are engineering choices for a simulation and have not been validated with STEG operators.
2. **Conservative by design.** Max-based risk and monotone escalation will over-escalate; this must be measured, not assumed acceptable.
3. **Gaps in [1].** Binary theory, lay participants, non-safety tasks, observational data; the multi-class adaptation is ours.
4. **Gaps in [2].** Single expert distribution, stationarity, no safety constraints, and the need for (x, y, m) data that do not yet exist.

5. **Ground truth** for real events may be delayed, ambiguous or never obtained, which biases accuracy metrics toward easy cases.
6. **Feedback loops.** The policy decides which cases humans see, so logged data reflect the policy; the audit sample mitigates this but does not remove it.
7. **Blind-phase latency** may be unacceptable for urgent cases, where it can be skipped at the cost of losing the agreement signal.
8. **Adversarial pressure.** An attacker aware of the policy could try to stay inside the automated region or flood operators; recurrence limits help but are not a security analysis.
9. **Simulation and synthetic operators.** All prototype results come from simulated data and simulated or volunteer operators and must be reported as such.

References

[1] N. L. Corvelo Benz and M. Gomez Rodriguez, "Human-Aligned Calibration for AI-Assisted Decision Making," arXiv:2306.00074v4, 2024.

[2] H. Mozannar and D. Sontag, "Consistent Estimators for Learning to Defer to an Expert," in *Proc. 37th International Conference on Machine Learning (ICML)*, PMLR 119, 2020.