




Worst Disturbance per Incident						
ID	Incident Time	Meter	Type	Phase	Duration (s)	Magnitude (%)
1	05/29/2026 06:29:20 AM	Trafo 5	Sag	V1	323.770	89.48