7SJ41 Relay

The model provides two overcurrent time defined elements.
The current transformer should be inserted with a 1:1 ratio. The current settings are entered in sec.A -> with a 1:1 Ct are sec.A = prim. Ampere.