Alstom MVTR51

It's a reclosing device. The device isn't able to trip the circuit but works with an other protective device having the responsibility to detect the fault and disconnect the faulty part of the line. Please note that the breaker status is implemented using a minimum current detector, this part is in the model only, in the "real world" relay the same information is provided by an input contact.

The relay is mostly supported.

Not supported features

None important.