

## **1. SPAJ 115C Relay Model**

The relay type model contains not all elements of the actual relay. However, in the application of the relay, please consider the following:

1. The residual earth-fault current setting must be insert in p.u. ( $xI_n$ ) instead of percent (%).
2. Note that the relay must be set in the measuring unit if it is 1 A or a 5 A device.

Not supported functions:

1. Restricted earth fault current stage  $\Delta I_o$