ABB RXPDK Relay


It's a directional overcurrent relay, 3 different model versions (21, 22H and 23H) are available.

Directional unit of 21H:

- cross-polarized with voltage memory

Directional unit of 22H:

- zero-sequence polarizing



The zero-sequence voltage is rotated by 180 deg:

$$3U0' = 3U0 \cdot e^{j \cdot (180 + MTA)}$$

for MTA; "leading"

$$3U0' = 3U0 \cdot e^{j \cdot (180 - MTA)}$$

for MTA; "lagging"

MTA = maximum torque angle setting

The angle between the voltage is measured:

Error! Not a valid link.

The magnitude of the calculated angle phi is compared with the "Angle operation sector":


$$Forward = phi | < SectorAngle$$

-> forward fault

For checking the reverse fault is the zero-sequence current rotated by 180 deg.

Directional unit for H23:

- the sector is limited to 0 140°
- the PowerFactory model is shifting the voltage by -70° and limits the sector to +/- 70°



The angle operating sector is fixed set to 70 deg. The MTA (max. torque angle) is set to -70 deg.