

# **Housing Recovery and Reconstruction Platform-Nepal (HRRP)**

Orientation Program for Partner  
organizations on

**Correction/Exception Manual & New  
approved Housing Designs**

Presented by  
Raman Shrestha  
Structure Engineer  
NRA/UNDP

## ❖ Compliant ?

- Constructed or produced in accordance with a specified body of rules.
- Seismic design of buildings in Nepal (NBC 105) or International state-of-the-art.
- Follow Mandatory rules of thumb (Minimum requirements).

## ❖ Non-compliant ?


- Materials
- Methodology

# Types of Non-compliant building in Dhading district

## ❑ In SMRF (RCC)

- Plan and elevation irregularities
- Reinforcement in column < 8 nos. (4-16+4-12)
- Room area > 13.5 sq. m.
- Column spacing <2.1m & >4.5 m
- One bay building
- Column size <12"\*12"
- Foundation size insufficient
- Aspect Ratio

# Plan and elevation irregularities





**GROUND FLOOR PLAN**  
870.60 sq. ft.



**SOUTH ELEVATION**

# Insufficient Reinforcement (RCC-B)



# Column Spacing $< 2.1$ m



Any question?

# Types of Non-compliant building in Dhading district

- ❑ In Load Bearing Structure (Masonry Building)
  - Horizontal and vertical reinforcement missing
  - Sill band, lintel band, roof band missing
  - Diaphragm
  - Through stone or stitch band missing
  - Hybrid system



# Hybrid system



**THANK YOU**