

Presentation on Common Structurally Analyzed Non Compliance Houses of Gorkha District

Er. Balaram Pudasaini
District Support Engineer
Gorkha

9th August, 2017

Non-Compliance Cases in RCC Structure

- ▶ L-Shaped
- ▶ Different Level Foundation
- ▶ Column Size 9"x9"
- ▶ Column Size 9"x12"
- ▶ Single Bay (1x1, 1x2, 1x3,)
- ▶ Structural Area > 13.5 Sqm.
- ▶ Plinth Area > 1000 SqFt
- ▶ Grid Missing
- ▶ Structural Span > 4.5m
- ▶ Reinforcement not as per MRT


Some Photos of Non- Compliance Houses



Non Compliance Cases in Masonry Structure

- ▶ Masonry structure with timber vertical post
- ▶ Masonry structure with RC column
- ▶ Masonry structure with steel vertical post
- ▶ Dry stone masonry

Some Photos of Non Compliance Houses





Recommendation for second/third tranche

- ▶ On the basis of SAP analysis
- ▶ Theoretical judgment
- ▶ Manual Calculations

Progress of Gorkha District in approx. 3 months

S.N.	Name of VDCs	No. of HH Recommended for Second tranche
1	Ashrang	9
2	Aruarbang	3
3	Aruchanaute	3
4	Arupokhari	47
5	Uhiya	-
6	Kerauja	-
7	Kasigaun	-
8	Kerabari	1
9	Kharibot	3
10	Khoplang	-
11	Gankhu	2

S.N.	Name of VDCs	No. of HH Recommended for Second tranche
12	Gumda	-
13	Ghairung	9
14	Ghyachwok	-
15	Ghyalchowk	38
16	Chumchet	-
17	Chhekampar	38
18	Chhoprak	58
19	Jaubari	10
20	Tamalabot	-
21	Takukot	10
22	Taklung	-

Contd...

S.N .	Name of VDC	No. of HH Recommended for Second tranche
23	Tanglichowk	6
24	Tandrang	18
25	Taple	-
26	Thalajung	-
27	Thumi	-
28	Darbung	-
29	Deurali	16
30	Dhawa	125
31	Dhuwakot	36
32	Namjung	-
33	Pandrung	1
34	Panchkhuwa Deurali	19
35	Prok	-
36	Fujel	5
37	Bakrang	-

S.N.	Name of VDC	No. of HH Recommended for Second tranche
38	Baguwa	4
39	Barpak	28
40	Bihi	1
41	Bungkot	15
42	Borlang	8
43	Bhumlichowk	20
44	Makaisingh	-
45	Manakamana	9
46	Masel	3
47	Manbu	-
48	Mirkot	16
49	Muchowk	-
50	Lapu	-
51	Laprak	-
52	Lhwo	-

Contd..

S.N.	Name of VDCs	No. of HH Recommended for Second tranche
53	Shreenathkot	-
54	Samagaun	-
55	Simjung	-
56	Sirdibas	5
57	Saurpani	14
58	Swara	-
59	Hamsapur	8
50	Harmi	12
61	Gorkah Municipality	101
62	Palungtar Municipality	2
	Total	<u>703</u>

Thank You for you attention..

- ▶ Er. Balaram Pudasaini, District Support Engineer, Gorkha
- ▶ Mail Id.: engineerbalaram@gmail.com
- ▶ Contact No.: 9841374950