

FIELD INSPECTION REPORT - TRACTION DISTRIBUTION (TDMS)

GOVERNMENT OF INDIA - MINISTRY OF RAILWAYS
Northern & North Central Railway - NDLS-CNB Trunk Corridor

Submitted by: TRD Linemen Gang / OHE Patrol Inspector

Inspection method: Tower wagon patrol + contact wire thickness gauging (ACTM norms)

Corridor: New Delhi (NDLS) - Kanpur Central (CNB), 440 km

Report class: Field evidence attachment - accompanies digital requisition

OBSERVATIONS

- Contact wire residual diameter measured against 12.24 mm nominal.
- ATD counterweight travel and tension balance verified at anchor.
- Insulator sheds inspected for tracking, cracks and pollution deposit.
- Pantograph spark incidence over preceding 30 days reviewed.

RECOMMENDED ACTION

- Recommend 25 kV AC power block with earthing before any work.
- Tower wagon and TRD crew to be positioned prior to block commencement.
- Renew contact wire section if wear exceeds condemning limit.

Field staff signature

Reviewing officer

Date / Time of inspection

Approved / Rejected