


VW System Technology

KUKA Roboter GmbH

KUKA.EthernetKRL 2.2

For VW System Software 8.2 and 8.3



Issued: 19.12.2012

Version: VST EthernetKRL 2.2 V1 en (PDF)

© Copyright 2012

KUKA Roboter GmbH
Zugspitzstraße 140
D-86165 Augsburg
Germany

This documentation or excerpts thereof may not be reproduced or disclosed to third parties without the express permission of KUKA Roboter GmbH.

Other functions not described in this documentation may be operable in the controller. The user has no claims to these functions, however, in the case of a replacement or service work.

We have checked the content of this documentation for conformity with the hardware and software described. Nevertheless, discrepancies cannot be precluded, for which reason we are not able to guarantee total conformity. The information in this documentation is checked on a regular basis, however, and necessary corrections will be incorporated in the subsequent edition.

Subject to technical alterations without an effect on the function.

Translation of the original documentation

KIM-PS5-DOC

Publication:	Pub VST EthernetKRL 2.2 (PDF) en
Bookstructure:	VST EthernetKRL 2.2 V1.1
Version:	VST EthernetKRL 2.2 V1 en (PDF)

Contents

1	Introduction	5
1.1	Target group	5
1.2	Industrial robot documentation	5
1.3	Representation of warnings and notes	5
1.4	Terms used	6
1.5	Trademarks	7
2	Product description	9
2.1	Overview of EthernetKRL	9
2.2	Configuration of an Ethernet connection	9
2.2.1	Behavior in the event of a lost connection	9
2.2.2	Monitoring a connection	10
2.3	Data exchange	10
2.4	Saving data	10
2.5	Client-server mode	12
2.6	Protocol types	12
2.7	Event messages	13
2.8	Error treatment	13
3	Safety	15
4	Installation	17
4.1	System requirements	17
4.2	Installing or updating EthernetKRL	17
4.3	Uninstalling EthernetKRL	18
5	Configuration	19
5.1	Network connection via the KLI of the robot controller	19
6	Programming	21
6.1	Configuring an Ethernet connection	21
6.1.1	XML structure for connection properties	21
6.1.2	XML structure for data reception	24
6.1.3	XML structure for data transmission	26
6.1.4	Configuration according to the XPath schema	27
6.2	Functions for data exchange	27
6.2.1	Programming tips	28
6.2.2	Initializing and clearing a connection	29
6.2.3	Opening and closing a connection	30
6.2.4	Sending data	31
6.2.5	Reading out data	33
6.2.6	Deleting received data	35
6.2.7	EKI_STATUS – Structure for function-specific return values	35
6.2.8	Configuration of event messages	36
6.2.9	Reception of complete XML data records	37
6.2.10	Processing incomplete data records	38
6.2.11	EKI_CHECK() – Checking functions for errors	38
7	Examples	41

7.1	Application examples	41
7.1.1	Implementing application examples	41
7.1.2	Integrating an example program into the VW_USER module	42
7.1.3	Server program user interface	43
7.1.4	Setting communication parameters in the server program	45
7.2	Configuration and program examples	46
7.2.1	BinaryFixed configuration example	46
7.2.2	BinaryStream configuration example	47
7.2.3	XmlTransmit configuration example	48
7.2.4	XmlServer configuration example	50
7.2.5	XmlCallback configuration example	50
8	Diagnosis	55
8.1	Displaying diagnostic data	55
8.2	Error protocol (EKI logbook)	55
8.3	Error messages	55
9	Appendix	61
9.1	Extended XML structure for connection properties	61
9.2	Increasing the memory	61
9.3	Deactivating message output and message logging	62
9.4	Command reference	62
9.4.1	Initializing, opening, closing and clearing a connection	62
9.4.2	Sending data	63
9.4.3	Writing data	64
9.4.4	Reading data	65
9.4.5	Checking a function for errors	69
9.4.6	Clearing, locking, unlocking and checking a memory	69
10	KUKA Service	71
10.1	Requesting support	71
10.2	KUKA Customer Support	71
	Index	79

1 Introduction

1.1 Target group

This documentation is aimed at users with the following knowledge and skills:

- Advanced KRL programming skills
- Advanced knowledge of the robot controller system
- Advanced knowledge of XML
- Advanced knowledge of networks



For optimal use of our products, we recommend that our customers take part in a course of training at KUKA College. Information about the training program can be found at www.kuka.com or can be obtained directly from our subsidiaries.

1.2 Industrial robot documentation

The industrial robot documentation consists of the following parts:

- Documentation for the manipulator
- Documentation for the robot controller
- Operating and programming instructions for the KUKA System Software
- Documentation relating to options and accessories
- Parts catalog on storage medium

Each of these sets of instructions is a separate document.

1.3 Representation of warnings and notes

Safety

These warnings are relevant to safety and **must** be observed.



DANGER These warnings mean that it is certain or highly probable that death or severe injuries **will** occur, if no precautions are taken.



WARNING These warnings mean that death or severe injuries **may** occur, if no precautions are taken.



CAUTION These warnings mean that minor injuries **may** occur, if no precautions are taken.



NOTICE These warnings mean that damage to property **may** occur, if no precautions are taken.



These warnings contain references to safety-relevant information or general safety measures.
These warnings do not refer to individual hazards or individual precautionary measures.

This warning draws attention to procedures which serve to prevent or remedy emergencies or malfunctions:



SAFETY INSTRUCTIONS Procedures marked with this warning **must** be followed exactly.

Notes

These hints serve to make your work easier or contain references to further information.



Tip to make your work easier or reference to further information.

1.4 Terms used

Term	Description
Data stream	Continuous sequences of data records of which the end cannot be foreseen in advance. The individual data records may be of any fixed type. The amount of data records per unit of time (data rate) may vary. Only sequential access to the data is possible.
EKI	EthernetKRL interface
EOS	End of stream (end string) String that indicates the end of a data record
Ethernet	Ethernet is a data network technology for local area networks (LANs). It allows data to be exchanged between the connected devices in the form of data frames.
FIFO	Methods used to process a data memory
LIFO	<ul style="list-style-type: none"> ■ First In First Out: the elements saved first are taken first from the memory. ■ Last In First Out: the elements saved last are taken first from the memory.
KLI	KUKA Line Interface Line bus for the integration of the system in the customer network
KR C	KUKA Robot Controller KR C is the KUKA robot controller
KRL	KUKA Robot Language KRL is the KUKA robot programming language.
smarHMI	Smart human-machine interface KUKA smarHMI is the user interface of the KUKA system software.
Socket	Software interface that links IP addresses to port numbers.
TCP/IP	Transmission Control Protocol Protocol of the data exchange between devices of a network. TCP constitutes a virtual channel between two sockets in a network connection. Data can be transmitted on this channel in both directions.
UDP/IP	User Datagram Protocol Connectionless protocol of the data exchange between the devices of a network
IP	Internet Protocol The Internet protocol is used to define subnetworks by means of physical MAC addresses.

Term	Description
XML	Extensible Markup Language Standard for creating machine-readable and human-readable documents in the form of a specified tree structure.
XPath	XML Path Language Language used to write and read sections of an XML document

1.5 Trademarks

.NET Framework is a trademark of Microsoft Corporation.

Windows is a trademark of Microsoft Corporation.

2 Product description

2.1 Overview of EthernetKRL

Functions	<p>EthernetKRL is an add-on technology package with the following functions:</p> <ul style="list-style-type: none"> ■ Data exchange via the EthernetKRL interface ■ Receiving XML data from an external system ■ Sending XML data to an external system ■ Receiving binary data from an external system ■ Sending binary data to an external system
Features	<ul style="list-style-type: none"> ■ Robot controller and external system as a client or server ■ Configuration of connections via XML-based configuration file ■ Configuration of “event messages” ■ Monitoring of connections by a ping on the external system ■ Reading and writing data from the Submit interpreter ■ Reading and writing data from the robot interpreter
Communication	<p>Data are transmitted via the TCP/IP protocol. It is possible to use the UDP/IP protocol, but not recommended (connectionless network protocol, e.g. no data loss detection).</p> <p>The communication time depends on the actions programmed in KRL and the data volume sent. Up to 2 ms package circulation time may be reached in KRL, depending on the programming method.</p>

2.2 Configuration of an Ethernet connection

Description	<p>The Ethernet connection is configured via an XML file. A configuration file must be defined for each connection in the directory C:\KRC\ROBOTER\Config\User\Common\EthernetKRL of the robot controller. The configuration is read in when initializing a connection.</p> <p>Ethernet connections can be created and operated by the robot interpreter or Submit interpreter. The channels can be used crosswise, e.g. a channel opened in the Submit interpreter can also be operated by the robot interpreter.</p> <p>The deletion of a connection can be linked to robot interpreter and Submit interpreter actions or system actions.</p>
--------------------	---

2.2.1 Behavior in the event of a lost connection

Description	<p>The following properties and functions of the EKI ensure the received data can be processed reliably:</p> <ul style="list-style-type: none"> ■ A connection is automatically closed when reaching the limit of a data memory. ■ A connection is automatically closed if a data reception error occurs. ■ The data memories continue to be read out with the connection closed. ■ If a connection is lost, it can be restored without any influence on the saved data. ■ A lost connection can be indicated, for example, by a flag. ■ The error message for the error which caused a lost connection can be displayed on the smartHMI.
--------------------	---

2.2.2 Monitoring a connection

Description

A connection can be monitored by a ping on the external system (<ALIVE.../> element in the connection configuration).

A flag or output can be set in the event of a successful connection, depending on the configuration. The output or flag is set as long as the ping is regularly sent and the connection to the external system is active. The output or flag is deleted if the connection to the external system is aborted.

2.3 Data exchange

Overview

The robot controller can receive data from an external system as well as send data to an external system via EthernetKRL.




Fig. 2-1: System overview

Data reception

Basic sequence (marked in red) (>>> Fig. 2-1):

1. The external system sends data which are transmitted via a protocol and received by the EKI.
2. The data are stored in a structured manner in a data memory.
3. The data are accessed from a KRL program in a structured manner. KRL instructions are used to read the data and copy them into KRL variables.

Data transmission

Basic sequence (marked in green) (>>> Fig. 2-1):

1. KRL instructions are used to write the data in a data memory in a structured manner.
2. A KRL instruction is used to read the data out of the memory.
3. EKI sends the data to the external system via a protocol.



It is possible to send data directly without first storing the data in a memory.

2.4 Saving data

Description

All data received are automatically saved and, in this way, are available to KRL. XML and binary data are treated differently when saving them.

Each data memory is implemented as a memory stack. The individual memories are read out in FIFO or LIFO mode.

XML data

The received data are extracted and stored type-specifically in different memories (one memory per value).




Fig. 2-2: XML data memory

Binary data

The received data are not extracted or interpreted. Only one memory exists for a connection in binary mode.




Fig. 2-3: Binary data memory

Read-out methods

Data elements are taken out of the memory in the order in which they were stored there (FIFO). The reverse method, in which the data element stored last in the memory is taken out first, can be configured (LIFO).

Each memory is assigned a common maximum limit for the data which can be saved. If the limit is exceeded, the Ethernet connection is immediately closed to prevent the reception of further data. The data currently received are still saved, i.e. the memory is increased by 1. The memories can still be further processed. The connection can be re-opened via the EKI_OPEN() function.




Fig. 2-4: Read-out method overview

2.5 Client-server mode

Description

The robot controller and external system are connected as a client and server. The external system may be the client or server. The number of active connections is limited to 16.




Fig. 2-5: Client-server mode

If the EKI is configured as a server, only an individual client can connect to the server. If several connections are required, several servers should also be created at the interface. It is possible to operate several clients and servers simultaneously within the EKI.

2.6 Protocol types

Description

The transmitted data can be packed in different formats.

The following formats are supported:

- Freely configurable XML structure
- Binary data record of fixed length
- Variable binary data record with end string




Fig. 2-6: Protocol types

The two binary variants cannot be operated simultaneously at the same connection.

The following combinations are possible:

Connection Cx	C1	C2	C3	C4	C5
Binary, fixed	✓	✗	✓	✗	✗
Binary, variable	✗	✗	✗	✓	✓
XML	✓	✓	✗	✗	✓

Examples

F F E A 1 6 C C 0 1 2 3 B E 9 7 8 F F F

Fig. 2-7: Binary data of fixed length (10 bytes)

H E L L O : E N D
G e t n e x t P o s ! ! ! \ R \ N

Fig. 2-8: Variable binary data with end string

2.7 Event messages

Description

The following events can be signaled by setting an output or flag:

- Connection is active.
- An individual XML element has arrived at the interface.
- A complete XML structure or complete binary data record has arrived at the interface.

(>>> 6.2.8 "Configuration of event messages" Page 36)

2.8 Error treatment

Description

EthernetKRL provides functions for data exchange between the robot controller and an external system.

Each of these functions returns values. These return values can be queried and evaluated in the KRL program.

The following values are returned, depending on the function:

- Error number
- Number of elements still in the memory after the access.
- Number of elements read out of the memory

- Information on whether a connection exists
- Time stamp of the data element taken from the memory

(>>> 6.2.7 "EKI_STATUS – Structure for function-specific return values"
Page 35)

A message is generated for each error on the smartHMI and in the EKI log-book. The automatic generation of messages can be deactivated.

3 Safety

This documentation contains safety instructions which refer specifically to the software described here.

The fundamental safety information for the industrial robot can be found in the “Safety” chapter of the Operating and Programming Instructions for System Integrators or the Operating and Programming Instructions for End Users.



The “Safety” chapter in the operating and programming instructions must be observed. Death to persons, severe injuries or considerable damage to property may otherwise result.

4 Installation

4.1 System requirements

- | | |
|-----------------|--|
| Hardware | <ul style="list-style-type: none"> ■ VKR C4 robot controller ■ External system |
| Software | <ul style="list-style-type: none"> ■ VW System Software 8.2 or 8.3 |

4.2 Installing or updating EthernetKRL



It is advisable to archive all relevant data before updating a software package.

Preparation

- Copy software from CD to KUKA USB stick.
The software must be copied onto the stick with the file Setup.exe at the highest level (i.e. not in a folder).

NOTICE

Recommendation: Always use KUKA sticks. Data may be lost if sticks from other manufacturers are used.

Precondition

- "Expert" user group

Procedure

1. Connect the USB stick to the robot controller or smartPAD.
2. In the main menu, select **Start-up > Additional software**.
3. Press **New software**. The entry **EthernetKRL** must be displayed in the **Name** column and drive **E:** or **K:** in the **Path** column.
If not, press **Refresh**.
4. If the specified entries are now displayed, continue with step 5.
If not, the drive from which the software is being installed must be configured first:
 - Press the **Configuration** button. A new window opens.
 - Select a line in the **Installation paths for options** area.
Note: If the line already contains a path, this path will be overwritten.
 - Press **Path selection**. The available drives are displayed.
 - Select **E:**. (If stick connected to the robot controller.)
Or select **K:**. (If stick connected to the smartPAD.)
 - Press **Save**. The window closes again.

The drive only needs to be configured once and then remains saved for further installations.
5. Mark the entry **EthernetKRL** and click on **Install**. Answer the request for confirmation with **Yes**.
6. Confirm the reboot prompt with **OK**.
7. Remove the stick.
8. Reboot the robot controller.

LOG file

A LOG file is created under C:\KRC\ROBOTER\LOG.

4.3 Uninstalling EthernetKRL



It is advisable to archive all relevant data before uninstalling a software package.

Precondition

- “Expert” user group

Procedure

1. In the main menu, select **Start-up > Additional software**. All additional programs installed are displayed.
2. Mark the entry **EthernetKRL** and click on **Uninstall**. Reply to the request for confirmation with **Yes**. Uninstallation is prepared.
3. Reboot the robot controller. Uninstallation is resumed and completed.

LOG file

A LOG file is created under C:\KRC\ROBOTER\LOG.

5 Configuration

5.1 Network connection via the KLI of the robot controller

Description

A network connection must be established via the KLI of the robot controller in order to exchange data via Ethernet.



Detailed information about network configuration via the KUKA Line Interface (KLI) of the robot controller is contained in the Operating and Programming Instructions for System Integrators.

The Ethernet cable can be connected either to the PROFINET Cu switch or directly to the control PC.



Further information on the PROFINET Cu switch interface can be found in the operating or assembly instructions for the robot controller.

6 Programming

6.1 Configuring an Ethernet connection

Overview

An Ethernet connection is configured via an XML file. A configuration file must be defined for each connection in the directory C:\KRC\ROBOTER\Config\User\Common\EthernetKRL of the robot controller.



XML files are case-sensitive. Upper/lower case must be taken into consideration.

The name of the XML file is also the access key in KRL.

Example: ... \EXT.XML → EKI_INIT("EXT")

```
<ETHERNETKRL>
  <CONFIGURATION>
    <EXTERNAL></EXTERNAL>
    <INTERNAL></INTERNAL>
  </CONFIGURATION>
  <RECEIVE>
    <ELEMENTS></ELEMENTS>
  </RECEIVE>
  <SEND>
    <ELEMENTS></ELEMENTS>
  </SEND>
</ETHERNETKRL>
```

Section	Description
<CONFIGURATION> ... </CONFIGURATION>	Configuration of the connection parameters between an external system and an interface (>>> 6.1.1 "XML structure for connection properties" Page 21)
<RECEIVE> ... </RECEIVE>	Configuration of the reception structure received by the robot controller (>>> 6.1.2 "XML structure for data reception" Page 24)
<SEND> ... </SEND>	Configuration of the transmission structure sent by the robot controller (>>> 6.1.3 "XML structure for data transmission" Page 26)

6.1.1 XML structure for connection properties

Description

The settings for the external system are defined in the section <EXTERNAL> ... </EXTERNAL>:

Element	Description
TYPE	Defines whether the external system is to communicate as a server or client with the interface (optional) <ul style="list-style-type: none"> ■ Server: external system is a server. ■ Client: external system is a client. Default value: server

Element	Description
IP	IP address of the external system if it is defined as a server (TYPE = server) The IP address is ignored if TYPE = client.
PORT	Port number of the external system if it is defined as a server (TYPE = server) ■ 1 ... 65,534 The port number is ignored if TYPE = client.

The settings for the interface are defined in the section <INTERNAL> ... </INTERNAL>:

Element	Attribute	Description
ENVIRONMENT	—	Link the deletion of the connection to actions (optional) <ul style="list-style-type: none"> ■ Program: deletion after actions of the robot interpreter <ul style="list-style-type: none"> ■ Reset program. ■ Deselect program. ■ Reconfigure I/Os. ■ Submit: deletion after actions of the Submit interpreter <ul style="list-style-type: none"> ■ Cancel submit interpreter. ■ Reconfigure I/Os. ■ System: deletion after system actions <ul style="list-style-type: none"> ■ Reconfigure I/Os. Default value: Program
BUFFERING	Mode	Method used to process all data memories (optional) <ul style="list-style-type: none"> ■ FIFO: First In First Out ■ LIFO: Last In First Out Default value: FIFO
	Limit	Maximum number of data elements which can be stored in a data memory (optional) <ul style="list-style-type: none"> ■ 1 ... 512 Default value: 16
BUFFSIZE	Limit	Maximum number of bytes which can be received without being interpreted (optional) <ul style="list-style-type: none"> ■ 1 ... 65,534 bytes Default value: 16,384 bytes
TIMEOUT	Connect	Time until the attempt to establish a connection is aborted (optional) Unit: ms <ul style="list-style-type: none"> ■ 0 ... 65,534 ms Default value: 2,000 ms

Element	Attribute	Description
ALIVE	Set_Out	Sets an output or a flag for a successful connection (optional) Number of the output: ■ 1 ... 4,096 Number of the flag: ■ 1 ... 1,025 The output or flag is set as long as a connection to the external system is active. The output or flag is deleted if the connection to the external system is aborted.
	Set_Flag	
	Ping	Interval for sending a ping in order to monitor the connection to the external system (optional) ■ 1 ... 65,534 s
IP	_____	IP address of the EKI if it is defined as a server (EXTERNAL/TYPE = client) The IP address is ignored if EXTERNAL/TYPE = server.
PORT	_____	Port number of the EKI if it is defined as a server (EXTERNAL/TYPE = client) ■ 54,600 ... 54,615 The port number is ignored if EXTERNAL/TYPE = server.
PROTOCOL	_____	Transmission protocol (optional) ■ TCP ■ UDP Default value: TCP It is recommended to always use the TCP/IP protocol.
Messages	Display	Deactivates message output on smartHMI (optional). ■ error : message output is active. ■ disabled : message output is deactivated. Default value: error
	Logging	Deactivates the writing of messages in the EKI logbook (optional). ■ warning : warning messages and error messages are logged. ■ error : only error messages are logged. ■ disabled : logging is deactivated. Default value: error
	(>>> 9.3 "Deactivating message output and message logging" Page 62)	

Example

```

<CONFIGURATION>
  <EXTERNAL>
    <IP>172.1.10.5</IP>
    <PORT>60000</PORT>
    <TYPE>Server</TYPE>
  </EXTERNAL>
  <INTERNAL>
    <ENVIRONMENT>Program</ENVIRONMENT>
    <BUFFERING Mode="FIFO" Limit="10"/>
    <BUFSIZE Limit="16384"/>
    <TIMEOUT Connect="60000"/>
    <ALIVE Set_Out="666" Ping="200"/>
    <IP>192.1.10.20</IP>
    <PORT>54600</PORT>
    <PROTOCOL>TCP</PROTOCOL>
    <Messages Display="disabled" Logging="error"/>
  </INTERNAL>
</CONFIGURATION>

```

6.1.2 XML structure for data reception**Description**

The configuration depends on whether XML data or binary data are received.

- An XML structure has to be defined for the reception of XML data: <XML> ... </XML>
- Raw data have to be defined for the reception of binary data: <RAW> ... </RAW>

Attributes in the elements of the XML structure <XML> ... </XML>:

Element	Attribute	Description
ELEMENT	Tag	<p>Name of the element</p> <p>The XML structure for data reception is defined here (XPath).</p> <p>(>>> 6.1.4 "Configuration according to the XPath schema" Page 27)</p>
ELEMENT	Type	<p>Data type of the element</p> <ul style="list-style-type: none"> ■ STRING ■ REAL ■ INT ■ BOOL ■ FRAME <p>Note: Optional if the tag is used only for event messages. In this case no memory capacity is reserved for the element.</p> <p>Event flag example: <ELEMENT Tag="Ext" Set_Flag="56"/></p>

Element	Attribute	Description
ELEMENT	Set_Out	Sets an output or flag after receiving the element (optional) Number of the output: ■ 1 ... 4,096 Number of the flag: ■ 1 ... 1,025
	Set_Flag	
ELEMENT	Mode	Method used to process a data record in the data memory ■ FIFO : First In First Out ■ LIFO : Last In First Out Only relevant if individual data records are to be treated differently than configured under BUFFERING for the interface.

Attributes for the element in the raw data <RAW> ... </RAW>:

Element	Attribute	Description
ELEMENT	Tag	Name of the element
ELEMENT	Type	Data type of the element ■ BYTE : Binary data record of fixed length ■ STREAM : Variable binary data record with end string
ELEMENT	Set_Out	Sets an output or flag after receiving the element (optional) Number of the output: ■ 1 ... 4 096 Number of the flag: ■ 1 ... 1 025
	Set_Flag	
ELEMENT	EOS	End string of an elementary piece of information (only relevant if TYPE = STREAM) ■ ASCII encoding: 1 ... 32 characters ■ Alternative end is separated by means of the "I" character. Examples: ■ <ELEMENT ... EOS="123,134,21"/> ■ <ELEMENT ... EOS="123,134,21I13,10"/>
ELEMENT	Size	Fixed size of information if TYPE = BYTE ■ 1 ... 3,600 bytes Maximum size of information if TYPE = STREAM ■ 1 ... 3,600 bytes

Examples

```
<RECEIVE>
<XML>
  <ELEMENT Tag="Ext/Str" Type="STRING"/>
  <ELEMENT Tag="Ext/Pos/XPos" Type="REAL" Mode="LIFO"/>
  <ELEMENT Tag="Ext/Pos/YPos" Type="REAL"/>
  <ELEMENT Tag="Ext/Pos/ZPos" Type="REAL"/>
  <ELEMENT Tag="Ext/Temp/Cpu" Type="REAL" Set_Out="1"/>
  <ELEMENT Tag="Ext/Temp/Fan" Type="REAL" Set_Flag="14"/>
  <ELEMENT Tag="Ext/Integer/AState" Type="INT"/>
  <ELEMENT Tag="Ext/Integer/BState" Type="INT"/>
  <ELEMENT Tag="Ext/Boolean/CState" Type="BOOL"/>
  <ELEMENT Tag="Ext/Frames/Frame1" Type="FRAME"/>
  <ELEMENT Tag="Ext/Attributes/@A1" Type="STRING"/>
  <ELEMENT Tag="Ext/Attributes/@A2" Type="INT"/>
  <ELEMENT Tag="Ext" Set_Flag="56"/>
</XML>
</RECEIVE>
```

```
<RECEIVE>
<RAW>
  <ELEMENT Tag="RawData" Type="BYTE" Size="1408"
    Set_Flag="14"/>
</RAW>
</RECEIVE>
```

```
<RECEIVE>
<RAW>
  <ELEMENT Tag="MyStream" Type="STREAM" EOS="123,134,21"
    Size="836" Set_Flag="14"/>
</RAW>
</RECEIVE>
```

6.1.3 XML structure for data transmission

Description

The configuration depends on whether XML data or binary data are sent.

- An XML structure has to be defined for the transmission of XML data:
<XML> ... </XML>



For transmission, the XML structure is created in the sequence in which it is configured.

- The transmission of binary data is implemented directly in the KRL programming. No configuration has to be specified.

Attribute in the elements of the XML structure <XML> ... </XML>:

Attribute	Description
Tag	Name of the element The XML structure for data transmission is defined here (XPath).

Example

```
<SEND>
<XML>
  <ELEMENT Tag="Robot/Data/ActPos/@X"/>
  <ELEMENT Tag="Robot/Data/ActPos/@Y"/>
  <ELEMENT Tag="Robot/Data/ActPos/@Z"/>
  <ELEMENT Tag="Robot/Data/ActPos/@A"/>
  <ELEMENT Tag="Robot/Data/ActPos/@B"/>
  <ELEMENT Tag="Robot/Data/ActPos/@C"/>
  <ELEMENT Tag="Robot/Status"/>
  <ELEMENT Tag="Robot/Mode"/>
  <ELEMENT Tag="Robot/Complex/Tickcount"/>
  <ELEMENT Tag="Robot/RobotType/Robot/Type"/>
</XML>
</SEND>
```

6.1.4 Configuration according to the XPath schema

Description If XML is used to exchange data, it is necessary for the exchanged XML documents to be structured in the same way. EthernetKRL uses the XPath schema to write and read the XML documents.

The following cases are to be distinguished for XPath:

- Writing and reading elements
- Writing and reading attributes

Element notation ■ Saved XML document for data transmission:

```
<Robot>
  <Mode>...</Mode>
  <RobotLamp>
    <GrenLamp>
      <LightOn>...</LightOn>
    </GrenLamp>
  </RobotLamp>
</Robot>
```

- Configured XML structure for data transmission:

```
<SEND>
  <XML>
    <ELEMENT Tag="Robot/Mode" />
    <ELEMENT Tag="Robot/RobotLamp/GrenLamp/LightOn" />
  </XML>
<SEND />
```

Attribute notation ■ Saved XML document for data transmission:

```
<Robot>
  <Data>
    <ActPos X="...">
    </ActPos>
    <LastPos A="..." B="..." C="..." X="..." Y="..." Z="...">
    </LastPos>
  </Data>
</Robot>
```

- Configured XML structure for data transmission:

```
<SEND>
  <XML>
    <ELEMENT Tag="Robot/Data/LastPos/@X" />
    <ELEMENT Tag="Robot/Data/LastPos/@Y" />
    ...
    <ELEMENT Tag="Robot/Data/ActPos/@X" />
  </XML>
<SEND />
```

6.2 Functions for data exchange

Overview EthernetKRL provides functions for data exchange between the robot controller and an external system.

Exact descriptions of the functions can be found in the appendix.

(>>> 9.4 "Command reference" Page 62)

Initializing, opening, closing and clearing a connection
EKI_STATUS = EKI_Init(CHAR[])
EKI_STATUS = EKI_Open(CHAR[])
EKI_STATUS = EKI_Close(CHAR[])
EKI_STATUS = EKI_Clear(CHAR[])

Sending data

```
EKI_STATUS = EKI_Send(CHAR[], CHAR[])
```

Writing data

```
EKI_STATUS = EKI_SetReal(CHAR[], CHAR[], REAL)
```

```
EKI_STATUS = EKI_SetInt(CHAR[], CHAR[], INTEGER)
```

```
EKI_STATUS = EKI_SetBool(CHAR[], CHAR[], BOOL)
```

```
EKI_STATUS = EKI_SetFrame(CHAR[], CHAR[], FRAME)
```

```
EKI_STATUS = EKI_SetString(CHAR[], CHAR[], CHAR[])
```

Reading data

```
EKI_STATUS = EKI_GetBool(CHAR[], CHAR[], BOOL)
```

```
EKI_STATUS = EKI_GetBoolArray(CHAR[], CHAR[], BOOL[])
```

```
EKI_STATUS = EKI_GetInt(CHAR[], CHAR[], Int)
```

```
EKI_STATUS = EKI_GetIntArray(CHAR[], CHAR[], Int[])
```

```
EKI_STATUS = EKI_GetReal(CHAR[], CHAR[], Real)
```

```
EKI_STATUS = EKI_GetRealArray(CHAR[], CHAR[], Real[])
```

```
EKI_STATUS = EKI_GetString(CHAR[], CHAR[], CHAR[])
```

```
EKI_STATUS = EKI_GetFrame(CHAR[], CHAR[], FRAME)
```

```
EKI_STATUS = EKI_GetFrameArray(CHAR[], CHAR[], FRAME[])
```

Checking a function for errors

```
EKI_CHECK(EKI_STATUS, EKIMsgType, CHAR[])
```

Clearing, locking, unlocking and checking a memory

```
EKI_STATUS = EKI_ClearBuffer(CHAR[], CHAR[])
```

```
EKI_STATUS = EKI_Lock(CHAR[])
```

```
EKI_STATUS = EKI_Unlock(CHAR[])
```

```
EKI_STATUS = EKI_CheckBuffer(CHAR[], CHAR[])
```

6.2.1 Programming tips



It is advisable to program the data exchange via the Ethernet KRL interface exclusively in VW_USER and not to use the Ethernet KRL functions in programs (Folgen).

- The following points should be observed if a connection is created in the Submit interpreter:
 - The <ENVIRONMENT> element must be used in the connection configuration to specify that the channel concerned is a Submit channel.
 - An open channel in the Submit interpreter can also be addressed by the robot interpreter.
 - If the Submit interpreter is deselected, the connection is automatically deleted by means of the configuration.



EKI instructions are executed in the advance run!

- If an EKI instruction is to be executed in the main run, instructions must be used which trigger an advance run stop, e.g. WAIT SEC.
- Since each access to the interface consumes time, it is recommended to call up large amounts of data with the field access functions EKI_Get...Array().

- EthernetKRL can access a maximum of 512 array elements by means of EKI_Get...Array(). It is possible to create a larger array in KRL, e.g. my-Frame[1000], but only a maximum of 512 elements can be read.
- There are various possibilities of waiting for data:
 - By setting a flag or an output, it can be indicated that a certain data element or a complete data record has been received (Set_Flag or Set_Out element in the XML structure for data reception).
Example: Interrupt of the KRL program by WAIT FOR \$FLAG[x]
(>>> 7.2.5 "XmlCallback configuration example" Page 50)
 - The EKI_CheckBuffer() function can be used to check cyclically whether the memory contains new data elements.

6.2.2 Initializing and clearing a connection

Description

A connection must be created and initialized with the EKI_Init() function. The connection configuration specified in the function is read in. A connection can be created both in the robot interpreter and in the Submit interpreter.

A connection can be deleted again in the robot or Submit interpreter using the EKI_Clear() function. The deletion of a connection can additionally be linked to robot interpreter and Submit interpreter actions or system actions. (Configurable via the <ENVIRONMENT> element in the connection configuration)

"Program" configuration




Fig. 6-1: "Program" connection configuration

With this configuration, a connection is deleted after the following actions:

- Reset program.
- Deselect program.
- Reconfigure I/Os.



The driver is reloaded when reconfiguring the I/Os, i.e. all initializations are deleted.

“Submit” configuration




Fig. 6-2: “Submit” connection configuration

With this configuration, a connection is deleted after the following actions:

- Cancel Submit interpreter.
- Reconfigure I/Os.



The driver is reloaded when reconfiguring the I/Os, i.e. all initializations are deleted.

“System” configuration




Fig. 6-3: “System” connection configuration

With this configuration, a connection is deleted after the following actions:

- Reconfigure I/Os.



The driver is reloaded when reconfiguring the I/Os, i.e. all initializations are deleted.

6.2.3 Opening and closing a connection

Description

The connection to the external system is established by means of a KRL program. Most KRL programs are structured as follows:

```

1 DEF Connection()
  ...
2 RET=EKI_Init("Connection")
3 RET=EKI_Open("Connection")
  ...
4 Write data, send data or get received data
  ...
5 RET=EKI_Close("Connection")
6 RET=EKI_Clear("Connection")
  ...
7 END

```

Line	Description
2	EKI_Init() initializes the channel used by the interface to connect to the external system.
3	EKI_Open() opens the channel.
4	KRL instructions used to write data in the memory, send data or access received data
5	EKI_Close() closes the channel.
6	EKI_Clear () deletes the channel.

It should be taken into account during programming whether the interface is configured as a server or client.

Server mode

EKI_Open() sets the interface (= server) to a listening state if the external system is configured as a client. The server waits for the connection request of a client without interruption of the program run. If the <TIMEOUT Connect="..."/> element is not assigned data in the configuration file, the server waits until a client requests a connection.

A connection request by a client is indicated by access to the interface or by an event message, e.g. via the <ALIVE SET_OUT="..."/> element.

An event flag or output has to be programmed, e.g. WAIT FOR \$OUT[...], if the program run is to be interrupted as long as the server waits for the connection request.



It is recommended not to use EKI_Close() in server mode. In server mode, the channel is closed from the external client.

Client mode

EKI_Open() interrupts the program run until the connection to the external system is active if the external system is configured as a server. EKI_Close() closes the connection to the external server.

6.2.4 Sending data

Description

Depending on the configuration and programming, the following data can be sent with EKI_Send():

- Complete XML structure
- Partial XML structure
- XML data directly as string
- Binary data record with end string (EOS) directly as string
- Binary data record of fixed length directly as string

Binary data records of fixed length must be read into the KRL program with CAST_TO(). Only data of REAL type (4 bytes) are legible, not Double.



Detailed information on the CAST_TO() command can be found in the CREAD/CWRITE documentation.

XML data example

Sending the complete XML structure

- Saved XML structure for data transmission:

```
<Robot>
  <ActPos X="1000.12"></ActPos>
  <Status>12345678</Status>
</Robot>
```

- Programming:

```
DECL EKI_STATUS RET
RET=EKI_Send("Channel_1","Robot")
```

- Sent XML structure:

```
<Robot>
  <ActPos X="1000.12"></ActPos>
  <Status>12345678</Status>
</Robot>
```

Sending part of the XML structure

- Saved XML structure for data transmission (not used in the case of direct transmission):

```
<Robot>
  <ActPos X="1000.12"></ActPos>
  <Status>12345678</Status>
</Robot>
```

- Programming:

```
DECL EKI_STATUS RET
RET=EKI_Send("Channel_1","Robot/ActPos")
```

- Sent XML structure:

```
<Robot>
  <ActPos X="1000.12"></ActPos>
</Robot>
```

Direct transmission of XML data as a string

- Saved XML structure for data transmission:

```
<Robot>
  <ActPos X="1000.12"></ActPos>
  <Status>12345678</Status>
</Robot>
```

- Programming:

```
DECL EKI_STATUS RET
RET=EKI_Send("Channel_1","<POS><XPOS>1</XPOS></POS>")
```

- Sent string:

```
<POS><XPOS>1</XPOS></POS>
```

Binary data example

Direct sending of a binary data record of fixed length (10 bytes)

- Configured raw data:

```
<RAW>
  <ELEMENT Tag="Buffer" Type="BYTE" Size="10" />
</RAW>
```

- Programming:


```
DECL EKI_STATUS RET
CHAR Bytes[10]
OFFSET=0
CAST_TO(Bytes[],OFFSET,91984754,913434.2,TRUE,"X")
RET=EKI_Send("Channel_1",Bytes[])
```

■ Sent data:

```
"r?{ ? _I X"
```

Direct sending of a binary data record with end string

■ Configured raw data:

```
<RAW>
<ELEMENT Tag="Buffer" Type="STREAM" EOS="65,66" />
</RAW>
```

■ Programming:

```
DECL EKI_STATUS RET
CHAR Bytes[64]
Bytes[]="Stream ends with:"
RET=EKI_Send("Channel_1",Bytes[])
```

■ Sent data:

```
"Stream ends with:AB"
```

6.2.5 Reading out data



In order to read out data, the corresponding KRL variables have to be initialized, e.g. by the assignment of values.

Description

XML and binary data are treated differently when saved and read out:

- XML data are extracted by the EKI and stored type-specifically in different memories. It is possible to access each saved value individually.
All EKI_Get...() access functions can be used to read out XML data.
- Binary data records are not interpreted by the EKI and stored together in a memory.
The EKI_GetString() access function must be used to read a binary data record out of a memory. Binary data records are read out of the memory as strings.
Binary data records of fixed length must be divided into individual variables again in the KRL program with CAST_FROM().



Detailed information on the CAST_FROM() command can be found in the CREAD/CWRITE documentation.

XML data example

Saved XML structure for data reception:

```
<Sensor>
  <Message>Example message</Message>
  <Status>
    <IsActive>1</IsActive>
  </Status>
</Sensor>
```

Programming:

```

; Declaration
INT i
DECL EKI_STATUS RET
CHAR valueChar[256]
BOOL valueBOOL

; Initialization
FOR i=(1) TO (256)
  valueChar[i]=0
ENDFOR
valueBOOL=FALSE

RET=EKI_GetString("Channel_1","Sensor/Message",valueChar[])
RET=EKI_GetBool("Channel_1","Sensor/Status/IsActive",valueBOOL)

```

Received data:

```

valueChar[] "Example message"
valueBOOL[] TRUE

```

Binary data example

Reading out a binary data record of fixed length (10 bytes)

■ Configured raw data:

```

<RAW>
  <ELEMENT Tag="Buffer" Type="BYTE" Size="10" />
</RAW>

```

■ Programming:

```

; Declaration
INT i
INT OFFSET
DECL EKI_STATUS RET
CHAR Bytes[10]
INT valueInt
REAL valueReal
BOOL valueBool
CHAR valueChar[1]
; Initialization
FOR i=(1) TO (10)
  Bytes[i]=0
ENDFOR
OFFSET=0
valueInt=0
valueBool=FALSE
valueReal=0
valueChar[1]=0
RET=EKI_GetString("Channel_1","Buffer",Bytes[])
OFFSET=0
CAST_FROM(Bytes[],OFFSET,valueReal,valueInt,valueChar[],valueBool)

```

Reading out a binary data record with end string

■ Configured raw data:

```

<RAW>
  <ELEMENT Tag="Buffer" Type="STREAM" EOS="13,10" />
</RAW>

```

■ Programming:

```

; Declaration
INT i
DECL EKI_STATUS RET
CHAR Bytes[64]
; Initialization
FOR i=(1) TO (64)
  Bytes[i]=0
ENDFOR
RET=EKI_GetString("Channel_1","Buffer",Bytes[])

```

6.2.6 Deleting received data

Description

A distinction is to be made between the following cases when deleting received data:

- Deletion with EKI_Clear(): the Ethernet connection is terminated and all memories used by the connection are deleted.
- Deletion with EKI_ClearBuffer(): data received but not yet called up are deleted from one or all of the memories.



XML data are extracted by the EKI and stored type-specifically in different memories. When deleting individual memories, it must be ensured that no data that belong together are lost.

Examples

- The position of the memory to be deleted is specified in XPATH. All elements after <Root><Activ><Flag>... are deleted.

```

EKI_STATUS RET
RET = EKI_ClearBuffer("Channel_1","Root/Activ/Flag")

```

- All memories of the <Root>...</Root> element are deleted.

```

EKI_STATUS RET
RET = EKI_ClearBuffer("Channel_1","Root")

```

6.2.7 EKI_STATUS – Structure for function-specific return values

Description

Each EthernetKRL function returns function-specific values. EKI_STATUS is the global structure variable to which these values are written.

Syntax

```
GLOBAL STRUC EKI_STATUS INT Buff, Read, Msg_No, BOOL Connected, INT Counter
```

Explanation of the syntax

Element	Description
Buff	Number of elements still in the memory after the access.
Read	Number of elements read out of the memory
Msg_No	Error number of the error that occurred during a function call or data reception. If automatic message output has been deactivated, EKI_CHECK() can be used to read out the error number and display the error message on the smartHMI.

Element	Description
Connected	Indicates whether a connection exists <ul style="list-style-type: none"> ■ TRUE = connection present ■ FALSE = connection interrupted
Counter	Time stamp for received data packets Data packets arriving in the memory are numbered consecutively in the order in which they are stored in the memory. If individual data are read, the Counter structure element is assigned the time stamp of the data packet from which the data element originates. (>>> 6.2.10 "Processing incomplete data records" Page 38)

Return values

The following elements of the EKI_STATUS structure are assigned data, depending on the function:

Function	Buff	Read	Msg_No	Connected	Counter
EKI_Init()					
EKI_Open()					
EKI_Close()					
EKI_Clear()					
EKI_Send()					
EKI_Set...()					
EKI_Get...()					
EKI_ClearBuffer()					
EKI_Lock()					
EKI_Unlock()					
EKI_CheckBuffer()					

6.2.8 Configuration of event messages**Description**

The following events can be signaled by setting an output or flag:

- Connection is active.
- An individual XML element has arrived at the interface.
- A complete XML structure or complete binary data record has arrived at the interface.

Event output




Fig. 6-4: Event output (active connection)

\$OUT[23] is set as long as the connection to the external system is active.
\$OUT[23] is reset when the connection is no longer active.



The connection can be restored only with the EKI_OPEN() function.

Event flag




Fig. 6-5: Event flag (complete XML structure)

The XML structure `<XY />` contains the `"XY/@x"` and `"XY/@z"` data elements. \$FLAG[1] is set since the complete XML structure has arrived at the interface. \$FLAG[2] is set since the `"x"` element is contained in `"XY"`. \$FLAG[3] is not set since the `"y"` element has not been transferred.

Example

6.2.9 Reception of complete XML data records

Description

The EKI_Get...() access functions are disabled until all data of an XML data record are in the memory.

If LIFO is configured and two or more XML data records arrive at the interface directly in succession, it is no longer ensured that a data record can be fetched in a non-fragmented condition from the memory. It may, for example, be the case that the data of the second data record are already stored in the memory although the first data record has not yet been completely processed. The data record available in the KRL is inconsistent since, in LIFO mode, the data saved last are always accessed first.

To prevent the fragmentation of data records in LIFO mode, the processing of newly received data must be disabled until all data belonging together have been fetched from the memory.

Example

```
...
RET=EKI_Lock("MyChannel")
RET=EKI_Get...()
RET=EKI_Get...()
...
RET=EKI_Get...()
RET=EKI_Unlock("MyChannel")
...
```

6.2.10 Processing incomplete data records

Under certain circumstances an external system may send incomplete data records. Individual XML elements are either empty or missing entirely, with the result that data from various data packets are present in one memory layer.

If it is necessary for the data records to be of contiguous structure in KRL, the Counter structure element of the EKI_STATUS variable can be used. When EKI_Get...Array functions are used, temporally non-contiguous data are recognized by the return of Counter = 0.

6.2.11 EKI_CHECK() – Checking functions for errors**Description**

For each error, EthernetKRL displays a message on the smartHMI. The automatic generation of messages can be deactivated.

(>>> 9.3 "Deactivating message output and message logging" Page 62)

If automatic message generation has been deactivated, it is recommended to use the EKI_CHECK() function to check whether an error has occurred during execution of an EthernetKRL function.

- The error number is read out and the corresponding message is displayed on the smartHMI.
- If a channel name is specified in EKI_CHECK(), it is checked during data reception whether errors have occurred.

(>>> 9.4.5 "Checking a function for errors" Page 69)

The program KRC:\R1\TP\EthernetKRL\EthernetKRL_USER.SRC is called up each time EKI_CHECK() is called up. User-specific error responses can be programmed in this program.

Example

A connection is closed whenever a reception error occurs. An interrupt can be programmed as a fault service function if the Ethernet connection is terminated.

- It is defined in the XmlTransmit.XML configuration file that FLAG[1] is set in the event of a successful connection. FLAG[1] is reset if the connection is lost.

```
<ALIVE Set_Flag="1"/>
```

- The interrupt is declared and switched on in the KRL program. The interrupt program is run if FLAG[1] is reset.

```
;FOLD Define callback
  INTERRUPT DECL 89 WHEN $FLAG[1]==FALSE DO CON_ERR()
  INTERRUPT ON 89
;ENDFOLD
```

- EKI_CHECK() is used in the interrupt program to query what sort of error occurred and then re-open the connection.

```
DEF CON_ERR()  
  DECL EKI_STATUS RET  
  RET={Buff 0,Read 0, Msg_no 0, Connected false}  
  EKI_CHECK(RET,#Quit,"XmlTransmit")  
  EKI_OPEN("XmlTransmit")  
END
```


7 Examples

7.1 Application examples

Overview

EthernetKRL comprises application examples which can be used to establish communication between a server program and the robot controller. The software can be found in the directory DOC\Example on the CD supplied.

The software consists of the following components:

Component	Folder
EthernetKRL_Server.exe server program	...\Application
Program examples in KRL <ul style="list-style-type: none"> ■ BinaryFixed.src ■ BinaryStream.src ■ XmlCallback.src ■ XmlServer.src ■ XmlTransmit.src 	...\Program
Configuration examples in XML <ul style="list-style-type: none"> ■ BinaryFixed.xml ■ BinaryStream.xml ■ XmlCallBack.xml ■ XmlServer.xml ■ XmlTransmit.xml ■ XmlFullConfig.xml 	...\Config

7.1.1 Implementing application examples

Precondition

External system:

- Windows operating system with .NET Framework 3.5 or higher installed

Robot controller:

- "Expert" user group
- Operating mode T1 or T2

Procedure

1. Copy the server program onto an external system.
2. Integrate the SRC files into the VW_USER module.
(>>> 7.1.2 "Integrating an example program into the VW_USER module" Page 42)
3. Copy the XML files into the directory C:\KRC\ROBOTER\Config\User\Common\EthernetKRL of the robot controller.
4. Start the server program on the external system.
(>>> 7.1.3 "Server program user interface" Page 43)
5. Press the menu button. The **Communication Properties** window appears.
(>>> 7.1.4 "Setting communication parameters in the server program" Page 45)
6. Only if several network interfaces are available at the external system: Enter the number of the network adapter (= network card index) used for communication with the robot controller.

7. Close the **Communication Properties** window and press the Start button. The IP address available for communication is displayed in the message window.
8. Set the displayed IP address of the external system in the desired XML file.

7.1.2 Integrating an example program into the VW_USER module

Precondition

- User group "Expert".
- Operating mode T1 or T2.

Procedure

1. Create a new program (Folge).
2. Call VW_USER in the Point PLC of the PTP motion before the start of the Folge.
3. In the inline form **VW User** define for the desired example program a parameter that is to be transferred to the VW_USER module.
4. In the subprogram USER_MAIN() of the file VW_USR_R.SRC, call the example program by means of an IF statement when the defined parameter is transferred.
5. Insert the example program as a subprogram at the end of the file VW_USR_R.SRC.

Example

In the program FOLGE1.SRC, VW_USER is called and the parameter X=12345 is transferred to the VW_USER module.

```

1  DEF FOLGE1 ()
2      PTP VB=100% VE=0% ACC=100% RobWzg=0 Base=0 SPSTrig=0[1/100s] P
3      1: VW USER X=12345 [mm] P2= 1 P3=1 P4=1 P5=1 P6=1 P7=EIN
4      Warte auf Folgenstart
    ...

```

In the subprogram USER_MAIN() of the file VW_USR_R.SRC, it is checked whether the parameter X=12345 (= PAR1) has been transferred. If this is the case, the subprogram BinaryFixed() is called.

```

1  DEF VW_USR_R(USER_CMD :IN,CMD_SEL :IN, PARA1 :IN,PARA2 :IN,PARA3
    :IN,PARA4 :IN,PARA5 :IN,PARA6 :IN,PARA7 :IN )
    ...
19 DEF  USER_MAIN (CMD_SEL :IN,PAR1 :IN,PAR2 :IN, PAR3
    :IN,PAR4 :IN,PAR5 :IN,PAR6 :IN,PAR7 :IN)
20 ;Aufruf im Hauptlauf
21 INT CMD_SEL,PAR1,PAR2,PAR3,PAR4,PAR5,PAR6
22 BOOL PAR7
23
24 IF PAR1 == 12345 THEN
25     BinaryFixed()
26 ENDIF
27
28 END
    ...
32 DEF  USER_MAKRO (CMD_SEL :IN,PAR1 :IN,PAR2 :IN, PAR3
    :IN,PAR4 :IN,PAR5 :IN,PAR6 :IN,PAR7 :IN)
33 ;Aufruf im Vorlauf
34 INT CMD_SEL,PAR1,PAR2,PAR3,PAR4,PAR5,PAR6
35 BOOL PAR7
36 END
37
38 DEF BinaryFixed( )
39 Declaration
40 INI
41 Initialize sample data
42
43 RET=EKI_Init("BinaryFixed")
44 RET=EKI_Open("BinaryFixed")
45 EKI_CHECK(RET,#QUIT)
46
47 OFFSET=0
48 CAST_TO(Bytes[],OFFSET,34.425,674345,"R",TRUE)
49
50 RET = EKI_Send("BinaryFixed",Bytes[])
51
52 WAIT FOR $FLAG[1]
53 RET=EKI_GetString("BinaryFixed","Buffer",Bytes[])
54 $FLAG[1]=FALSE
55
56 OFFSET=0
57 CAST_FROM(Bytes[],OFFSET,valueReal,valueInt,
    valueChar[],valueBool)
58
59 RET=EKI_Close("BinaryFixed")
60 RET=EKI_Clear("BinaryFixed")
61 END

```

Line	Description
24 ... 26	Condition for calling the subprogram BinaryFixed(): PAR1=12345
38 ... 61	Subprogram BinaryFixed()

7.1.3 Server program user interface

Description

The server program enables the communication between an external system and the robot controller to be tested by establishing a stable connection to the robot controller.

The server program has the following functions:

- Sending and receiving data (automatically or manually)
- Displaying the data received
- Displaying the data sent




Fig. 7-1: Server program user interface

Item	Description
1	Message window
2	<p>Display of the communication parameters set</p> <p>(>>> 7.1.4 "Setting communication parameters in the server program" Page 45)</p> <ul style="list-style-type: none"> ■ P: port number ■ E: example data <ul style="list-style-type: none"> ■ Xml: XML data ■ BinaryFixed: binary data of fixed length ■ BinaryStream: variable binary data stream with end string ■ A: communication mode <ul style="list-style-type: none"> ■ Autoreply: The server automatically responds to each data package received. ■ Manual: only manual data reception or data transmission
3	<p>Stop button</p> <p>Communication with the robot controller is terminated and the server is reset.</p>
4	<p>Start button</p> <p>Data exchange between the server program and robot controller is evaluated. The first incoming connection request is linked and used as a communication adapter.</p>
5	<p>Menu button for setting the communication parameters</p> <p>(>>> 7.1.4 "Setting communication parameters in the server program" Page 45)</p>
6	<p>Display options</p> <ul style="list-style-type: none"> ■ Arrow pointing to the left: the received RDC data are displayed. (Default) ■ Arrow pointing to the right: the sent RDC data are displayed.
7	Button for manual data reception

Item	Description
8	Button for manual data transmission
9	Display window The sent or received data are displayed, depending on the display option set.

7.1.4 Setting communication parameters in the server program

Procedure

1. Click on the menu button in the server program.
The **Communication Properties** window appears.
2. Set the communication parameters.
3. Close the window.

Description




Fig. 7-2: Communication Properties window

Element	Description
Example	<p>Select example data.</p> <ul style="list-style-type: none"> ■ Xml: XML data ■ BinaryFixed: binary data of fixed length ■ BinaryStream: variable binary data stream with end string <p>Default value: xml</p>
Autoresponder	<p>Select communication mode.</p> <ul style="list-style-type: none"> ■ Autoreply: The server automatically responds to each data package received. ■ Manual: only manual data reception or data transmission <p>Default value: Autoreply</p>
Portnumber	<p>Enter the port number of the socket connection.</p> <p>The external system awaits the connection request from the robot controller at this port. A free number that is not assigned a standard service must be selected.</p> <p>Default value: 59152</p>
Network interface card index:	<p>Enter the number of the network adapter.</p> <p>Only relevant if the external system uses several network cards, e.g. WLAN and LAN.</p> <p>Default value: 0</p>

7.2 Configuration and program examples

7.2.1 BinaryFixed configuration example



For communication with the robot controller, the appropriate example data must have been set in the server program; in this case **BinaryFixed**.

The EKI is configured as a client. Only binary data records with a fixed length of 10 bytes and the element name "Buffer" can be received via the connection. The server program sends a data record. \$FLAG[1] is set if the interface has received external data.

XML file

```
<ETHERNETKRL>
  <CONFIGURATION>
    <EXTERNAL>
      <IP>x.x.x.x</IP>
      <PORT>59152</PORT>
    </EXTERNAL>
  </CONFIGURATION>
  <RECEIVE>
    <RAW>
      <ELEMENT Tag="Buffer" Type="BYTE" Set_Flag="1" Size="10" />
    </RAW>
  </RECEIVE>
  <SEND />
</ETHERNETKRL>
```

Binary data records of fixed length must be read into and out of the KRL program with CAST_TO() and CAST_FROM(). Only data of REAL type (4 bytes) are legible, not Double.



Detailed information on the CAST_TO() and CAST_FROM() commands can be found in the CREAD/CWRITE documentation.

Program

```
1 DEF BinaryFixed( )
2   Declaration
3   INI
4   Initialize sample data
5
6   RET=EKI_Init("BinaryFixed")
7   RET=EKI_Open("BinaryFixed")
8
9   OFFSET=0
10  CAST_TO(Bytes[],OFFSET,34.425,674345,"R",TRUE)
11
12  RET = EKI_Send("BinaryFixed",Bytes[])
13
14  WAIT FOR $FLAG[1]
15  RET=EKI_GetString("BinaryFixed","Buffer",Bytes[])
16  $FLAG[1]=FALSE
17
18  OFFSET=0
19  CAST_FROM(Bytes[],OFFSET,valueReal,valueInt,
            valueChar[],valueBool)
20
21
22  RET=EKI_Close("BinaryFixed")
23  RET=EKI_Clear("BinaryFixed")
24  END
```

Line	Description
4	Initialization of KRL variables by the assignment of values
6	EKI_Init() initializes the channel used by the interface to connect to the external system.
7	EKI_Open() opens the channel and connects to the server.
9, 10	CAST_TO writes the values in the Bytes[] CHAR array.
12	EKI_Send() sends the Bytes[] CHAR array to the external system.
14 ... 16	\$FLAG[1] indicates the reception of the configured data element. EKI_GetString accesses the memory and copies the data into the Bytes[] CHAR array. \$FLAG[1] is reset again.
18, 19	CAST_FROM reads the values out of the Bytes[] CHAR array and copies them type-specifically into the specified variables.
22	EKI_Close() closes the channel.
23	EKI_Clear() clears the channel.

7.2.2 BinaryStream configuration example



For communication with the robot controller, the appropriate example data must have been set in the server program; in this case **BinaryStream**.

The EKI is configured as a client. Only binary data records with a maximum length of 64 bytes and the element name "Buffer" can be received via this connection. The end of the binary data record must be indicated with the end string CR, LF. \$FLAG[1] is set when the interface has received this element.

XML file

```
<ETHERNETKRL>
  <CONFIGURATION>
    <EXTERNAL>
      <IP>x.x.x.x</IP>
      <PORT>59152</PORT>
    </EXTERNAL>
  </CONFIGURATION>
  <RECEIVE>
    <RAW>
      <ELEMENT Tag="Buffer" Type="STREAM" Set_Flag="1"
        Size="64" EOS="13,10" />
    </RAW>
  </RECEIVE>
  <SEND />
</ETHERNETKRL>
```

Program

```

1  DEF BinaryStream( )
2  Declaration
3  INI
4  Initialize sample data
5
6  RET=EKI_Init("BinaryStream")
7  RET=EKI_Open("BinaryStream")
8
9  Bytes[]="Stream ends with CR,LF"
10
11 RET = EKI_Send("BinaryStream",Bytes[])
12
13 WAIT FOR $FLAG[1]
14 RET=EKI_GetString("BinaryStream","Buffer",Bytes[])
15 $FLAG[1]=FALSE
16
17 RET=EKI_Close("BinaryStream")
18 RET=EKI_Clear("BinaryStream")
19
20 END

```

Line	Description
4	Initialization of KRL variables by the assignment of values
6	EKI_Init() initializes the channel used by the interface to connect to the external system.
7	EKI_Open() opens the channel and connects to the server.
9	The Bytes[] CHAR array is assigned data.
11	EKI_Send() sends the Bytes[] CHAR array to the external system.
13 ... 15	<p>\$FLAG[1] indicates the reception of the configured data element.</p> <p>EKI_GetString reads the string in the Bytes[] CHAR array out of the memory.</p> <p>\$FLAG[1] is reset again.</p>
17	EKI_Close() closes the channel.
18	EKI_Clear() clears the channel.

7.2.3 XmlTransmit configuration example



For communication with the robot controller, the appropriate example data have to be set in the server program; in this case **Xml**.

The EKI is configured as a client. Robot data are sent and the received sensor data read out of the memory after a waiting time of 1 second.

XML file

```

<ETHERNETKRL>
  <CONFIGURATION>
    <EXTERNAL>
      <IP>x.x.x.x</IP>
      <PORT>59152</PORT>
    </EXTERNAL>
  </CONFIGURATION>
  <RECEIVE>
    <XML>
      <ELEMENT Tag="Sensor/Message" Type="STRING" />
      <ELEMENT Tag="Sensor/Positions/Current/@X" Type="REAL" />
      <ELEMENT Tag="Sensor/Positions/Before/X" Type="REAL" />
      <ELEMENT Tag="Sensor/Nmb" Type="INT" />
      <ELEMENT Tag="Sensor/Status/IsActive" Type="BOOL" />
      <ELEMENT Tag="Sensor/Read/xyzabc" Type="FRAME" />
      <ELEMENT Tag="Sensor/Show/@error" Type="BOOL" />
      <ELEMENT Tag="Sensor/Show/@temp" Type="INT" />
      <ELEMENT Tag="Sensor/Show" Type="STRING" />
      <ELEMENT Tag="Sensor/Free" Type="INT" />
    </XML>
  </RECEIVE>
  <SEND>
    <XML>
      <ELEMENT Tag="Robot/Data/LastPos/@X" />
      <ELEMENT Tag="Robot/Data/LastPos/@Y" />
      <ELEMENT Tag="Robot/Data/LastPos/@Z" />
      <ELEMENT Tag="Robot/Data/LastPos/@A" />
      <ELEMENT Tag="Robot/Data/LastPos/@B" />
      <ELEMENT Tag="Robot/Data/LastPos/@C" />
      <ELEMENT Tag="Robot/Data/ActPos/@X" />
      <ELEMENT Tag="Robot/Status" />
      <ELEMENT Tag="Robot/Mode" />
      <ELEMENT Tag="Robot/RobotLamp/GrenLamp/LightOn" />
    </XML>
  </SEND />
</ETHERNETKRL>

```

Program

```

1  DEF XmlTransmit( )
2  Declaration
3  Communicated data
4  INI
5  Initialize sample data
6
7  RET=EKI_Init("XmlTransmit")
8  RET=EKI_Open("XmlTransmit")
9
10 Write data to connection
11 Send data to external program
12 Get received sensor data
13
14 RET=EKI_Close("XmlTransmit")
15 RET=EKI_Clear("XmlTransmit")
16
17 END

```

Line	Description
5	Initialization of KRL variables by the assignment of values
7	EKI_Init() initializes the channel used by the interface to connect to the external system.
8	EKI_Open() opens the channel and connects to the external system.
10	Writes data in the saved XML document for data transmission.
11	Sends the written XML document to the external system.
12	Reads the received sensor data out of the memory.
14	EKI_Close() closes the channel.
15	EKI_Clear() clears the channel.

7.2.4 XmlServer configuration example



If the interface has been configured as a server, the server program cannot be used on the external system. A simple client can be implemented with Windows HyperTerminal.

The EKI is configured as a server. \$FLAG[1] is set as long as a connection to the external system exists.

XML file

```
<ETHERNETKRL>
  <CONFIGURATION>
    <EXTERNAL>
      <TYPE>Client</TYPE>
    </EXTERNAL>
    <INTERNAL>
      <IP>x.x.x.x</IP>
      <PORT>54600</PORT>
      <ALIVE Set_Flag="1" />
    </INTERNAL>
  </CONFIGURATION>
  <RECEIVE>
    <XML>
      <ELEMENT Tag="Sensor/A" Type="BOOL" />
    </XML>
  </RECEIVE>
  <SEND>
    <XML>
      <ELEMENT Tag="Robot/B" />
    </XML>
  </SEND>
</ETHERNETKRL>
```

Program

```
1 DEF XmlServer( )
2 Declaration
3 INI
4
5 RET=EKI_Init("XmlServer")
6 RET=EKI_Open("XmlServer")
7
8 ; wait until server is connected
9 wait for $FLAG[1]
10 ; wait until server is disconnected
11 wait for $FLAG[1]==FALSE
12
13 RET=EKI_Clear("XmlServer")
14 END
```

Line	Description
5	EKI_Init() initializes the channel used by the external system to connect to the interface.
6	EKI_Open() opens the channel.
9	\$FLAG[1] is set when the external client has connected successfully to the server.
11	Since the interface is configured as a server, the robot controller expects the channel to be closed by the external client. In this case, \$FLAG[1] is deleted.
13	EKI_Clear() clears the channel.

7.2.5 XmlCallback configuration example



For communication with the robot controller, the appropriate example data have to be set in the server program; in this case **Xml**.

The EKI is configured as a client. Robot data are sent, sensor data received and then \$FLAG[1] awaited. \$FLAG[1] indicates that the sensor data have been read out.

It is configured in the XML file that \$FLAG[998] is set when the interface has received all sensor data. This flag triggers an interrupt in the program. The configuration of the "Sensor" tag as event tag ensures that the sensor data are fetched only when all data are in the memories.

\$FLAG[998] is reset and \$FLAG[1] set when the sensor data have been read out.

XML file

```
<ETHERNETKRL>
  <CONFIGURATION>
    <EXTERNAL>
      <IP>x.x.x.x</IP>
      <PORT>59152</PORT>
    </EXTERNAL>
  </CONFIGURATION>
  <RECEIVE>
    <XML>
      <ELEMENT Tag="Sensor/Message" Type="STRING" />
      <ELEMENT Tag="Sensor/Positions/Current/@X" Type="REAL" />
      <ELEMENT Tag="Sensor/Positions/Before/X" Type="REAL" />
      <ELEMENT Tag="Sensor/Nmb" Type="INT" />
      <ELEMENT Tag="Sensor/Status/IsActive" Type="BOOL" />
      <ELEMENT Tag="Sensor/Read/xyzabc" Type="FRAME" />
      <ELEMENT Tag="Sensor/Show/@error" Type="BOOL" />
      <ELEMENT Tag="Sensor/Show/@temp" Type="INT" />
      <ELEMENT Tag="Sensor/Show" Type="STRING" />
      <ELEMENT Tag="Sensor/Free" Type="INT" Set_Out="998" />
      <ELEMENT Tag="Sensor" Set_Flag="998" />
    </XML>
  </RECEIVE>
  <SEND>
    <XML>
      <ELEMENT Tag="Robot/Data/LastPos/@X" />
      <ELEMENT Tag="Robot/Data/LastPos/@Y" />
      <ELEMENT Tag="Robot/Data/LastPos/@Z" />
      <ELEMENT Tag="Robot/Data/LastPos/@A" />
      <ELEMENT Tag="Robot/Data/LastPos/@B" />
      <ELEMENT Tag="Robot/Data/LastPos/@C" />
      <ELEMENT Tag="Robot/Data/ActPos/@X" />
      <ELEMENT Tag="Robot/Status" />
      <ELEMENT Tag="Robot/Mode" />
      <ELEMENT Tag="Robot/RobotLamp/GrenLamp/LightOn" />
    </XML>
  <SEND />
</ETHERNETKRL>
```

Program

```

1  DEF XmlCallBack( )
2  Declaration
3  Communicated data
4  INI
5  Define callback
6
7  RET=EKI_Init("XmlCallBack")
8  RET=EKI_Open("XmlCallBack")
9
10 Write data to connection
11 RET = EKI_Send("XmlCallBack","Robot")
12
13 ;wait until data read
14 WAIT FOR $FLAG[1]
15
16 RET=EKI_Close("XmlCallBack")
17 RET=EKI_Clear("XmlCallBack")
18 END
19
20 DEF GET_DATA()
21 Declaration
22 Initialize sample data
23 Get received sensor data
24 Signal read

```

Line	Description
5	Declaring and switching on the interrupt
7	EKI_Init() initializes the channel used by the interface to connect to the external system.
8	EKI_Open() opens the channel.
10	Writes data in the saved XML document for data transmission.
11	Sends the data.
14	Waits for \$FLAG[1]. The event flag signals that all data have been read.
16	EKI_Close() closes the channel.
17	EKI_Clear() clears the channel.
20 ... 24	initialization of KRL variables by assigning values and reading out data \$FLAG[1] is set when all data have been read.

Data transmission

The XML document is assigned robot data by the KRL program and sent to the external system via the EKI.

```

<Robot>
  <Data>
    <LastPos X="..." Y="..." Z="..." A="..." B="..." C="...">
    </LastPos>
    <ActPos X="1000.12">
    </ActPos>
  </Data>
  <Status>12345678</Status>
  <Mode>ConnectSensor</Mode>
  <RobotLamp>
    <GrenLamp>
      <LightOn>1</LightOn>
    </GrenLamp>
  </RobotLamp>
</Robot>

```

Data reception

The XML document is assigned sensor data by the server program and received by the EKI.

```
<Sensor>
  <Message>Example message</Message>
  <Positions>
    <Current X="4645.2" />
    <Before>
      <X>0.9842</X>
    </Before>
  </Positions>
  <Nmb>8</Nmb>
  <Status>
    <IsActive>1</IsActive>
  </Status>
  <Read>
    <xyzabc X="210.3" Y="825.3" Z="234.3" A="84.2" B="12.3"
      C="43.5" />
  </Read>
  <Show error="0" temp="9929">Taginfo in attributes</Show>
  <Free>2912</Free>
</Sensor>
```


8 Diagnosis

8.1 Displaying diagnostic data

- Procedure**
1. Select **Diagnosis > Diagnostic monitor** in the main menu.
 2. Select the **EKI (EthernetKRL)** module in the **Module** field.

Description

Name	Description
Total memory	Total available memory (bytes)
Allocated memory	Used memory (bytes)
Robot program connections	Number of connections initialized by the robot interpreter
Submit program connections	Number of connections initialized by the Submit interpreter
System connections	Number of connections initialized by the system
Ethernet connections	Number of open connections
Processing time	Maximum time required to process received data (refreshed every 5 seconds)
Warning messages	Number of warning messages
Error messages	Number of error messages



The warning and error messages are also counted if the automatic message output and message logging have been deactivated.

8.2 Error protocol (EKI logbook)

All error messages of the interface are logged in a LOG file under C:\KRC\ROBOTER\LOG\EthernetKRL.

8.3 Error messages

If an error has occurred when a function is called or data are received, EthernetKRL returns the error number. The error numbers are assigned a message text which is displayed on the smartHMI. If the automatic generation of messages is deactivated, the message can still be displayed on the smartHMI by means of EKI_CHECK().

No.	Message text	Cause	Remedy
1	<i>Unknown error</i>	No message has been assigned to the error.	Contact KUKA Roboter GmbH and submit the log-book with details on the error. (>>> 10 "KUKA Service" Page 71)
2	<i>Out of system memory</i>	The memory reserved for EthernetKRL is completely occupied. No more elements can be saved.	Check the programming method in KRL and the configuration of the Ethernet connection. If no other type of programming or configuration is possible, the memory can be increased in consultation with KUKA Roboter GmbH. (>>> 9.2 "Increasing the memory" Page 61)
3	<i>File access failed</i>	A file could not be found or is not legible.	Check whether the file is present or whether the file can be opened.
4	<i>Requested function not implemented</i>	Software error: The EthernetKRL function used has not been implemented.	Contact KUKA Roboter GmbH and submit the log-book with details on the error. (>>> 10 "KUKA Service" Page 71)
5	<i>Creation of XML parser failed</i>	The connection has not been initialized, since the internal system parser could not be activated.	Contact KUKA Roboter GmbH and submit the log-book with details on the error. (>>> 10 "KUKA Service" Page 71)
6	<i>Interpretation of configuration failed</i>	Error when reading the connection configuration	Check the configuration of the Ethernet connection.
7	<i>Writing of data to send failed</i>	Error when writing the XML structure for the data transmission	check configuration of transmission structure.
8	<i>Add new element failed</i>	Error when creating the data memory	Contact KUKA Roboter GmbH and submit the log-book with details on the error. (>>> 10 "KUKA Service" Page 71)
9	<i>Connection not available</i>	No access to the connection is possible due to the missing initialization.	Initialize the Ethernet connection with EKI_Init().
10	<i>Ethernet is disconnected</i>	No Ethernet connection is present.	Open the Ethernet connection with EKI_Open().
11	<i>Ethernet connection to external system established</i>	Ethernet connection is already present.	Do not call the EKI_Open() function if the Ethernet connection already exists.

No.	Message text	Cause	Remedy
12	<i>Create server failed</i>	An Ethernet connection configured as a server could not be created.	Check configuration of connection parameters (IP elements, PORT).
13	<i>Initialization of Ethernet parameters failed</i>	Error when initializing the Ethernet connection	Check configuration of connection parameters (IP elements, PORT).
14	<i>Ethernet connection to external system failed</i>	No Ethernet connection: <ul style="list-style-type: none"> ■ Hardware error, e.g. network cable, switch, external system ■ Software error (external system) ■ Error during the connection configuration 	Establish an Ethernet connection: <ul style="list-style-type: none"> ■ Check hardware. ■ Check software of external system. ■ Check configuration of connection parameters (IP elements, PORT).
15	<i>Access to empty element memory</i>	No data elements in the memory when accessed with EKI_Get...()	Evaluate the return value of the EKI_Get...() function in the KRL program to avoid accessing empty memories ("Buff" element). (>>> 6.2.7 "EKI_STATUS – Structure for function-specific return values" Page 35)
16	<i>Element not found</i>	A data element specified in the EKI_Get...() access function cannot be found.	<ul style="list-style-type: none"> ■ Check the name of the data element and its notation in the KRL program. ■ Check the configuration of the reception structure.
17	<i>Assembly of data to send failed</i>	<ul style="list-style-type: none"> ■ Sending XML data: error when writing the XML document for data transmission ■ Sending binary data: error when checking the binary data to be sent 	<ul style="list-style-type: none"> ■ Sending XML data: check configuration of transmission structure. ■ Sending binary data: Check the EKI_Send() function in the KRL program.
18	<i>Send data failed</i>	No Ethernet connection: <ul style="list-style-type: none"> ■ Hardware error, e.g. network cable, switch, external system ■ Software error (external system) 	Establish an Ethernet connection: <ul style="list-style-type: none"> ■ Check hardware. ■ Check software of external system.
19	<i>No data to send</i>	The data to be sent are not specified in an EKI_Send() function.	Check the EKI_Send() function in the KRL program.

No.	Message text	Cause	Remedy
20	<i>Mismatch in type of data</i>	An attempt was made to read an element which belongs to a different data type.	Check the data type of the element in the configuration of the reception structure. OR Use the data type defined in the configuration of the reception structure in the KRL program.
21	<i>System memory insufficient with maximum data storage</i>	It was established that the system memory is insufficient when reading in the configuration.	Check the configuration of the Ethernet connection and adjust it so that less memory is used. If no other configuration is possible, the memory can be increased in consultation with KUKA Roboter GmbH. (>>> 9.2 "Increasing the memory" Page 61)
22	<i>Error while reading the configuration. XML not valid.</i>	An error in the XML structure was detected when reading in the configuration.	Check the XML structure in the configuration file.
24	<i>Link to internal parameters (Port, IP) failed</i>	The Ethernet connection, i.e. the interface, is configured as a server. The IP address and port number of the external system specified in the configuration are not available.	Use the correct IP address and port number in the configuration of the connection parameters (IP elements, PORT).
25	<i>Internal software error</i>	Internal software error	Contact KUKA Roboter GmbH and submit the logbook with details on the error. (>>> 10 "KUKA Service" Page 71)
26	<i>FRAME array not initialized</i>	An FRAME type array has not been initialized.	Initialize the FRAME type array (assign value).
27	<i>CHAR[] Array too small.</i>	A CHAR type array is too small.	Increase the number of array elements.
512	<i>Ethernet connection disrupted</i>	No Ethernet connection: <ul style="list-style-type: none">■ Hardware error, e.g. network cable, switch, external system■ Software error (external system)	Restore the Ethernet connection: <ul style="list-style-type: none">■ Check hardware.■ Check software of external system.
768	<i>Ping reports no contact</i>	The external system no longer responds to the ping sent. The connection is aborted.	Check external system.

No.	Message text	Cause	Remedy
1024	<i>Error while reading received XML data</i>	An XML document received from the external system does not correspond to the XPath schema.	Check the XML document sent by the external system.
1280	<i>Limit of element storage reached</i>	The data memory is assigned the maximum number of data elements. The Ethernet connection is closed.	Evaluate the return value of the EKI_Get...() function in the KRL program to disable the processing of received data ("Buff" element). (>>> 6.2.7 "EKI_STATUS – Structure for function-specific return values" Page 35) OR Increase the data memory (BUFFERING element in the connection configuration).
1536	<i>Received string too long</i>	Programming error on external system: a string received from the external system exceeds the maximum permissible length (max. 3,600 characters).	Check the data sent by the external system.
1792	<i>Limit of element memory reached</i>	The data memory is assigned the maximum number of bytes. The Ethernet connection is closed.	Increase the data memory (BUFFSIZE element in the connection configuration).
2048	<i>Server time limit reached</i>	Server is waiting for a call.	Check external system.

9 Appendix

9.1 Extended XML structure for connection properties



The extended XML structure may only be used in consultation with KUKA Roboter GmbH. (>>> 10 "KUKA Service" Page 71)

Description

Further interface properties can be configured in the section <INTERNAL> ... </INTERNAL> of the configuration file:

Element	Attribute	Description
TIMEOUT	Receive	Time until the attempt to receive data is aborted (optional) <ul style="list-style-type: none"> 0 ... 65,534 ms Default value: 0 ms
	Send	Time until the attempt to send data is aborted (optional) <ul style="list-style-type: none"> 0 ... 65,534 ms Default value: 0 ms
BUFFSIZE	Receive	Size of the socket used to receive data (optional) <ul style="list-style-type: none"> 1 ... 65,534 bytes Default value: Predefined by the system
	Send	Size of the socket used to send data (optional) <ul style="list-style-type: none"> 1 ... 65,534 bytes Default value: Predefined by the system

9.2 Increasing the memory



The memory may be increased only in consultation with KUKA Roboter GmbH. (>>> 10 "KUKA Service" Page 71)

Description

If the available memory is insufficient, it is recommended to check the programming method in KRL as well as the configuration.

- Check whether a connection is configured in such a manner that the memory is completely occupied with received data.
- Check whether several connections with high levels of data have been defined and activated.

Precondition

- Windows interface

Procedure

- Open the file C:\KRC\ROBOTER\Config\User\Common\Ethernet-KRL.XML.
- Enter the desired memory capacity in bytes in the <MemSize> element in the <EthernetKRL> section.

```
<EthernetKRL>
  <Interface>
    <MemSize>1048576</MemSize>
    ...
  </EthernetKRL>
```

3. Save the change and close the file.

9.3 Deactivating message output and message logging

Description

It is recommended for automatic message output on the smartHMI to be deactivated in the following cases:

- Runtime errors occur.
- The EKI is used in the Submit interpreter.

If automatic message output is deactivated, all error messages are still logged by default. If these errors or warnings are to be deliberately ignored, e.g. because logging the messages causes a high system load and slows down performance, this mechanism can likewise be deactivated.

Precondition

- "Expert" user group

Procedure

1. Open the configuration file of the Ethernet connection in the directory C:\KRC\ROBOTER\Config\User\Common\EthernetKRL of the robot controller.
2. Enter the following line in the section <INTERNAL> ... </INTERNAL> of the XML file:

```
<Messages Display="disabled" Logging="disabled"/>
```

3. Save the change and close the file.



If automatic message output is deactivated, the EKI_CHECK() function can be used to check individual EKI instructions for errors.

9.4 Command reference

9.4.1 Initializing, opening, closing and clearing a connection

RET = EKI_Init(CHAR[])	
Function	Initializes a channel for Ethernet communication The following actions are performed: <ul style="list-style-type: none"> ■ The configuration is read in. ■ The data memories are created. ■ The Ethernet connection is prepared.
Parameter	Type: CHAR Name of channel
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_Init("Channel_1")

RET = EKI_Open(CHAR[])	
Function	Opens an initialized channel If the EthernetKRL interface is configured as a client, the interface connects to the server. If the EthernetKRL interface is configured as a server, the interface waits for the connection.
Parameter	Type: CHAR Name of channel
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_Open("Channel_1")

RET = EKI_Close(CHAR[])	
Function	Closes an open channel
Parameter	Type: CHAR Name of channel
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_Close("Channel_1")

RET = EKI_Clear(CHAR[])	
Function	Deletes a channel and terminates the connection.
Parameter	Type: CHAR Name of channel
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_Clear("Channel_1")

9.4.2 Sending data

RET = EKI_Send(CHAR[], CHAR[])	
Function	Sends an XML structure or raw data (>>> 6.2.4 "Sending data" Page 31)
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure or name of the element in the raw data If the position or element is not found, the function sends the information contained here
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example 1	RET = EKI_Send("Channel_1", "Root/Test")
Example 2	RET = EKI_Send("Channel_1", MyBytes[])

9.4.3 Writing data

RET = EKI_SetReal(CHAR[], CHAR[], REAL)	
Function	Writes a floating point value in a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: REAL Value written in the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_SetReal("Channel_1", "Root/Number", 1.234)

RET = EKI_SetInt(CHAR[], CHAR[], INTEGER)	
Function	Writes an integer value in a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: INT Value written in the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_SetInt("Channel_1", "Root/List", 67234)

RET = EKI_SetBool(CHAR[], CHAR[], BOOL)	
Function	Writes a Boolean value in a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: BOOL Value written in the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_SetBool("Channel_1", "Root/Activ", true)

RET = EKI_SetFrame(CHAR[], CHAR[], FRAME)	
Function	Writes a FRAME type value in a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure

RET = EKI_SetFrame(CHAR[], CHAR[], FRAME)	
Parameter 3	Type: FRAME Value written in the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET= EKI_SetFrame("Channel_1", "Root/BASE", {X 0.0, Y 0.0, Z 0.0, A 0.0, B 0.0, C 0.0})

RET = EKI_SetString(CHAR[], CHAR[], CHAR[])	
Function	Writes a string in a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: CHAR String written in the memory Maximum number of characters: ■ 3,600
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_SetString("Channel_1", "Root/Message", "Hello")

9.4.4 Reading data

RET = EKI_GetBool(CHAR[], CHAR[], BOOL)	
Function	Reads a Boolean value out of a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: BOOL Value read out of the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_GetBool("Channel_1", "Root/Activ", MyBool)

RET = EKI_GetBoolArray(CHAR[], CHAR[], BOOL[])	
Function	<p>Reads a Boolean value out of the memory and copies the value into the array transferred by the KRL program</p> <p>Values are read until the array is full or no element is present anymore.</p>
Parameter 1	<p>Type: CHAR</p> <p>Name of the open channel</p>
Parameter 2	<p>Type: CHAR</p> <p>Name of the position in the XML structure</p>
Parameter 3	<p>Type: BOOL</p> <p>Array read out of the memory</p> <p>Maximum number of readable array elements:</p> <p>■ 512</p>
RET	<p>Type: EKI_STATUS</p> <p>Return values of the function (>>> "Return values" Page 36)</p>
Example	RET = EKI_GetBoolArray("Channel_1", "Root/Activ", MyBool[])

RET = EKI_GetInt(CHAR[], CHAR[], Int)	
Function	Reads an integer value out of a memory
Parameter 1	<p>Type: CHAR</p> <p>Name of the open channel</p>
Parameter 2	<p>Type: CHAR</p> <p>Name of the position in the XML structure</p>
Parameter 3	<p>Type: INT</p> <p>Value read out of the memory</p>
RET	<p>Type: EKI_STATUS</p> <p>Return values of the function (>>> "Return values" Page 36)</p>
Example	RET = EKI_GetInt("Channel_1", "Root/Numbers/One", MyInteger)

RET = EKI_GetIntArray(CHAR[], CHAR[], Int[])	
Function	<p>Reads an integer value out of a memory and copies the value into the array transferred by the KRL program</p> <p>Values are read until the array is full or no element is present anymore.</p>
Parameter 1	<p>Type: CHAR</p> <p>Name of the open channel</p>
Parameter 2	<p>Type: CHAR</p> <p>Name of the position in the XML structure</p>
Parameter 3	<p>Type: INT</p> <p>Array read out of the memory</p> <p>Maximum number of readable array elements:</p> <p>■ 512</p>

RET = EKI_GetIntArray(CHAR[], CHAR[], Int[])	
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_GetIntArray("Channel_1", "Root/Numbers/One", MyInteger[])

RET = EKI_GetReal(CHAR[], CHAR[], Real)	
Function	Reads a floating point value out of a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: REAL Value read out of the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_GetReal("Channel_1", "Root/Position", MyReal)

RET = EKI_GetRealArray(CHAR[], CHAR[], Real[])	
Function	Reads a floating point value out of a memory and copies the value into the array transferred by the KRL program Values are read until the array is full or no element is present anymore.
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: REAL Array read out of the memory Maximum number of readable array elements: ■ 512
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_GetRealArray("Channel_1", "Root/Position", MyReal[])

RET = EKI_GetString(CHAR[], CHAR[], CHAR[])	
Function	Reads a string out of a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure or name of the element in the raw data

RET = EKI_GetString(CHAR[], CHAR[], CHAR[])	
Parameter 3	Type: CHAR String read out of the memory Maximum number of characters: ■ 3,600
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
XML example	RET = EKI_GetString("Channel_1", "Root/Message", MyChars[])
Binary example	RET = EKI_GetString("Channel_1", "Streams", MyStream[])

RET = EKI_GetFrame(CHAR[], CHAR[], FRAME)	
Function	Reads a FRAME type value out of a memory
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: FRAME Value read out of the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_GetFrame("Channel_1", "Root/TCP", MyFrame)

RET = EKI_GetFrameArray(CHAR[], CHAR[], FRAME[])	
Function	Reads a FRAME type value out of a memory and copies the value into the array transferred by the KRL program Values are read until the array is full or no element is present anymore.
Parameter 1	Type: CHAR Name of the open channel
Parameter 2	Type: CHAR Name of the position in the XML structure
Parameter 3	Type: FRAME Array read out of the memory Maximum number of readable array elements: ■ 512
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_GetFrameArray("Channel_1", "Root/TCP", MyFrame[])

9.4.5 Checking a function for errors

EKI_CHECK(EKI_STATUS, EKrlMsgType, CHAR[])	
Function	Checks whether an error occurred during execution of an EthernetKRL function: <ul style="list-style-type: none"> ■ The error number is read out and the corresponding message is displayed on the smartHMI. (Parameter 1) ■ Optional: If the channel name is specified, it is checked during data reception whether errors have occurred. (Parameter 3)
Parameter 1	EKI_STATUS Return values of the checked function (>>> "Return values" Page 36)
Parameter 2	Type: ENUM Type of message displayed on the smartHMI: <ul style="list-style-type: none"> ■ #NOTIFY: Notification message ■ #STATE: Status message ■ #QUIT: Acknowledgement message ■ #WAITING: Wait message
Parameter 3 (optional)	Type: CHAR Name of the open channel
Example 1	EKI_CHECK(RET,#QUIT)
Example 2	EKI_CHECK(RET,#NOTIFY,"MyChannelName")

9.4.6 Clearing, locking, unlocking and checking a memory

RET = EKI_ClearBuffer(CHAR[], CHAR[])	
Function	Deletes data which have been received but not yet called up from a memory
Parameter 1	Type: CHAR Name of channel
Parameter 2	Type: CHAR Position of the memory or all memories (>>> 6.2.6 "Deleting received data" Page 35)
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example 1	RET = EKI_ClearBuffer("Channel_1", "Root/Activ/Flag")
Example 2	RET = EKI_ClearBuffer("Channel_1", "Root")

RET = EKI_Lock(CHAR[])	
Function	Disables the processing of received data, i.e. the data can no longer be stored in the memory.

RET = EKI_Lock(CHAR[])	
Parameter	Type: CHAR Name of channel
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)

RET = EKI_Unlock(CHAR[])	
Function	Enables the processing of received data, i.e. the data are stored in the memory again.
Parameter	Type: CHAR Name of channel
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)

RET = EKI_CheckBuffer(CHAR[], CHAR[])	
Function	Checks how many data elements are still in the memory. The memory is not changed. Additionally, the time stamp of the next data element ready to be taken from the memory is returned.
Parameter 1	Type: CHAR Name of channel
Parameter 2	Type: CHAR Position of the memory
RET	Type: EKI_STATUS Return values of the function (>>> "Return values" Page 36)
Example	RET = EKI_CheckBuffer("Channel_1", "Root/Activ/Flag")

10 KUKA Service

10.1 Requesting support

Introduction The KUKA Roboter GmbH documentation offers information on operation and provides assistance with troubleshooting. For further assistance, please contact your local KUKA subsidiary.

Information The following information is required for processing a support request:

- Model and serial number of the robot
- Model and serial number of the controller
- Model and serial number of the linear unit (if applicable)
- Version of the VW System Software
- Optional software or modifications
- Archive of the software

For VW System Software V8: instead of a conventional archive, generate the special data package for fault analysis (via **KrcDiag**).

- Application used
- Any external axes used
- Description of the problem, duration and frequency of the fault

10.2 KUKA Customer Support

Availability KUKA Customer Support is available in many countries. Please do not hesitate to contact us if you have any questions.

Argentina Ruben Costantini S.A. (Agency)
Luis Angel Huergo 13 20
Parque Industrial
2400 San Francisco (CBA)
Argentina
Tel. +54 3564 421033
Fax +54 3564 428877
ventas@costantini-sa.com

Australia Headland Machinery Pty. Ltd.
Victoria (Head Office & Showroom)
95 Highbury Road
Burwood
Victoria 31 25
Australia
Tel. +61 3 9244-3500
Fax +61 3 9244-3501
vic@headland.com.au
www.headland.com.au

Belgium	<p>KUKA Automatisering + Robots N.V. Centrum Zuid 1031 3530 Houthalen Belgium Tel. +32 11 516160 Fax +32 11 526794 info@kuka.be www.kuka.be</p>
Brazil	<p>KUKA Roboter do Brasil Ltda. Travessa Claudio Armando, nº 171 Bloco 5 - Galpões 51/52 Bairro Assunção CEP 09861-7630 São Bernardo do Campo - SP Brazil Tel. +55 11 4942-8299 Fax +55 11 2201-7883 info@kuka-roboter.com.br www.kuka-roboter.com.br</p>
Chile	<p>Robotec S.A. (Agency) Santiago de Chile Chile Tel. +56 2 331-5951 Fax +56 2 331-5952 robotec@robotec.cl www.robotec.cl</p>
China	<p>KUKA Robotics China Co.,Ltd. Songjiang Industrial Zone No. 388 Minshen Road 201612 Shanghai China Tel. +86 21 6787-1888 Fax +86 21 6787-1803 www.kuka-robotics.cn</p>
Germany	<p>KUKA Roboter GmbH Zugspitzstr. 140 86165 Augsburg Germany Tel. +49 821 797-4000 Fax +49 821 797-1616 info@kuka-roboter.de www.kuka-roboter.de</p>

France
KUKA Automatisme + Robotique SAS
Techvallée
6, Avenue du Parc
91140 Villebon S/Yvette
France
Tel. +33 1 6931660-0
Fax +33 1 6931660-1
commercial@kuka.fr
www.kuka.fr

India
KUKA Robotics India Pvt. Ltd.
Office Number-7, German Centre,
Level 12, Building No. - 9B
DLF Cyber City Phase III
122 002 Gurgaon
Haryana
India
Tel. +91 124 4635774
Fax +91 124 4635773
info@kuka.in
www.kuka.in

Italy
KUKA Roboter Italia S.p.A.
Via Pavia 9/a - int.6
10098 Rivoli (TO)
Italy
Tel. +39 011 959-5013
Fax +39 011 959-5141
kuka@kuka.it
www.kuka.it

Japan
KUKA Robotics Japan K.K.
YBP Technical Center
134 Godo-cho, Hodogaya-ku
Yokohama, Kanagawa
240 0005
Japan
Tel. +81 45 744 7691
Fax +81 45 744 7696
info@kuka.co.jp

Canada
KUKA Robotics Canada Ltd.
6710 Maritz Drive - Unit 4
Mississauga
L5W 0A1
Ontario
Canada
Tel. +1 905 670-8600
Fax +1 905 670-8604
info@kukarobotics.com
www.kuka-robotics.com/canada

Korea	<p>KUKA Robotics Korea Co. Ltd. RIT Center 306, Gyeonggi Technopark 1271-11 Sa 3-dong, Sangnok-gu Ansan City, Gyeonggi Do 426-901 Korea Tel. +82 31 501-1451 Fax +82 31 501-1461 info@kukakorea.com</p>
Malaysia	<p>KUKA Robot Automation Sdn Bhd South East Asia Regional Office No. 24, Jalan TPP 1/10 Taman Industri Puchong 47100 Puchong Selangor Malaysia Tel. +60 3 8061-0613 or -0614 Fax +60 3 8061-7386 info@kuka.com.my</p>
Mexico	<p>KUKA de México S. de R.L. de C.V. Progreso #8 Col. Centro Industrial Puente de Vigas Tlalnepantla de Baz 54020 Estado de México Mexico Tel. +52 55 5203-8407 Fax +52 55 5203-8148 info@kuka.com.mx www.kuka-robotics.com/mexico</p>
Norway	<p>KUKA Sveiseanlegg + Roboter Sentrumsvegen 5 2867 Hov Norway Tel. +47 61 18 91 30 Fax +47 61 18 62 00 info@kuka.no</p>
Austria	<p>KUKA Roboter Austria GmbH Vertriebsbüro Österreich Regensburger Strasse 9/1 4020 Linz Austria Tel. +43 732 784752 Fax +43 732 793880 office@kuka-roboter.at www.kuka-roboter.at</p>

Poland KUKA Roboter Austria GmbH
Spółka z ograniczoną odpowiedzialnością
Oddział w Polsce
Ul. Porcelanowa 10
40-246 Katowice
Poland
Tel. +48 327 30 32 13 or -14
Fax +48 327 30 32 26
ServicePL@kuka-roboter.de

Portugal KUKA Sistemas de Automatización S.A.
Rua do Alto da Guerra n° 50
Armazém 04
2910 011 Setúbal
Portugal
Tel. +351 265 729780
Fax +351 265 729782
kuka@mail.telepac.pt

Russia OOO KUKA Robotics Rus
Webnaja ul. 8A
107143 Moskau
Russia
Tel. +7 495 781-31-20
Fax +7 495 781-31-19
kuka-robotics.ru

Sweden KUKA Svetsanläggningar + Robotar AB
A. Odhners gata 15
421 30 Västra Frölunda
Sweden
Tel. +46 31 7266-200
Fax +46 31 7266-201
info@kuka.se

Switzerland KUKA Roboter Schweiz AG
Industriestr. 9
5432 Neuenhof
Switzerland
Tel. +41 44 74490-90
Fax +41 44 74490-91
info@kuka-roboter.ch
www.kuka-roboter.ch

Spain	KUKA Robots IBÉRICA, S.A. Pol. Industrial Torrent de la Pastera Carrer del Bages s/n 08800 Vilanova i la Geltrú (Barcelona) Spain Tel. +34 93 8142-353 Fax +34 93 8142-950 Comercial@kuka-e.com www.kuka-e.com
South Africa	Jendamark Automation LTD (Agency) 76a York Road North End 6000 Port Elizabeth South Africa Tel. +27 41 391 4700 Fax +27 41 373 3869 www.jendamark.co.za
Taiwan	KUKA Robot Automation Taiwan Co., Ltd. No. 249 Pujong Road Jungli City, Taoyuan County 320 Taiwan, R. O. C. Tel. +886 3 4331988 Fax +886 3 4331948 info@kuka.com.tw www.kuka.com.tw
Thailand	KUKA Robot Automation (M)SdnBhd Thailand Office c/o Maccall System Co. Ltd. 49/9-10 Soi Kingkaew 30 Kingkaew Road Tt. Rachatheva, A. Bangpli Samutprakarn 10540 Thailand Tel. +66 2 7502737 Fax +66 2 6612355 atika@ji-net.com www.kuka-roboter.de
Czech Republic	KUKA Roboter Austria GmbH Organisation Tschechien und Slowakei Sezemická 2757/2 193 00 Praha Horní Počernice Czech Republic Tel. +420 22 62 12 27 2 Fax +420 22 62 12 27 0 support@kuka.cz

Hungary KUKA Robotics Hungaria Kft.
Fő út 140
2335 Taksony
Hungary
Tel. +36 24 501609
Fax +36 24 477031
info@kuka-robotics.hu

USA KUKA Robotics Corporation
51870 Shelby Parkway
Shelby Township
48315-1787
Michigan
USA
Tel. +1 866 873-5852
Fax +1 866 329-5852
info@kukarobotics.com
www.kukarobotics.com

UK KUKA Automation + Robotics
Hereward Rise
Halesowen
B62 8AN
UK
Tel. +44 121 585-0800
Fax +44 121 585-0900
sales@kuka.co.uk

Index

A

Appendix 61
Application examples 41
Application examples, implementing 41

C

CAST_FROM() 33, 46
CAST_TO() 31, 46
Client mode 12, 31
Command reference 62
Communication 9
Configuration 19
Configuration examples 46
Configuration, Ethernet connection 9, 21
Connection, monitoring 10

D

Data exchange 10
Data stream 6
Defragmentation 37
Diagnosis 55
Diagnostic data, displaying 55
Diagnostic monitor (menu item) 55
Documentation, industrial robot 5

E

EKI 6
EKI_CHECK() 35, 38, 69
EKI_CheckBuffer() 29, 70
EKI_Clear() 35, 63
EKI_ClearBuffer() 35, 69
EKI_Close() 31, 63
EKI_GetBool() 65
EKI_GetBoolArray() 66
EKI_GetFrame() 68
EKI_GetFrameArray() 68
EKI_GetInt() 66
EKI_GetIntArray() 66
EKI_GetReal() 67
EKI_GetRealArray() 67
EKI_GetString() 33, 67
EKI_Init() 29, 62
EKI_Lock() 69
EKI_Open() 31, 63
EKI_Send() 31, 63
EKI_SetBool() 64
EKI_SetFrame() 64
EKI_SetInt() 64
EKI_SetReal() 64
EKI_SetString() 65
EKI_STATUS 35
EKI_Unlock() 70
End string 6
EOS 6
Error messages 55
Error protocol 55
Error response, programming 38
Error treatment 13

Ethernet 6

Ethernet connection, configuration 9, 21
Ethernet, interfaces 19
EthernetKRL_Server.exe 41
EthernetKRL, overview 9
Event messages 13, 36
Examples 41

F

Features 9
FIFO 6, 11
Fragmentation 37
Functions 9
Functions, overview 27

H

Hardware 17

I

Installation 17
Installation, EthernetKRL 17
Introduction 5
IP 6

K

KLI 6, 19
Knowledge, required 5
KR C 6
KRL 6
KRL program, examples 41
KUKA Customer Support 71

L

LIFO 6, 11, 37
Logbook 55
Lost connection 9

M

Memory, increasing 61
Messages, deactivating 62
Monitoring, connection 10

N

Network connection 19

O

Overview, EthernetKRL 9
Overview, functions 27

P

Ping 10
Product description 9
Program examples 46
Programming 21
Programming tips 28
Protocol types 12

S

- Safety 15
- Safety instructions 5
- Saving data 10
- Server mode 12, 31
- Server program 41
- Server program, setting communication parameters 45
- Server program, user interface 43
- Service, KUKA Roboter 71
- smarHMI 6
- Socket 6
- Software 17
- Support request 71
- System requirements 17

T

- Target group 5
- TCP/IP 6
- Terms used 6
- Terms, used 6
- Time stamp 36
- Trademarks 7
- Training 5

U

- UDP/IP 6
- Uninstallation, EthernetKRL 18
- Update, EthernetKRL 17

V

- VW_USER, integrating example program 42

W

- Warnings 5

X

- XML 7
- XML file, examples 41
- XPath 7, 24, 26, 27

