

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 235

Dated: -16/07/2026

It is certified that an inspection team headed by Girendra Kumar Patel, Sub-Engineer

(Name of Officers with designation) from P.H.E. Sub-Dn Raigarh PHED

inspected the Little Angle public school Tadola (Pusour.)

(Name & Address of the school) on 10/07/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DL/PHED/RGH-256 dated 12/07/26

of District water testing Lab Raigarh (PHED Lab) certified that the

Little Angle public school Tadola (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30/06/2027

Signature with Seal: PHED Sub-Dn Raigarh

Name

Designation

Name & Address of the Office / Department : PHED Raigarh

To

Principal
Little Angle public school Tadola (Pusour.)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
L.A.P.S.- Tadola
Distt.-Raigarh(C.G.)

Manager
L.A.P.S.- Tadola
Distt.-Raigarh(C.G.)



District Water Testing Laboratory
Public Health Engineering Department, Div. Raigarh
Near PHE, Central Store Campus, Chakradhar Nagar Raigarh C.G.
e-mail:- phedrghlab1990@gmail.com

Test Report (Drinking Water)

Report no. DL/PHED/RGH. - 256	Discipline:- Chemical Testing	Group:- Drinking Water		
Senders Name :- Principal Little Angel Public School Tadola , Pusour, Raigarh (C.G.)	Senders letter no./Date	Nil/09.07.2026	Sampled by	By Client
	Sample collection date	09.07.2026	Sampling Plan & procedure	Sampling is not done by laboratory staff
	DL receipt no.	135	DL Receipt date	09.07.2026
	Date of analysis started	09.07.2026	Date of analysis completed	10.07.2026

Sample Details

S No.	Sample ID	District/Block	Panchayat/Village	Habitation	Location/Source ID/GPS Identification
1	DL/RGH-25/994	Raigarh/ Pusour	Tadola	-	Compus Of Little Angel Public School Tadola

Details of parameters their test method units and specification as per IS:3025/APHA

S. No.	Parameters	Test method IS:3025/APHA 24th ed.		unit	As per IS-10500-2012(Second Rev) for drinking water		Results				
		method	Part no.		Acceptable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5	6	7					
1	Iron	APHA24th ed	3500-Fe-B	mg/L	0.3	01	0.11				
2	Nitrates	APHA24th ed	4500-NO ₃ -B	mg/L	45	45	-				
3	Fluoride	APHA24th ed	4500-F-C	mg/L	1.0	1.5	0.36				
4	Sulphate	APHA24th ed	IS:3025	mg/L	200	400	-				
5	Conductivity	IS:3025	Part- 14	µmho/cm	-	-	231				
6	Total Coliform	-	-	CFU/100ml	Nil	Nil	00 (24 Hours)				
7	Residual Chlorin	-	-	mg/L	0.2	1	-				
8	Test	IS:3025	Part- 8	-	Agreable	Agreable	Agr.				

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
 2. The results refer only to tested samples and parameters.
 3. Samples will be stored for a period of 10 days from date of issue of report.
 4. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
- Remarks - 1. Results apply to the sample as received.
2. Sampling not done by Lab staff.

Issue no./date. 256/12.07.2026

Chemist / Lab Incharge
District Water Testing Laboratory
P.H.E.D. Raigarh C.G

Lab Assistant
District Water Testing Laboratory
P.H.E.D. Raigarh C.G

Principal
L.A.P.S.- Tadola
Distt.-Raigarh(C.G.)

Manager
L.A.P.S.- Tadola
Distt.-Raigarh(C.G.)

****End Of Report****



District Water Testing Laboratory
Public Health Engineering Department, Div. Raigarh
 Near PHE, Central Store Campus, Chakradhar Nagar Raigarh C.G.

e-mail:- phedrghlab1990@gmail.com



TC-13241

Test Report (Drinking Water)

Report no. DL/PHED/RGH. - 256	Discipline:- Chemical Testing	Group:- Drinking Water	ULR no. :- TC13241250000000251F
Senders Name :- Principal Little Angel Public School Tadola, Pusour, Raigarh (C.G.)	Senders letter no./Date	NII/09.07.2026	Sampled by
	Sample collection date	09.07.2026	Sampling Plan & procedure
	DL receipt no.	135	DL Receipt date
	Date of analysis started	09.07.2026	Date of analysis completed
			By Client Sampling is not done by laboratory staff

Sample Details					
S No.	Sample ID	District/Block	Panchayat/Village	Habitation	Location/Source ID/GPS Identification
1	DL/RGH-25/994	Raigarh/ Pusour	Tadola	-	Compus Of Little Angel Public School Tadola

Details of parameters their test method units and specification as per IS:3025/APHA

S. No.	Parameters	Test method IS:3025/APHA 24th ed.		unit	As per IS-10500-2012(Second Rev) for drinking water		Results				
		method	Part no.		Acceptable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5	6	7					
1	Colour	APHA24th ed	2120-B	Hazen	5	15	2				
2	Odour	IS:3025	Part 5	-	Agreeable	Agreeable	Ag.				
3	TDS (Total Dissolved Solids)	APHA24th ed	Part-2540-C	mg/L	500	2000	120				
4	Chloride as Cl-	APHA24th ed	Part-4500-Cl-B	mg/L	250	1000	16.56				
5	Alkalinity as CaCO3	APHA24th ed	Part-3220- B	mg/L	200	600	58.23				
6	Total Hardness as CaCO3	APHA24th ed	Part-2340- C	mg/L	200	600	68.27				
7	Calcium as Ca2+	APHA24th ed	3500- Ca- B	mg/L	75	200	20.92				
8	Magnesium as Mg2+	APHA24th ed	3500- Mg-B	mg/L	30	100	3.90				
9	pH	IS:3025	Part-11	pH Scale	6.5-8.5	No Relaxation	6.68				
10	Turbidity	IS:3025	Part-10	NTU	1	5	1.26				

- The report should not be produced partly or full without approval signatory authority of legal purpose.
- The results refer only to tested samples and parameters.
- Samples will be stored for a period of 10 days from date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.

Remarks - 1. Results apply to the sample as received.
 2. Sampling not done by Lab staff.

Issue no./date. 256/12.07.2026 Page no.01/01

Tested by :- Khomnath Sahu

(Raju George)
 Authorized Signatory

****End Of Report****

(Signature)
 28/09/2026
Principal
 L.A.P.S.- Tadola
 Distt.-Raigarh(C.G.)

(Signature)
Manager
 L.A.P.S.- Tadola
 Distt.-Raigarh(C.G.)