

Range

HAIEnd

HAI

No

Name

Unit

Description

Min

Max

23.05

23.05

153

DM-CIP-1ST

-

-

-

For maintenance

154

DM-CIP-2ND

-

-

-

For maintenance

155

DM-CIP-START

-

-

-

For maintenance

156

DM-CIP-STEP1

-

-

-

For maintenance

157

DM-CIP-STEP11

-

-

-

For maintenance

158

DM-CIPH-1ST

-

-

-

For maintenance

159

DM-CIPH-2ND

-

-

-

For maintenance

160

DM-CIPH-START

-

-

-

For maintenance

161

DM-CIPH-STEP1

-

-

-

For maintenance

162

DM-CIPH-STEP11

-

-

-

For maintenance

163

DM-COOL-ON

-

-

-

For maintenance

164

DM-COOL-R

-

-

-

For maintenance

165

DM-FCV01-D

0

100

%

Position command for the FCV01 valve

(P1_FCV01D)

166

DM-FCV01-Z

0

100

%

Current position of the FCV01 valve

(P1_FCV01Z)

167

DM-FCV02-D

0

100

%

Position command for the FCV02 valve

(P1_FCV02D)

168

DM-FCV02-Z

0

100

%

Current position of the FCV02 valve

(P1_FCV02Z)

169

DM-FCV03-D

0

100

%

Position command for the FCV03 valve

(P1_FCV03D)

170

DM-FCV03-Z

0

100

%

Current position of the FCV03 valve

(P1_FCV03Z)

171

DM-FT01

0

2,500

mmH2O

Measured flowrate of the return water tank

(P1_FT01)

172

DM-FT01Z

0

3,190

l/h

Water inflow rate converted from P1_FT01

(P1_FT01Z)

173

DM-FT02

0

2,500

mmH₂O

Measured flowrate of heating water tank

(P1_FT02)

174

DM-FT02Z

0

3,190

l/h

Water outflow rate conversion from P1_FT02

(P1_FT02Z)

175

DM-FT03

0

2,500

mmH2O

Measured flowrate of the return water tank

(P1_FT03)

176

DM-FT03Z

0

3,190

l/h

Water outflow rate converted from P1_FT03

(P1_FT03Z)

177

DM-HT01-D

0

1

Boolean

Start command of heater

178

DM-LCV01-D

0

100

%

Position command for the LCV01 valve

(P1_LCV01D)

179

Check point when the difference between DM-LCV01-D

DM-LCV01-MIS

0

1

Boolean

and DM-LCV01-Z exceeds 10

180

DM-LCV01-Z

0

100

%

Current position of the LCV01 valve

(P1_LCV01Z)

21