

Range

HAI

No

Name

Unit

Description

Min

22.04

Max

20.07

21.03

23.05

79

P4\_HT\_PS

0

100

MW

Scheduled power demand of HTM

80

P4\_LD

0

500

MW

Total electrical load demand

81

P4\_ST\_FD

-0,02

0.02

Hz

Frequency deviation of STM

82

P4\_ST\_GOV

0

27,648

-

Gate opening rate of STM

83

P4\_ST\_LD

0

500

MW

Electrical load demand of STM

84

P4\_ST\_PO

0

500

MW

Output power of STM

85

P4\_ST\_PS

0

500

MW

Scheduled power demand of STM

86

P4\_ST\_PT01

0

27,648

-

Digital value of steam pressure of STM

87

P4\_ST\_TT01

0

27,648

-

Digital value of steam temperature of STM

TOTAL

59

78

86

HAIEND DATA POINTS

The HAIEnd 23.05 has 225 data points, all points of Boiler' Emerson Ovation DCS. 35 data points of HAIEnd correspond to the same points as in the HAI data points. Duplicate points are shown in the table below.

Range

HAIEnd

HAI

No

Name

Unit

Description

Min

Max

23.05

23.05

1

1001.02-OUT

-

-

-

Output of 1001.02

2

1001.05-OUT

-

-

-

Output of 1001.05

3

1001.07-OUT1

-

-

-

Output of 1001.07

4

1001.07-OUT2

-

-

-

Output of 1001.07

5

1001.08-OUT

-

-

-

Output of 1001.08

6

1001.09-OUT

-

-

-

Output of 1001-.9

7

1001.13-OUT

-

-

-

Output of 1001.13

8

1001.14-OUT

-

-

-

Output of 1001.14

9

1001.15-OUT

-

-

-

Output of 1001.15

(P1\_B2016)

10

1001.16-OUT

-

-

-

Output of 1001.16

11

1001.17-OUT

-

-

-

Output of 1001.17

12

1001.20-OUT

-

-

-

Output of 1001.20

15