SHREE RAM RESEARCH AND TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001:2015 MSME APPROVED LABORATORY

H.O. G-42, Krishan Vihar, North West Delhi, Delhi-110086

Lab- BGH-A, P-2, 205, Pine Tower, Second Floor, Paramount Golf Forest, Opp- Sector Zeta-1 Surajpur, Site-C, Industrial Area, Greater Noida, Gautam Buddha Nagar, (U.P) - 201306

Website : http://www.shreeramresearch.com | E-mail:- info@shreeramresearch.com | info@shreeramresearch.in

9355579996, 9548480033, 7011745586, 8810200342, 8810226618 ☎ 0120-5104809

TEST REPORT

Issued to :M/s Koncave Anchor Fastners Pvt. Ltd. Ismaila-11B, Tehsil Sampla Rohtak	**Report No.**	**M-020424-01**
	Report date:	08/04/2024
	Sample Received:	02/04/2024
	Analysis date:	04/04/2024 to 08/04/2024
	Sampled By:	Customer

Reference Letter Date 29-03-2024

Sample Description: Galvanized Wedge Anchor
Size: M8x100 mm

RESULTS

A	Parameters (Units)	Test Method	Results
I	Tensile Strength (N/mm^2)	IS:1608(P-1) 2022	545.08
II	Shear Strength(N/mm^2)		299.75
III	Double Shear Load (KN)		23.54

END OF REPORT

TESTED BY

Shree Ram Research And Testing Laboratories ★ Technical Manager

AUTHORIZED SIGNATORY

Note: (I) The above Results are related only to the fast performed on the sample, Endorsement to product is nether inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in any advertising media without special permission in writing (3) sample will be destroyed after 30 days from the date reporting unless otherwise specified .(4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by Shree Ram Research and Testing Laboratories unless mentioned otherwise.

SHREE RAM RESEARCH AND TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001:2015 MSME APPROVED LABORATORY

H.O. G-42, Krishan Vihar, North West Delhi, Delhi-110086

Lab- BGH-A, P-2, 205, Pine Tower, Second Floor, Paramount Golf Forest, Opp- Sector Zeta-1 Surajpur, Site-C, Industrial Area, Greater Noida, Gautam Buddha Nagar, (U.P) - 201306

Website : http://www.shreeramresearch.com | E-mail:- info@shreeramresearch.com | info@shreeramresearch.in

9355579996, 9548480033, 7011745586, 8810200342, 8810226618 ☎ 0120-5104809

TEST REPORT

Issued to :M/s Koncave Anchor Fastners Pvt. Ltd. Ismaila-11B, Tehsil Sampla Rohtak	**Report No.**	**M-020424-02**
	Report date:	08/04/2024
	Sample Received:	02/04/2024
	Analysis date:	04/04/2024 to 08/04/2024
	Sampled By:	Customer

Reference Letter Date 29-03-2024

Sample Description: Galvanized Wedge Anchor
Size:M 10x100 mm

RESULTS

A	Parameters (Units)	Test Method	Results
I	Tensile Strength (N/mm^2)	IS:1608(P-1) 2022	570.24
II	Shear Strength(N/mm^2)		303.79
III	Double Shear Load (KN)		23.86

END OF REPORT

TESTED BY

Shree Ram Research And Testing Laboratories ★ Technical Manager

AUTHORIZED SIGNATORY

Note: (I) The above Results are related only to the fast performed on the sample, Endorsement to product is nether inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in any advertising media without special permission in writing (3) sample will be destroyed after 30 days from the date reporting unless otherwise specified .(4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by Shree Ram Research and Testing Laboratories unless mentioned otherwise.

SHREE RAM RESEARCH AND TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001:2015 MSME APPROVED LABORATORY

H.O. G-42, Krishan Vihar, North West Delhi, Delhi-110086
Lab- BGH-A, P-2, 205, Pine Tower, Second Floor, Paramount Golf Forest, Opp- Sector Zeta-1
Surajpur, Site-C, Industrial Area, Greater Noida, Gautam Buddha Nagar, (U.P) - 201306
Website : http://www.shreeramresearch.com | E-mail:- info@shreeramresearch.com | info@shreeramresearch.in
9355579996, 9548480033, 7011745586, 8810200342, 8810226618 ☎ 0120-5104809

TEST REPORT

Issued to :M/s Koncave Anchor Fastners Pvt. Ltd. Ismaila-11B, Tehsil Sampla Rohtak	**Report No.**	**M-020424-03**
	Report date:	08/04/2024
	Sample Received:	02/04/2024
	Analysis date:	04/04/2024 to 08/04/2024
	Sampled By:	Customer

Reference Letter Date 29-03-2024

Page: 1/1

Sample Description: Galvanized Wedge Anchor
Size: M12x150 mm

RESULTS

A	Parameters (Units)	Test Method	Results
I	Tensile Strength (N/mm^2)	IS:1608(P-1) 2022	597.11
II	Shear Strength(N/mm^2)		346.26
III	Double Shear Load (KN)		27.20

END OF REPORT

TESTED BY

Shree Ram Research And Testing Laboratories ★ Technical Manager

AUTHORIZED SIGNATORY

Note: (I) The above Results are related only to the fast performed on the sample, Endorsement to product is nether inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in any advertising media without special permission in writing (3) sample will be destroyed after 30 days from the date reporting unless otherwise specified .(4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by Shree Ram Research and Testing Laboratories unless mentioned otherwise.