



NIGERIAN ELECTRICITY MANAGEMENT SERVICES AGENCY

CORPORATE HEADQUARTERS

No 4, Dar es Salaam Crescent Wuse II, Abuja



Federal Ministry
of Power

REF. ID: H481-2-A-0407-2025-1-OS-002

CERTIFICATION NO.: NEMSA/NMTSO/TTC/2025/082.
EXPIRY DATE: 17TH JULY, 2027.

ELECTRICITY METER TEST CERTIFICATE

NAME OF CLIENT: HEDREG GROUP LIMITED

ADDRESS OF CLIENT: TEAM 1, ROAD 1312, 1ST AVENUE, HOUSE NO 6, GWARINPA ESTATE,
ABUJA, NIGERIA.

METER MANUFACTURER: SHENZHEN CALINMETER CO., LIMITED

ADDRESS OF MANUFACTURER: FLOOR 6, BD A6, QIAODE TECH PARK, KELVIN ROAD, GUANG
MING DISTRICT SHENZHEN, CHINA.

METER CERTIFICATION TYPE: TYPE TEST

METER PARTICULARS

DESCRIPTION:

MAKE: Three Phase Whole Current Prepaid
Energy Meter.

TYPE DESIGNATION: CA368

CLASS: 1.0

RATED CURRENT: 3X10(100) A

METER CONSTANT: 1000 imp/KWh

APPLICATION: Indoor

MODE OF REGISTRATION: Uni-Directional

APPLICABLE STANDARD:

The Energy Meter was tested based on the requirements of:

NIS/IEC 62052-11:2021 : Electricity Metering Equipment (a.c)-General Requirements, Tests and
Conditions for Metering equipment.

NIS/IEC 62053-21:2021 : Electricity Metering Equipment (a.c)-Particular Requirements: Static
Meters for Active Energy (classes 1 and 2).

Nigeria Metering Code (NMC) Version 02

TEST LOCATION: NATIONAL METER TEST STATION, OSHODI, LAGOS

AMBIENT CONDITIONS: Temperature: 27.1 °C, Relative Humidity: 38%

TEST MODE: As received (The samples of electricity meter were received in good condition
without any defect. See pages 27-28)

SCOPE OF TEST: Covers evaluation of conformity to General/Constructional, Insulation,
Accuracy, Electrical, Electro-magnetic, Mechanical and Climatic requirements.

EXCLUSION FROM LIABILITY CLAUSE

This certification covers the meter(s) presented to NEMSA for certification, NEMSA is not liable
for any tampering, alteration or modification that may occur after certifications.

CERTIFIED BY: Engr. GIDEON FAFUNMI DESIGNATION: GM NMTSO

SIGNATURE: [Signature] DATE: 23-07-2025

