

SECURED RFID-BASED ACCESS CONTROL SYSTEM
FOR 11 INFANTRY DIVISION

1. Overview.

This project aims to enhance the security infrastructure of the 11 Infantry Division by implementing an automated RFID-based access control system. The primary objectives are to streamline personnel entry/exit, ensure real-time tracking of movement, and restrict unauthorized access to cantonment. The scope includes a central control station for identity management and automated access points equipped with physical barriers.



2. Project Cost Summary.

Item Description	Cost (BDT)
1. Control Station Hardware	
1 x Desktop PC	50,000
Network Connectivity	0
1 x J308 RFID Card Reader (125KHz)	1,000
Blank RFID Cards (10 Pcs)	1,000
Subtotal (Control Station)	52,000
2. Server PC Hardware	
Desktop PC hardware (Database server & management terminal)	80,000

RESTRICTED

Subtotal (Server PC)	80,000
3. Access Point Hardware (1 x Gate)	
1 x Desktop PC (Local gateway controller)	50,000
2 x J308 RFID Card Readers (125KHz)	1,000
1 x Turnstile Barrier Gate	100,000
Blank Visitor RFID Cards (100 Pcs)	10,000
Subtotal (Access Point)	161,000
4. Software Development	
Software Development & Implementation	100,000
Subtotal (Software)	100,000
GRAND TOTAL	393,000

3. Operational Workflow. The system operates through a sequential authentication process:

- a. Scanning. A soldier or visitor taps their RFID card against the J308 reader at the gate.
- b. Authentication. The local terminal communicates with the centralized database at 4 Sig Bn to verify card validity.
- c. Triggering. Upon successful verification, the system sends an electronic signal to the Turnstile Barrier Gate.
- d. Logging. The entry time and personnel ID are logged in the central control station for audit purposes.

4. Training Requirements. A one-week training program titled "System Familiarization & Operation" may be conducted to enable all units to become accustomed to the RFID system operations and troubleshooting.

RESTRICTED

5. **Maintenance & Contingency.** To ensure 24/7 operational readiness, the following protocols are established:

- a. **Maintenance:** Weekly hardware diagnostics for RFID readers and monthly mechanical servicing of the turnstile gates.
- b. **Contingency:** In the event of a power failure, the turnstile barriers will switch to manual override mode. Local terminals are equipped with UPS backup to maintain data integrity until power is restored or safe shutdown occurs.