

SOP: Cooling System Thresholds

Standard Operating Procedure: Cooling System

Acceptable Operating Ranges:

1. Pressure: Must be between 90 PSI and 110 PSI.
2. Temperature: Must not exceed 50 °C.
3. Seal Integrity: Must be intact with no leaks.

If all conditions are met, the equipment is approved for continued operation.