

SOP: Boiler Safety Parameters

Standard Operating Procedure: Boiler Gamma

Critical Safety Limits:

1. Maximum allowable pressure: 110 PSI.
2. Maximum allowable temperature: 90 °C.
3. Structural integrity: Any fractures or cracks are immediate grounds for failure.

Action: If any critical safety limit is breached, the decision **MUST** be REJECT.

Equipment must be flagged for immediate shutdown and repair.