

SOP: Backup Generator Maintenance

Standard Operating Procedure: Generator Safety

Inspection Requirements:

1. Oil Level must be Normal.
2. Battery Voltage must be measured and above 12.5V.
3. If any data point is missing or 'Unknown', the equipment status is undetermined.

Action: If data is missing, the decision MUST be REVIEW for manual intervention.