



OpenBuildingControl

ASHRAE Standard 231P
—
Control Description Language

Michael Wetter, LBNL

March 30, 2022

ASHRAE Proposed Standard 231 “A Control Description Language for Building Environmental Control Systems”

- Started in September 2020.
- Approximately 35 members on the committee including system designers, control suppliers, and others.
- Proposed Structure:
 - Title, Purpose, Scope
 - Definitions and introduction
 - **Definition of control function blocks**
 - **Semantics and Structure**
 - **Definition of CDL**
 - Definition of a Controls Exchange Format (CXF)

Why Are We Doing This?

Properly applied commercial building controls can reduce energy use by 20 - 30% and also help improve comfort, safety, and protect occupant health.

But the current process for control design, delivery, operation, and maintenance is problematic.

To ensure that installed control sequences are high performing, OpenBuildingControl

1. Allows performance assessment of controls during design.
2. Digitizes the controls design and delivery.
3. Allows quality control at each step.
4. Allows high performance sequences to be shared — controls becomes a digital asset.

To aid deployment, project

5. Creates an ASHRAE Standard to provide industry with robust technology.
6. Integrates with DOE's BEM program
7. Creates tools for designers, control providers and commissioning agents.

Challenges of today's process

Designer

- Producing specifications are tedious and error-prone.
- Controls is a skill many designers do not have.
- No tools to judge how good a sequence is.
- Controls is not tested, let alone co-designed or optimized.

Controls Contractor

- Interpreting verbose sequence is tedious and error-prone.
- Often very tight schedule and budget.
- Often old sequences are adapted to make them work on next building.
- Errors and callbacks are expensive.

Commissioning agent & operator

- Verification is slow, tedious, and often done only for a limited set of conditions.
- Control intent is poorly documented.
- Lack of semantic knowledge complicates FDD and analytics.

What is new?

Specification

Provide tools for system designers to select and customize control sequences using a reference library including ASHRAE Guideline 36.

Performance testing

Provide tools for the designer to validate and test the sequence during design.

Support Spawn of Energy Plus to do accurate energy modeling of control sequences.

Deployment

Communicate logic to the contractor in a digital format.

This means that the control contractor no longer needs to interpret the sequence and develop the logic - saving time and money and reducing errors.

Standard documentation of control logic for commissioning agents and owners.


Verification

Tools to validate the logic in an installed system relative to design specification.




Standardized through a
vendor-independent
language

Digital control delivery process that links repository of control sequences with tools for design, deployment and verification




What gap does CDL address?



What is the Control Description Language?


A declarative **block diagram language**.



A **library** with elementary input/output blocks that should be supported, through a translator, by control providers.

Example:

CDL has a gain with input u , gain k , and output $y = k * u$.



A **documentation syntax** for control blocks and sequences.

Output the absolute value of the input


Information

Block that outputs $y = \text{abs}(u)$, where u is an input.

Connectors

Type	Name	Description
input RealInput	u	Connector of Real input signal
output RealOutput	y	Connector of Real output signal

A **model of computation** that describes when to update signals.



A language fully compatible with the open Modelica standard, enabling **simulation** and **code generation**.


How we specified CDL

Conform to the Modelica Standard 3.3, **but** remove everything that is not needed to practically declare control logic and their English language documentation.

Keep it simple & easy to parse.

... and allow reuse of technology from the Modelica ecosystem.

Reviewed by advisory panel, through peer-review process, and used by various project partners from industry.



Basic elementary blocks are defined in a library that is immutable to the users (fixed by the specification).


Basic blocks are organized in packages

- Constants
- Continuous
- Conversions
- Discrete
- Integers
- Logical
- Psychrometrics
- Routing
- SetPoints
- Utilities
- Types
- Interfaces

blocks are in packages:

Signal sources are in **Sources** sub package:

Blocks for validation and CI tests are in **Validation** package




Basic elementary blocks are defined in a library that is immutable to the users (fixed by the specification).

Behavior is expressed mathematically,


$$(p, t, u(t), x(t)) \mapsto y(t).$$

Software implementation is not part of the specification.


Control product line can use any language.



For implementation, can translate CDL to proprietary control product lines, or can use CDL natively





Library of Reference Sequence Implementations based on ASHRAE Guidelines





Library of Reference Sequence Implementations based on ASHRAE Guidelines

1711 Chiller Plant Control Sequences



1711 Boiler Plant Control Sequences



Sequence Selection and Configuration Tool “Linkage”

All Projects > Denver Build 2021

EDIT

Systems

Ventilation, Air Handlers And Other...

Exhaust Fans

- Default_Exhaust Fan qty. 1

Multiple Zone VAV Air Handler

- MZ_VAVCustom qty. 10

Single Zone VAV Air Handler

- Default_Single-Zone VAV qty. 4

Zone Equipment

VAV Parallel Fan Powered

- Default_Fan Powered Box... qty. 16

VAV Series Fan Powered

- Default_Fan Powered Box... qty. 8

Chilled Water Plants

Air Cooled Chilled Water Plant

- Default_Electric Chiller_Air qty. 2

Heating Plants

Results

LAST SAVED: TODAY 2:31PM

SAVE

MZ_VAVCustom

Schematics


Sequence

Points List

Schedules

Download.RVT

?



DETAILS

SYSTEMS

CONFIGS


SCHEDULES

RESULTS


ALL DOWNLOADS

15

Prototype translation showed feasibility of translating Guideline 36 multi-zone VAV sequence to an existing control product line



Implementation in CDL




Translation to Automated Logic webCTRL

Summary

Overarching goal is to digitize control delivery to provide robust implementation of control sequences at scale.

- ASHRAE Standard 231P.
- Control repository
 - LBNL and PNNL are implementing sequences from ASHRAE Guideline 36 using CDL, and other sources.
 - Support for ASHRAE Guideline 36.
 - Expansion towards heat pump plants and systems with storage.
 - Spawn of EnergyPlus integration
- Sequence Selection and Configuration Tool
- Verification, in support of
 - Simulation Q&A
 - Commissioning agents
- Integration with
 - Other “advanced” methods such as MPC/RL.
 - Fault Detection and Diagnostics.
 - Semantic models.



Questions?