



ECOTECH SERVICES INC... (Analytical Laboratory Division)

ISO/IEC - 17025 : 2017 Accredited Testing Laboratory
by NABL Vide Certificate Number TC - 5951.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road,
Ballabgarh - 121004, Faridabad (Haryana)
Phone No.: +91-129-4630926, M.: 9650160159, 9911378912

E-mail : ecotbd@yahoo.com, info@ecotechservices.in

Website : www.ecotechservices.in

MSME No. : UDYAM-HR-03-0021507



TEST REPORT

Test Report Issued To:-	ULR Number	TC-5951-230000008138
M/s Liquiclear Technologies Private Ltd.	Date of Report	04/09/2023
64/2A, New Industrial Area	Work Order No.	ESI/23-24/0478
NIT- Faridabad -121001(Haryana)	Period of testing	31/08/2023 to 04/09/2023
	Type of Sample	Raw Water Sample
	Date of Receiving	31/08/2023
	Method of Sampling	-
	Sample Received By.	Mr. S. Choudhary
Description of Sample.	One "Raw Water" sample was received by us on 31/08/2023.	
Sample Code/ Location.	Raw Water.	

Test Results.

S. No.	Parameter	Unit	Test Results	Limits as per IS :10500:2012 (Reaffirmed 2018)		Specification, standard (method) or technique used
				Requirement (Acceptable) Limit)	Permissible Limit in the Absence of Alternate	
1	Colour	CU	<1.0	5max.	15max.	IS: 3025(P- 04)
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	IS: 3025(P- 05)
3	Turbidity	NTU	<0.2	1.0max.	5.0max.	IS: 3025(P- 10)
4	pH value @ 25 Deg. C	-	7.79	6.5-8.5	No Relaxation	IS: 3025(P- 11)
5	Total Dissolved Solids (TDS)	mg/L	1120	500max.	2000max.	IS: 3025(P- 16)
6	Total Hardness as CaCO ₃	mg/L	509	200max.	600max.	IS: 3025(P- 21)
7	Total Alkalinity	mg/L	190	200max.	600max.	IS: 3025(P- 23)
8	Chloride as Cl	mg/L	341	250max.	1000max.	IS: 3025(P- 32)
9	Iron as Fe	mg/L	BDL <0.075	0.3max.	No Relaxation	IS: 3025(P- 53)
10	Fluoride as F	mg/L	1.0	1.0max.	1.5max.	IS: 3025(P- 60)
11	Calcium as Ca	mg/L	36	75max.	200max.	IS: 3025(P- 40)
12	Magnesium as Mg	mg/L	102	30max.	100max.	IS: 3025(P- 46)
13	Sulphate as SO ₄	mg/L	149	200max.	400max.	IS: 3025(P- 24)

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report

---End of report---

Reviewed by:

(Authorised Signatory)
Mr. R. Chauhan
(General Manager - Q & T.)



ECOTECH SERVICES INC... (Analytical Laboratory Division)

ISO : 9001 : 2015. ISO : 14001 : 2015 | OHSMS - ISO : 45001 : 2018 Certified.
Members of Association of Indian Laboratories (AOIL) & IAM SME of India.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road,
Ballabgarh - 121004, Faridabad (Haryana)
Phone No.: +91-129-4630926, M.: 9650160159, 9911378912

E-mail : ecotbd@yahoo.com, info@ecotechservices.in

Website : www.ecotechservices.in

MSME No. : UDYAM-HR-03-0021507

TEST REPORT

Test Report Issued To:-	Test Report Number	0013276
M/s Liquiclear Technologies Private Ltd. 64/2A, New Industrial Area NIT- Faridabad -121001(Haryana)	Date of Report	04/09/2023
	Work Order No.	ESI/23-24/0478
	Period of testing	31/08/2023 to 04/09/2023
	Type of Sample	Raw Water Sample
	Date of Receiving	31/08/2023
	Method of Sampling	-
	Sample Received By.	Mr. S. Choudhary
Description of Sample.	One "Raw Water" sample was received by us on 31/08/2023.	
Sample Code/ Location.	Raw Water.	

Test Results.

S.No.	Test Parameters	Unit	Test Results	Limits as per IS:10500:2012 (Requirement Acceptable Limits)	Limits as per IS:10500:2012 (Permissible limit in the absence of alternative sources)	Test Methods
01	Nitrate (as NO ₃)	mg / L	4.6	45max.	No Relaxation	IS:3025(P-34)
02	Boron as B	mg / L	<0.01	0.5max.	1.0max.	IS:3025(P-57)
03	Barium as Ba	mg / L	Not Detected	0.7max.	No Relaxation	APHA 22 edit.
04	Phenolic compounds as C ₆ H ₅ OH.	mg / L	Not Detected	0.001max.	0.002max.	APHA 22 edit.
05	Manganese as Mn	mg / L	<0.01	0.1max.	0.3max.	APHA 22 edit.
06	Copper as Cu	mg / L	Not Detected	0.05max.	1.5max.	IS:3025(P-42)
07	Zinc as Zn	mg / L	2.0	5.0max.	15max.	IS:3025(P-49)
08	Selenium as Se	mg / L	Not Detected	0.01max.	No Relaxation	IS:3025(P-56)
09	Cadmium as cd	mg / L	Not Detected	0.003max	No relaxation	IS:3025(P-41)
10	Total Chromium as Cr	mg / L	<0.05	0.05max	No relaxation	IS:3025(P-52)
11	Aluminum as Al.	mg / L	Not Detected	0.03max	0.2max	IS:3025(P-55)
12	Mercury as Hg	mg / L	Not Detected	0.001max	No relaxation	IS:3025(P-48)
13	Sulphide as H ₂ S	mg / L	Not Detected	0.05max	No relaxation	IS:3025(P-29)
14	Cyanide as CN	mg / L	Not Detected	0.05max	No relaxation	IS:3025(P-27)
15	Lead as Pb	mg / L	Not Detected	0.01max	No relaxation	IS:3025(P-47)
16	Total Arsenic as As	mg / L	Not Detected	0.01max	0.05max.	IS:3025(P-37)
17	Nickel as Ni	mg / L	Not Detected	0.02max	No relaxation	IS:3025(P-54)
18	Total Coliform Bacteria/100ml	MPN/ 100ml	8.0	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS:1622
19	E.Coli /100ml	MPN/ 100ml	Not Detected	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS:1622

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This report is not valid for any publicity/ legal purpose.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report.

-----End of Report-----



(Auth. Signatory)





ECOTECH SERVICES INC... (Analytical Laboratory Division)

ISO/IEC - 17025 : 2017 Accredited Testing Laboratory
by NABL Vide Certificate Number TC - 5951.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road,
Ballabgarh - 121004, Faridabad (Haryana)
Phone No.: +91-129-4630926, M.: 9650160159, 9911378912
E-mail : ecotbd@yahoo.com, info@ecotechservices.in
Website : www.ecotechservices.in
MSME No. : UDYAM-HR-03-0021507



NABL
Certificate No TC-5951
Format No. ESI/NABL/TR/35

TEST REPORT

Test Report Issued To:- M/s Liquiclear Technologies Private Ltd. 64/2A, New Industrial Area NIT- Faridabad -121001(Haryana)	ULR Number	TC-5951-230000008150
	Date of Report	04/09/2023
	Work Order No.	ESI/23-24/0478
	Period of testing	31/08/2023 to 04/09/2023
	Type of Sample	Drinking Water Sample
	Date of Receiving	31/08/2023
	Method of Sampling	-
	Sample Received By.	Mr. S. Choudhary
Description of Sample.	One "Drinking Water" sample was received by us on 31/08/2023.	
Sample Code/ Location.	"Electronic Water Purifier – LDI-1000".	

Test Results.

S. No.	Parameter	Unit	Test Results	Limits as per IS :10500:2012 (Reaffirmed 2018)		Specification, standard (method) or technique used
				Requirement (Acceptable) Limit)	Permissible Limit in the Absence of Alternate	
1	Colour	CU	<1.0	5max.	15max.	IS: 3025(P- 04)
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	IS: 3025(P- 05)
3	Turbidity	NTU	<0.2	1.0max.	5.0max.	IS: 3025(P- 10)
4	pH value @ 25 Deg. C	-	6.87	6.5-8.5	No Relaxation	IS: 3025(P- 11)
5	Total Dissolved Solids (TDS)	mg/L	223	500max.	2000max.	IS: 3025(P- 16)
6	Total Hardness as CaCO3	mg/L	77	200max.	600max.	IS: 3025(P- 21)
7	Total Alkalinity	mg/L	95	200max.	600max.	IS: 3025(P- 23)
8	Chloride as Cl	mg/L	71	250max.	1000max.	IS: 3025(P- 32)
9	Iron as Fe	mg/L	BDL<0.075	0.3max.	No Relaxation	IS: 3025(P- 53)
10	Fluoride as F	mg/L	BDL<0.05	1.0max.	1.5max.	IS: 3025(P- 60)
11	Calcium as Ca	mg/L	16	75max.	200max.	IS: 3025(P- 40)
12	Magnesium as Mg	mg/L	8.8	30max.	100max.	IS: 3025(P- 46)
13	Sulphate as SO4	mg/L	59	200max.	400max.	IS: 3025(P- 24)

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report

----End of report----

Reviewed by:

(Authorised Signatory)
Mr. R. Chauhan
(General Manager - Q & T.)



ECOTECH SERVICES INC...

(Analytical Laboratory Division)

ISO : 9001 : 2015. ISO : 14001 : 2015 | OHSMS - ISO : 45001 : 2018 Certified.
Members of Association of Indian Laboratories (AOIL) & IAM SME of India.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road,
Ballabgarh -121004, Faridabad (Haryana)
Phone No.: +91-129-4630926, M.: 9650160159, 9911378912

E-mail : ecotbd@yahoo.com, info@ecotechservices.in

Website : www.ecotechservices.in

MSME No. : UDYAM-HR-03-0021507

TEST REPORT

Test Report Issued To:-	Test Report Number	0013273
M/s Liquiclear Technologies Private Ltd.	Date of Report	04/09/2023
64/2A, New Industrial Area	Work Order No.	ESI/23-24/0478
NIT- Faridabad -121001(Haryana)	Period of testing	31/08/2023 to 04/09/2023
	Type of Sample	Drinking Water Sample
	Date of Receiving	31/08/2023
	Method of Sampling	-
	Sample Received By.	Mr. S. Choudhary
Description of Sample.	One "Drinking Water" sample was received by us on 31/08/2023.	
Sample Code/ Location.	"Electronic Water Purifier – LDI-1000"	

Test Results.

S.No.	Test Parameters	Unit	Test Results	Limits as per IS:10500:2012 (Requirement Acceptable Limits)	Limits as per IS:10500:2012 (Permissible limit in the absence of alternative sources)	Test Methods
01	Nitrate (as NO ₃)	mg / L	<0.01	45max.	No Relaxation	IS:3025(P-34)
02	Boron as B	mg / L	<0.01	0.5max.	1.0max.	IS:3025(P-57)
03	Barium as Ba	mg / L	Not Detected	0.7max.	No Relaxation	APHA 22 edit.
04	Phenolic compounds as C ₆ H ₅ OH.	mg / L	Not Detected	0.001max.	0.002max.	APHA 22 edit.
05	Manganese as Mn	mg / L	<0.01	0.1max.	0.3max.	APHA 22 edit.
06	Copper as Cu	mg / L	Not Detected	0.05max.	1.5max.	IS:3025(P-42)
07	Zinc as Zn	mg / L	0.13	5.0max.	15max.	IS:3025(P-49)
08	Selenium as Se	mg / L	Not Detected	0.01max.	No Relaxation	IS:3025(P-56)
09	Cadmium as cd	mg / L	Not Detected	0.003max	No relaxation	IS:3025(P-41)
10	Total Chromium as Cr	mg / L	<0.05	0.05max	No relaxation	IS:3025(P-52)
11	Aluminum as Al.	mg / L	Not Detected	0.03max	0.2max	IS:3025(P-55)
12	Mercury as Hg	mg / L	Not Detected	0.001max	No relaxation	IS:3025(P-48)
13	Sulphide as H ₂ S	mg / L	Not Detected	0.05max	No relaxation	IS:3025(P-29)
14	Cyanide as CN	mg / L	Not Detected	0.05max	No relaxation	IS:3025(P-27)
15	Lead as Pb	mg / L	Not Detected	0.01max	No relaxation	IS:3025(P-47)
16	Total Arsenic as As	mg / L	Not Detected	0.01max	0.05max.	IS:3025(P-37)
17	Nickel as Ni	mg / L	Not Detected	0.02max	No relaxation	IS:3025(P-54)
18	Total Coliform Bacteria/100ml	MPN/ 100ml	Not Detected	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS:1622
19	E.Coli /100ml	MPN/ 100ml	Not Detected	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS:1622

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This report is not valid for any publicity/ legal purpose.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report.

-----End of Report-----

[Signature]

[Signature]
(Auth. Signatory)





ECOTECH SERVICES INC... (Analytical Laboratory Division)

ISO/IEC - 17025 : 2017 Accredited Testing Laboratory
by NABL Vide Certificate Number TC - 5951.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road,
Ballabgarh -121004, Faridabad (Haryana)
Phone No.:+91-129-4630926, M.: 9650160159, 9911378912
E-mail : ecotbd@yahoo.com, info@ecotechservices.in
Website : www.ecotechservices.in
MSME No. : UDYAM-HR-03-0021507



NABL
Certificate No TC-5951
Format No: ESI/NABL/TR/35

TEST REPORT

Test Report Issued To:-	ULR Number	TC-5951-230000008140
M/s Liquiclear Technologies Private Ltd.	Date of Report	04/09/2023
64/2A, New Industrial Area	Work Order No.	ESI/23-24/0478
NIT- Faridabad -121001(Haryana)	Period of testing	31/08/2023 to 04/09/2023
	Type of Sample	Drinking Water Sample
	Date of Receiving	31/08/2023
	Method of Sampling	-
	Sample Received By.	Mr. S. Choudhary
Description of Sample.	One "Drinking Water" sample was received by us on 31/08/2023.	
Sample Code/ Location.	"Electronic Water Purifier – LDI-5000"	

Test Results.

S. No.	Parameter	Unit	Test Results	Limits as per IS :10500:2012 (Reaffirmed 2018)		Specification, standard (method) or technique used
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate	
1	Colour	CU	<1.0	5max.	15max.	IS: 3025(P- 04)
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	IS: 3025(P- 05)
3	Turbidity	NTU	<0.2	1.0max.	5.0max.	IS: 3025(P- 10)
4	pH value @ 25 Deg. C	-	6.80	6.5-8.5	No Relaxation	IS: 3025(P- 11)
5	Total Dissolved Solids (TDS)	mg/L	243	500max.	2000max.	IS: 3025(P- 16)
6	Total Hardness as CaCO ₃	mg/L	80	200max.	600max.	IS: 3025(P- 21)
7	Total Alkalinity	mg/L	133	200max.	600max.	IS: 3025(P- 23)
8	Chloride as Cl	mg/L	59	250max.	1000max.	IS: 3025(P- 32)
9	Iron as Fe	mg/L	BDL<0.075	0.3max.	No Relaxation	IS: 3025(P- 53)
10	Fluoride as F	mg/L	BDL<0.05	1.0max.	1.5max.	IS: 3025(P- 60)
11	Calcium as Ca	mg/L	17.6	75max.	200max.	IS: 3025(P- 40)
12	Magnesium as Mg	mg/L	9.2	30max.	100max.	IS: 3025(P- 46)
13	Sulphate as SO ₄	mg/L	82	200max.	400max.	IS: 3025(P- 24)

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report

----End of report----

Reviewed by:

(Authorised Signatory)
Mr. R. Chauhan
(General Manager - Q & T.)



ECOTECH SERVICES INC...

(Analytical Laboratory Division)

ISO : 9001 : 2015. ISO : 14001 : 2015 | OHSMS - ISO : 45001 : 2018 Certified.
Members of Association of Indian Laboratories (AOIL) & IAM SME of India.

Plot No. 99, Gali No. 04, Navlu Colony, Railway Station Road,
Ballabgarh - 121004, Faridabad (Haryana)
Phone No.: +91-129-4630926, M.: 9650160159, 9911378912

E-mail : ecotbd@yahoo.com, info@ecotechservices.in

Website : www.ecotechservices.in

MSME No. : UDYAM-HR-03-0021507

TEST REPORT

Test Report Issued To:-	Test Report Number	0013274
M/s Liquiclear Technologies Private Ltd. 64/2A, New Industrial Area NIT- Faridabad -121001(Haryana)	Date of Report	04/09/2023
	Work Order No.	ESI/23-24/0478
	Period of testing	31/08/2023 to 04/09/2023
	Type of Sample	Drinking Water Sample
	Date of Receiving	31/08/2023
	Method of Sampling	-
	Sample Received By.	Mr. S. Choudhary
Description of Sample.	One "Drinking Water" sample was received by us on 31/08/2023.	
Sample Code/ Location.	"Electronic Water Purifier – LDI-5000"	

Test Results.

S.No.	Test Parameters	Unit	Test Results	Limits as per IS:10500:2012 (Requirement Acceptable Limits)	Limits as per IS:10500:2012 (Permissible limit in the absence of alternative sources)	Test Methods
01	Nitrate (as NO ₃)	mg / L	<0.01	45max.	No Relaxation	IS:3025(P-34)
02	Boron as B	mg / L	<0.01	0.5max.	1.0max.	IS:3025(P-57)
03	Barium as Ba	mg / L	Not Detected	0.7max.	No Relaxation	APHA 22 edit.
04	Phenolic compounds as C ₆ H ₅ OH.	mg / L	Not Detected	0.001max.	0.002max.	APHA 22 edit.
05	Manganese as Mn	mg / L	<0.01	0.1max.	0.3max.	APHA 22 edit.
06	Copper as Cu	mg / L	Not Detected	0.05max.	1.5max.	IS:3025(P-42)
07	Zinc as Zn	mg / L	0.24	5.0max.	15max.	IS:3025(P-49)
08	Selenium as Se	mg / L	Not Detected	0.01max.	No Relaxation	IS:3025(P-56)
09	Cadmium as cd	mg / L	Not Detected	0.003max	No relaxation	IS:3025(P-41)
10	Total Chromium as Cr	mg / L	<0.05	0.05max	No relaxation	IS:3025(P-52)
11	Aluminum as Al.	mg / L	Not Detected	0.03max	0.2max	IS:3025(P-55)
12	Mercury as Hg	mg / L	Not Detected	0.001max	No relaxation	IS:3025(P-48)
13	Sulphide as H ₂ S	mg / L	Not Detected	0.05max	No relaxation	IS:3025(P-29)
14	Cyanide as CN	mg / L	Not Detected	0.05max	No relaxation	IS:3025(P-27)
15	Lead as Pb	mg / L	Not Detected	0.01max	No relaxation	IS:3025(P-47)
16	Total Arsenic as As	mg / L	Not Detected	0.01max	0.05max.	IS:3025(P-37)
17	Nickel as Ni	mg / L	Not Detected	0.02max	No relaxation	IS:3025(P-54)
18	Total Coliform Bacteria/100ml	MPN/ 100ml	Not Detected	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS:1622
19	E.Coli /100ml	MPN/ 100ml	Not Detected	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	IS:1622

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This report is not valid for any publicity/ legal purpose.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report.

-----End of Report-----

[Signature]



(Auth. Signatory)

