

CA-D-317A Oil Carryover Laboratory Results

Laboratory report reference: LAB-AC317-2026-06 | Sampling point: downstream of AF-317A

1. Summary and acceptance basis

The local oil-carryover limit is 0.010 mg/m3. Laboratory QA disposition controls whether a result is valid for reconciliation. A numerical exceedance from a contaminated or invalid sample is retained as conflict evidence but is not used as the accepted current result.

Sample	Date	Reported result mg/m3	QA disposition	Accepted for current reconciliation	Reason
OC-317-2401	2024-04-18	0.012	SUPERSEDED	No	Historic pre-retrofit sample
OC-317-2601	2026-06-20	0.014	INVALID	No	Broken bottle seal; field blank elevated
OC-317-2602	2026-06-20	0.006	ACCEPTED	Yes	Valid duplicate sample
OC-317-2603	2026-06-21	0.007	ACCEPTED	Yes	Confirmatory sample

Accepted current oil carryover: 0.006 mg/m3 primary result, corroborated by 0.007 mg/m3 confirmatory result. Both are below the 0.010 mg/m3 local limit.

2. Chain of custody and sample integrity

Sample	Bottle ID	Seal received	Field blank mg/m3	Sample point	Collection time	Integrity note
OC-317-2601	B-260620-A	Broken	0.006	AF-317A outlet	2026-06-20 10:15	Invalidated by laboratory QA
OC-317-2602	B-260620-B	Intact	0.001	AF-317A outlet	2026-06-20 10:20	Accepted duplicate
OC-317-2603	B-260621-C	Intact	0.001	AF-317A outlet	2026-06-21 09:45	Accepted confirmation

The control-panel alarm export imported 0.014 mg/m3 from OC-317-2601 before the QA invalidation was posted. The alarm value is therefore not a valid current oil-carryover result.

3. Analytical method and uncertainty

Item	Detail
Method	ISO 8573-5 gravimetric aerosol collection, laboratory method LM-AIR-05
Reporting limit	0.002 mg/m3
Expanded uncertainty	±0.0015 mg/m3 at k=2
Blank correction	Applied to accepted samples only
Instrument calibration	Balance BAL-044, certificate BC-260515, valid through 2027-05-15

4. Laboratory bench results

Sample	Gross mass ug	Blank mass ug	Net mass ug	Air volume m3	Calculated mg/m3	Reported status
OC-317-2601	47.2	18.1	29.1	2.08	0.0140	FAIL - later invalidated
OC-317-2602	16.5	2.1	14.4	2.40	0.0060	ACCEPTED
OC-317-2603	18.7	2.0	16.7	2.39	0.0070	ACCEPTED

QA authorization: Laboratory supervisor J. Mercer | Authorization date: 2026-06-22

This report records analytical evidence only. It does not assign maintenance work, schedule activity, or recommend component replacement.