

CA-D-317A Relief Valve Certificate Package

Current certificates, installed-serial reconciliation, and superseded certificate history

1. Installed assignment summary

Valve tag	Installed serial	Protected equipment	Protected MAWP psig	Certified set pressure psig	Certificate date	Status
PSV-317A	RV-A-2117	CA-C-317A compressor discharge	150	125	2026-05-12	CURRENT
PSV-317B	RV-B-1182	CA-R-317A dryer receiver	125	110	2025-11-03	CURRENT

PSV-317B certificate text identifies protected vessel CA-R-317B. Field serial RV-B-1182 and line trace to CA-R-317A establish that CA-R-317B is a certificate transcription error.

2. Certificate RV-A-2117 - PSV-317A

Field	Certified value
Certificate number	VC-260512-017
Valve tag	PSV-317A
Serial number	RV-A-2117
Protected equipment	CA-C-317A compressor discharge
Set pressure	125 psig
Bench pop test	125.4 psig
Reseat pressure	118.2 psig
Protected-system MAWP	150 psig
Test date	2026-05-12
Next due date	2027-05-12
Technician	M. Elwood
Certificate status	ACCEPTED

Bench result is within the laboratory tolerance for the certified set pressure. The installed serial agrees with field survey record NFS-019.

3. Certificate RV-B-1182 - PSV-317B

Field	Certified value
Certificate number	VC-251103-042
Valve tag	PSV-317B
Serial number	RV-B-1182
Protected equipment shown on certificate	CA-R-317B
Field-traced protected equipment	CA-R-317A dryer receiver
Set pressure	110 psig
Bench pop test	110.3 psig
Reseat pressure	103.8 psig
Protected-system MAWP	125 psig
Test date	2025-11-03
Next due date	2026-11-03
Certificate status	ACCEPTED WITH TAG CORRECTION

The installed serial and field assignment control equipment mapping. The certificate vessel suffix does not match the field-traced receiver tag and is retained as a documentation discrepancy.

4. Superseded certificate history

Certificate	Valve tag	Serial	Set pressure psig	Date	Status	Reason not controlling
VC-231002-011	PSV-317B	RV-B-1181	115	2023-10-02	SUPERSEDED	Valve removed during 2025 overhaul
VC-250516-009	PSV-317A	RV-A-2117	125	2025-05-16	SUPERSEDED	Replaced by 2026 annual certificate

Asset register AR-015 and AR-016 still carry serial RV-B-1181 and 115 psig. Those values are superseded by the current installed serial and accepted certificate.