

RC-28 Existing Conditions and Utility Plan

1. Existing Conditions Overview

The site is a constrained urban street segment with adjacent residences, a shallow watercourse, and active utilities near the proposed culvert excavation. Utility information is source data for constructability review only.

Record ID	Station	Feature	Elevation or Offset	Note
EC-001	12+040 to 12+128	Roadway width	7.30 m curb-to-curb	Two lane local road.
EC-002	12+058 to 12+078	Existing culvert	1800 mm CMP	Existing culvert to be removed.
EC-003	12+058	Existing upstream invert	99.74 m	Surveyed at west inlet.
EC-004	12+078	Existing downstream invert	99.68 m	Surveyed at east outlet.
EC-005	12+070	Stream bed at crossing	99.46 m	Approximate observed bed elevation.
EC-006	12+064 to 12+082	Overhead clearance	6.4 m	Crane picks require staging check.

2. Utility Plan Records

Utility ID	Station	Utility	Plan Position	Elevation / Depth	Protection Requirement	Comment
U-001	12+064	150 mm gas main	1.8 m LT of centerline	top elevation 101.02 m	Minimum 0.60 m vertical clearance	Utility owner requires hand exposure within 1.0 m of crossing.
U-002	12+071	Telecom duct bank	0.9 m RT of centerline	top elevation 100.68 m	Minimum 0.45 m vertical clearance	Crosses proposed excavation zone.
U-003	12+087	50 mm water service	2.1 m RT of centerline	depth field blank	Minimum 0.45 m vertical clearance	Depth not shown in utility plan.
U-004	12+056	Sanitary lateral	3.4 m LT of centerline	invert 99.92 m	Maintain service during works	Private lateral crosses near west excavation limit.
U-005	12+092	Street-light conduit	north sidewalk	cover 0.32 m	Protect in place	Near temporary pedestrian route.
U-006	12+071	Telecom duct bank duplicate export	0.9 m RT of centerline	top elevation 100.68 m	Minimum 0.45 m vertical clearance	Duplicate of U-002, export row retained for audit.

3. Utility Clearance Notes

Clearance ID	Related Utility	Supplied Clearance Value	Reference	Status Note
UC-001	U-001 gas main	0.64 m vertical clearance	Utility plan against proposed culvert crown	Above 0.60 m minimum.
UC-002	U-002 telecom duct bank	0.32 m vertical clearance	Utility plan against proposed culvert crown	Below 0.45 m minimum and should be treated as a utility protection conflict.
UC-003	U-003 water service	not supplied	Depth field blank	Clearance cannot be verified.
UC-004	U-005 street-light conduit	0.32 m cover	Existing conditions plan	Shallow cover beside pedestrian route.

4. Plan Use Limitation

Utility records shall be used as supplied source data. The plan does not approve excavation methods, utility protection measures, or temporary support. Missing depths shall remain open constraints.