

## 4 Ways breeching inlet



- Certificate: BSI / Kitemark / LPCB Approved
- Standard: BS 5041-3
- Inlet: 4 x BS336
- Outlet: DN150 Flange as BS EN 1092-2
- Working pressure: 290PSI (2.0MPa)
- Material: Body, ductile iron  
Drain valve, DN25 gate valve as BS5154  
Inlet, copper alloy as BS1400
- Coating: AWWA C550 Fusion bonded epoxy coating



**Head Office:** Office No.21 Ground floor North  
Star Plaza Rehmanabad Stop  
Murree Road Rawalpindi.  
Ph: 051-4427778, 051-4418967  
Fax: 051-4427778  
Cell: 0332-5284828

**Lahore Office:** Office No. 302 Rehman Center Opp  
Shama Metro Bus Stop Ferozpur Road  
Lahore.  
Ph: 042-37429761, 042-37429773  
Fax: 042-7523905  
Cell: 03219700008

**Karachi Office:** 167/ E-Market block 6, P.E.C.H.S  
Shahrah-e-Faisal Karachi.  
Ph: 021-34530373, 021-34254306  
Fax: 021-34530573  
Cell: 0315-4233313

**Email:** [info@universalfireprotection.com.pk](mailto:info@universalfireprotection.com.pk)  
**Website:** [www.universalfireprotection.com.pk](http://www.universalfireprotection.com.pk)