

# Water Sampling Report Summary



**C 2890143 Bison Assist: Rawdah School BD9 4JJ**

Laboratory Number			25633357	25633358
Customer Sample Ref.			Rawdah School BD9 4JJ DAA WC	Rawdah School BD9 4JJ DAA WC
Sample Matrix			Drinking Water	Drinking Water
Sample Date			16/09/2025 10:00:00	16/09/2025 10:00:00
Sample Time			10:00	10:00
Point Code			Private Limits	Private Limits
Analyte	Method	Units		
Pseudomonas aeruginosa Pres	W11	cfu/100ml	N/S	0
Pseudomonas aeruginosa, conf.	W11	cfu/100ml	N/S	0
Legionella pneumophila Sg 1	W5	cfu in vol	ND	N/S
Legionella pneumophila Sg 2-15	W5	cfu in vol	ND	N/S
Legionella Sp(non-pneumophila)	W5	cfu in vol	ND	N/S
Legionella, Total	W5	cfu in vol	ND	N/S
Volume Analysed for Legionella	W5	ml	500	N/S
Legionella Limit Of Detection	W5	cfu/litre	40	N/S

*The results have been analysed by a UKAS accredited laboratory, in line with their methods and as per ACOP L8.*

*To discuss these, contact us at [support@bisonassist.co.uk](mailto:support@bisonassist.co.uk).*

*0 or ND=Not Detected*

*N/S=No Sample*