Fire Safety & Emergency Evacuation SOP

Department: Compliance & Sustainability

Fire Safety Equipment:

- Fire extinguishers: Check pressure gauge monthly, refill annually.
- Smoke detectors: Test monthly, replace batteries yearly.
- Emergency lighting: Check monthly.
- Fire alarm system: Test weekly.

Evacuation Procedure:

1. On hearing the alarm, stop work immediately.
2. Walk (do not run) to the nearest emergency exit.
3. Assemble at the designated assembly point.
4. Supervisors take headcount and report to the Fire Safety Officer.
5. Do not re-enter the building until cleared.

Fire Drill Frequency: Mandatory drill every 6 months (as per Bangladesh Fire Service rules).

Common Audit Findings to Avoid:

- Blocked emergency exits.
- Expired fire extinguishers.
- Missing evacuation route maps.