



Notification Number: 2017/91/F

## Order amending provisions of the regulations concerning fire safety and public order in establishments accessible to the public

Date received : 02/03/2017

End of Standstill : 06/06/2017

### Message

Message 002

Communication from the Commission - TRIS/(2017) 00590

Directive (EU) 2015/1535

Translation of the message 001

Notification: 2017/0091/F

No abre el plazo - Nezaahajuje odklady - Fristerne indledes ikke - Kein Fristbeginn - Viivituste perioodi ei avata - Καμμία έναρξη προθεσμίας - Does not open the delays - N'ouvre pas de délais - Non fa decorrere la mora - Neietekmē atlikšanu - Atidėjimai nepradedami - Nem nyitja meg a késések - Ma' jiftaħ il-perijodi ta' dawmien - Geen termijnbegin - Nie otwiera opóźnień - Não inicia o prazo - Neotvorí oneskorenia - Ne uvaja zamud - Määräaika ei ala tästä - Inleder ingen frist - He ce предвижда период на прекъсване - Nu deschide perioadele de stagnare - Nu deschide perioadele de stagnare.

(MSG: 201700590.EN)

#### 1. Structured Information Line

MSG 002 IND 2017 0091 F EN 02-03-2017 F NOTIF

#### 2. Member State

F

#### 3. Department Responsible

Direction générale des entreprises – SQUALPI – Bât. Sieyès -Teledoc 151 – 61, Bd Vincent Auriol - 75703 PARIS Cedex 13

d9834.france@finances.gouv.fr

tél : 01 44 97 24 55

#### 3. Originating Department

Ministère de l'intérieur

Direction Générale de la Sécurité Civile et de la Gestion des Crises

Place Beauvau



75800 PARIS cedex 08.  
herve.tephany@interieur.gouv.fr  
01 72 71 66 88

#### **4. Notification Number**

2017/0091/F - B00

#### **5. Title**

Order amending provisions of the regulations concerning fire safety and public order in establishments accessible to the public

#### **6. Products Concerned**

This order concerns the electrical power of lifts intended for the evacuation of people with disabilities.

#### **7. Notification Under Another Act**

-

#### **8. Main Content**

In a move to simplify regulations, the threshold limits for electrical power installed in lift shafts are being made consistent between establishments accessible to the public (ERP) and high-rise buildings (IGH). A correction is also being made to the reference to an Article AM (Interior fittings, decoration and furniture).

#### **9. Brief Statement of Grounds**

According to § 1-d of the current Article AS4, the total electrical power installed in a shaft is limited to 15 kVA. In numerous cases, this evacuation capacity for people with disabilities will be insufficient. In other articles covering electrical power installed in a shaft, the power limit is set at 40 kVA, or even 100 kVA (CO 53 of the ERP regulations and GH 30 of the IGH regulations).

Furthermore, the reference to the AM articles should be updated to take into account the revision of the latter.

#### **10. Reference Documents - Basic Texts**

Reference(s) to basic text(s): - Order of 25 June 1980 approving regulations concerning fire safety and public order in establishments accessible to the public.

#### **11. Invocation of the Emergency Procedure**

No

#### **12. Grounds for the Emergency**

-

#### **13. Confidentiality**

No



**14. Fiscal measures**

No

**15. Impact assessment**

-

**16. TBT and SPS aspects**

TBT aspect

Yes

SPS aspect

No - the draft is neither a sanitary nor phytosanitary measure.

\*\*\*\*\*

European Commission

Contact point Directive (EU) 2015/1535

Fax: +32 229 98043

email: [grow-dir83-189-central@ec.europa.eu](mailto:grow-dir83-189-central@ec.europa.eu)