



# Greece — Monthly Intelligence Report v4.2

Edition 006 — Deep-Dive Theme

Where the energy transition is outrunning the grid. edition · August 2026 · SSI v4.2  
(refreshed June 2026)

CONTENTS


|                                            |                                                                         |
|--------------------------------------------|-------------------------------------------------------------------------|
| <b>A</b> Executive Summary                 | <b>E</b> European Context Card                                          |
| <b>B</b> Cyber & Economic Exposure Monitor | <b>F</b> SSI Enhanced Neural Network                                    |
| <b>C</b> Data Refresh & Changelog          | <b>F.5</b> Anti-maladaptation Gate (Radar 2 · W1–W10) <span>v4.2</span> |
| <b>D</b> Deep-Dive: Monthly Theme          | <b>G</b> Looking Ahead                                                  |

SECTION A

## Executive Summary

### Radar 1 — v4.2: now 7-axis with the new Re composite

v4.0.2 Radar 1 had 6 axes (C/V/I/E/S/T). **v4.2 adds Re — the bounded resilience composite** capturing the new modifier family (R6c flood + R6d wildfire + R6e winter + R8 adapt + R9 compound + R10 just) in one normalised scalar (Re\_norm ∈ [0, 1] via  $\text{clip}((\text{Re\_raw} - 0.920) / (1.787 - 0.920), 0, 1)$ ). Two worked examples overlaid: **Attica Substation 2** (low-exposure reference, Re\_norm 0.000) · **Epirus Substation 5** (high-exposure reference, Re\_norm 1.000). The Re axis is colour-highlighted in cayenne to emphasise the v4.2 architectural addition.



The Re composite (★, cayenne-highlighted axis at upper-left) captures the v4.2 resilience modifier family in one bounded scalar — formula  $\text{Re\_raw} = (R6d \times R6e \times R8 \times R9 \times R10) + (R6c - 1.00)$ , bounds [0.920, 1.787]. Per Convention #6 §2.3.6 Path B refactor (11 Jun 2026), this country's exemplars are algorithmically selected (min/max Re\_norm) per the v4.2 methodology. The Substation in Focus radar canvas (Section A below) is rendered by shared intelligence-sections.js and now also displays the 7th Re axis (Convention #11 surface-pair coherence, V4.2-disc-24 closure 12 Jun 2026).

SUBSTATIONS SCORED

581

71 EHV · 410 HV · 100 distribution-tier

GRID LINES MAPPED

1,420

~12,400 km coverage

MC SIMULATIONS

42.9 M

10,000 per substation

PUBLIC DATA SOURCES

34

101 variables · zero proprietary

The SSI Index is the only operational framework that fuses substation-level engineering metrics with socio-economic consequence valuation in a single composite score — scoring 71/80 (89%) across 16 competitive dimensions, ahead of GMLC 1.1 (48/80), EPRI (40/80), and academic MCDA frameworks (41/80). Its engine processes 146,000+ source data points per run, executes 42.9 million Monte Carlo simulations through a 20×20 Gaussian copula correlation matrix, and performs 1.78 billion arithmetic operations — producing 244,701 output data points with full uncertainty quantification across 581 substations and 1,420 grid lines spanning ~12,400 km. v4.2 adds the Re composite (7th axis) and six resilience modifiers (R6c flood / R6d wildfire / R6e winter / R8 adapt / R9 compound / R10 just) on top of the v4.0.2 foundation.

Operated as a non-profit through a dedicated foundation, the SSI Index serves the public interest with zero dependency on proprietary data. All 101 variables are drawn from 34 verified public sources, making the methodology fully auditable and reproducible. Initially covering Greece's entire transmission and distribution grid, the Index is progressively being rolled out to all OECD countries — applying the same silo-breaking approach: fusing grid risk with societal exposure at asset-level resolution wherever open data permits.

Substation in Focus

North Aegean Substation 562

North Aegean, North Aegean · 0 kV

1.047

Extreme

0.153


97th

R\_FINAL

CLASSIFICATION

CI WIDTH

FLEET PERCENTILE



Re composite v4.2 7th axis

Re\_raw 1.3075 · Re\_norm 0.586

ELEVATED EXPOSURE

COMPONENTS

C

Continuity: 1.000 / 0.30 (333%)

I

Infrastructure: 1.000 / 0.25 (400%) ▲

S

Saturation: 1.000 / 0.20 (500%) ▲

V

Voltage: 1.000 / 0.10 (1000%) ▲

E

Economic: 0.754 / 0.10 (754%)

T

Transition: 0.544 / 0.05 (1089%)

MODIFIERS

R3

Consequence: 0.964 ↓ dampens

R4

Graph Criticality: 0.965 ↓ dampens

R6a

Restoration: 1.080 ↑ amplifies

R6b

Seismic: 1.150 ↑ amplifies

R7

Digital Readiness: 0.996 → neutral

This month's spotlight — automatically selected for August 2026 — is **North Aegean Substation 562** in North Aegean, North Aegean. With an R\_final of 1.047 (Extreme band, 97th fleet percentile), its risk profile is dominated by the T (Transition) component at 1089% of its weight ceiling, followed by V (Voltage) at 1000%. Modifiers collectively shift R\_base by 9.9%, reflecting the substation's specific geographic, socio-economic, and network context.

**Why this section exists:** Traditional grid risk frameworks treat cybersecurity and economic vulnerability as separate domains. The SSI's R7 (Digital Readiness) modifier and E (Economic) component allow us to cross these silos — revealing substations where low digital resilience intersects with high economic consequence. This is precisely the anticipatory intelligence that infrastructure digitalisation planning requires.

CYBER HIGH EXPOSURE

**248**

34.5% of fleet

BLIND SPOTS

**177**

High/Critical/Extreme + R7 < median

AVG R7 MODIFIER

**1.0082**

Range [0.99, 1.05]


HIGH-CONSEQUENCE SUBS

**140**

19.5% · R3 ≥ 1.08

## B.1 Cyber-Physical Risk Matrix

Each substation plotted by R7 digital readiness (x-axis) vs overall R\_median (y-axis). The upper-left quadrant — high risk, low digital readiness — identifies *blind spots* where grid stress is high but monitoring/response capacity is weakest.




● Low ● Medium ● High ● Critical

Dashed lines = fleet medians

The cyber-physical matrix identifies **177 blind-spot substations** — scoring High, Critical, or Extreme on overall risk while sitting below the fleet median for digital readiness ( $R7 < 1.0008$ ). These substations are the most vulnerable to a compound event: a grid disturbance at a location where digital monitoring, automated switching, and remote diagnostic capacity are weakest. The blind spots concentrate in **Thessaly (65)**, **Central Macedonia (34)**, **Eastern Macedonia and Thrace (25)**. Across the full fleet, 248 substations (34.5%) carry a HIGH cyber-exposure classification, while 131 (18.2%) are in the LOW tier.

## B.2 Economic Impact by Business Fabric

Substations segmented by economic consequence tier — derived from the R3 consequence multiplier and E component. Higher R3 indicates the substation serves a territory with greater socio-economic exposure to disruption.




The capital-intensive tier concentrates in **Eastern Macedonia and Thrace (30), Western Greece (17), Western Macedonia (17)** — regions where industrial corridors depend on uninterrupted power for continuous processes. A single hour of unplanned outage at these substations carries an estimated VoLL of €15–30/kWh, compared to €1–3/kWh in rural agricultural areas. The fleet-wide average energy poverty rate is 24.6%, but this masks sharp regional variation: Southern regions combine higher energy poverty with higher grid risk, creating a double vulnerability that the E component captures.

This cross-referencing of economic fabric with grid condition is unique to the SSI — no competing framework links VoLL exposure to substation-level risk scores.

### B.3 Province Digital Readiness Ranking

Provinces ranked by average R7 modifier — lower values indicate weaker digital infrastructure (DESI sub-dimensions). Cross-referenced with average R\_median to identify provinces combining digital exposure with high grid stress.



region-level analysis reveals a clear digital divide mirroring the broader DESI pattern. **EL527** has the lowest average R7 (0.0000), while **Attica** leads at 1.0392 — a spread of 1.0392 across the R7 range. **8 region regions** combine below-median digital readiness with above-median grid risk, making them priority targets for digitalisation investment. The R7 modifier is intentionally narrow to reflect the current limitations of open DESI data — as NIS2 compliance reporting matures, future editions will expand R7’s dynamic range and incorporate operational technology (OT) security indicators.

### B.4 Monthly Pulse

**Inaugural edition — Baseline Snapshot (August 2026).** This edition establishes the baseline for the Cyber & Economic Exposure Monitor. Key reference points: fleet average R7 = 1.0082, median = 1.0008; 248 substations classified HIGH cyber-exposure; 177 blind-spot substations (High/Critical/Extreme risk + below-median R7); 42 Critical-band substations with below-median digital readiness. Future editions will track deltas against this baseline.

## SECTION C

### Data Refresh & Changelog

The SSI v4.0.2 draws on — **verified public data sources** feeding — variables across — components and — modifiers. This section provides a live registry of all sources, their update frequencies, and the current state of the fleet. Transparency in

data vintage is central to the SSI's credibility.

TOTAL SOURCES



— variables

HOURLY — MONTHLY



High-frequency feeds

QUARTERLY / ANNUAL



Regular refresh cycle

STATIC / DERIVED



Standards + scenarios

Data Source Registry — August 2026

|            |                                     |           |                |         |
|------------|-------------------------------------|-----------|----------------|---------|
| OSM        | OSM Power Infrastructure            | WEEKLY    | Node/edge      | 3 vars  |
| HMEPATHS   | Hellenic Meteorological Service     | DAILY     | ~5 km          | 3 vars  |
| DEDDIE     | DEDDIE/HEDNO (Διανομή Ηλεκτρισμού)  | MONTHLY   | Prefecture     | 5 vars  |
| PDVSA      | Public Power Corporation Data       | MONTHLY   | Prefecture     | 2 vars  |
| RAE        | RAE (Ρυθμιστική Αρχή Ενέργειας)     | QUARTERLY | Prefecture     | 3 vars  |
| IPT0-EX    | IPTO Extended Topology              | QUARTERLY | Prefecture     | 3 vars  |
| HEPI       | HEPI (Hellenic Energy Policy Index) | ANNUAL    | National       | 3 vars  |
| EUROSTAT   | Eurostat Energy Statistics          | ANNUAL    | NUTS2          | 3 vars  |
| DESI       | DESI Digital Economy Index          | ANNUAL    | EU Regional    | 2 vars  |
| JRC        | JRC DSO Observatory                 | ANNUAL    | DSO-level      | 2 vars  |
| ETVA       | ETVA (Ελληνικό Ταμείο Αναπτύξεως)   | ANNUAL    | Prefecture     | 2 vars  |
| MINENV     | Ministry of Environment             | ANNUAL    | Prefecture     | 2 vars  |
| HMEPD      | Hellenic Forest Management          | ANNUAL    | Prefecture     | 1 var   |
| INFOSTAT   | Infrastructure Statistics           | ANNUAL    | Prefecture     | 1 var   |
| APIVITA    | Industry Association Data           | ANNUAL    | Prefecture     | 1 var   |
| COPERNICUS | Copernicus CDS / ERA5               | STATIC    | 0.25° (~25 km) | 4 vars  |
| IEEE-1     | IEEE C57.91 / IEC 60076             | STATIC    | Asset-level    | 16 vars |
| EAK2003    | EAK 2003 Seismic Code               | STATIC    | Prefecture     | 2 vars  |
| GFZ        | GFZ German Research Centre          | STATIC    | ~5 km          | 2 vars  |
| COPDEM     | Copernicus DEM / Landcover          | STATIC    | 30 m           | 2 vars  |
| DIMOVSKI   | Dimovski et al. (2025)              | STATIC    | Municipal      | 3 vars  |
| ISLAND-ISO | Island Isolation Factor             | STATIC    | Prefecture     | 1 var   |
| COG-GR     | COG Prefecture Registry             | STATIC    | Prefecture     | 1 var   |



|        |                                      |              |              |        |
|--------|--------------------------------------|--------------|--------------|--------|
| ADMIE  | ADMIE/IPTO (Ανεξάρτητο Διαχειριστή)  | REAL-TIME    | Nodal        | 8 vars |
| ELSTAT | ELSTAT (Ελληνική Στατιστική Αρχή)    | QUINQUENNIAL | Prefecture   | 8 vars |
| HENEX  | HEnEx (Ελληνική Ηλεκτρική Ανταλλαγή) | HOURLY       | National     | 3 vars |
| ENTSOE | ENTSO-E Transparency                 | HOURLY       | Control Area | 2 vars |
| NOA    | NOA (Εθνικό Αστεροσκοπείο)           | REAL-TIME    | Prefecture   | 4 vars |
| MF-0M  | Open-Meteo Historical Weather        | HOURLY       | ~1 km        | 3 vars |
| D-0M   | Open-Meteo / ERA5                    | HOURLY       | ~1 km        | 1 var  |

### C.1 Update Frequency Timeline

EXPECTED UPDATE WINDOWS

### C.2 Fleet Score Snapshot

FLEET SIZE

719

substations scored

MEDIAN R

0.515

P5=0.086 · P95=0.912

HIGH + CRITICAL + EXTREME

372

51.7% of fleet

HIGH CONFIDENCE

98%

707 subs · CI/R < 0.50

BAND DISTRIBUTION



No primary data sources have been updated since the v4.0.2 launch baseline. All **719 substation scores remain unchanged** this edition. The fleet median R of 0.515 (mean 0.497) reflects a distribution skewed toward the lower bands, with 21.1% in Low and 27.1% in Medium. The first material score changes are expected when the national regulator publishes the annual quality-of-supply indicators and when DER registries refresh. High-frequency sources (OSM, weather) update weekly but feed only infrastructure topology (R4) and thermal proxy (I5), which have minimal impact on fleet-level score distribution.

### C.3 Changelog — v3.4 → v4.0.2 → v4.2

v4.2 (June 2026) adds six resilience modifiers (R6c flood / R6d wildfire / R6e winter / R8 adapt / R9 compound / R10 just), the Re composite (7th axis, bounds [0.920, 1.787]), four new data sources ( IdroGEO PGRA, SIAB wildfire, ECMWF ERA5 Bourgouin, bulk smart meter), six new variables, and W1–W10 anti-maladaptation governance gate (5/1/1/3 4-tier mesh resolution per Convention #6 §5.6) on top of the v4.0.2 baseline.


|        |        |                                                                                                                                                                                     |      |
|--------|--------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| V42-1  | NEW    | R6c_flood — PGRA-style flood-vulnerability modifier (additive cliff +0.00..+0.30, P3=high/P2=medium/P1=low per national flood-hazard tier convention)                               | §5   |
| V42-2  | NEW    | R6d_wildfire — Canadian Fire Weather Index modifier (EFFIS FWI + NASA FIRMS + national fire-registry, multiplicative [1.00, 1.20])                                                  | §5   |
| V42-3  | NEW    | R6e_winter — Bourgouin winter-storm modifier (ECMWF ERA5 winter-precipitation signal, multiplicative [1.00, 1.02])                                                                  | §5   |
| V42-4  | NEW    | R8_adapt — Adaptive-capacity multiplier (smart-meter penetration + DSO investment + DESI index, multiplicative [0.95, 1.05])                                                        | §5   |
| V42-5  | NEW    | R9_compound — Compound-hazard STEP function (R6b/R6c/R6d/R6e elevated-count gates, multiplicative {1.00, 1.04, 1.08, 1.10})                                                         | §5   |
| V42-6  | NEW    | R10_just — Energy-justice modifier (EU-SILC or national-equivalent household material-deprivation gradient, multiplicative [1.00, 1.12])                                            | §5   |
| V42-7  | NEW    | Re composite — bounded resilience scalar $Re_{raw} = (R6d \times R6e \times R8 \times R9 \times R10) + (R6c - 1.00)$ ; $Re_{norm} = clip((Re_{raw} - 0.920)/(1.787 - 0.920), 0, 1)$ | §7   |
| V42-8  | NEW    | R7 SFDR PAI Infrastructure axis — added to ESG Radar ( $Re_{norm}$ proxy under Convention #7 Data-Layer Anchoring)                                                                  | §14  |
| V42-9  | NEW    | W1-W10 audit-state mesh — 5 Published / 1 Published-baseline ▲ / 1 Baseline-only / 3 Commercial (Convention #6 §5.6)                                                                | §4   |
| V42-10 | CHANGE | 95 → 101 variables (+6 from v4.2 modifier inputs); 30 → 34 data sources (+4 hazard / monitoring layers)                                                                             | data |
| V42-11 | CHANGE | Substation fleet: 581 substations (per OSM canonical extract + national TSO/DSO registry cross-validation)                                                                          | data |

SECTION D — MONTHLY DEEP-DIVE

# Monthly Deep-Dive Theme

**Deep-dive rotation:** Each edition features a substantive thematic analysis. The 12-month rotation: **Ed. 001** the monthly theme · **002** DER saturation hotspots · **003** Climate vulnerability under CMIP6 · **004** North-South economic impact disparity · **005** Voltage quality and industrial output · **006** Infrastructure age vs investment · **007** Stress-Resilience quadrant trends · **008** T-component forward projections · **009** Sub-national Grid Health Cards · **010** Academic validation and peer feedback · **011** European replication feasibility · **012** Year in review.

## D.1 Theme Context



15 EHv · 5 HV

100.0% of corridor

Fleet median: 0.515


WORST PROVINCE

Crete

Avg R: 1.055 · 20 substations

The Crete hosts **20 substations** across 1 region regions, making it the locus of this edition's deep-dive analysis. Its risk profile is concentrated in the upper bands: **0 substations (0.0%)** are classified High, with only **0** in the Low band. 100% of corridor substations score above the national fleet median of 0.515. The corridor median R of 1.055 reflects the local risk profile. The corridor concentrates the country's industrial heartland. The SSI flags continuity-of-supply deficits, infrastructure age mismatches with modern demand patterns, and grid modernization lag under national digitalisation timelines.

D.2 Corridor Map and Scoring




| SUBSTATION           | PROVINCE | R_FINAL | BAND    | C     | V     | I     | E     | S     | T     | RE<br>v4.2 | ALERT |
|----------------------|----------|---------|---------|-------|-------|-------|-------|-------|-------|------------|-------|
| Crete Substation 518 | Crete    | 1.060   | Extreme | 1.000 | 1.000 | 1.000 | 0.611 | 1.000 | 0.768 | I, S, V    |       |
| Crete Substation 541 | Crete    | 1.060   | Extreme | 0.875 | 1.000 | 1.000 | 0.611 | 1.000 | 0.768 | I, S, V    |       |
| Crete Substation 519 | Crete    | 1.058   | Extreme | 1.000 | 1.000 | 1.000 | 0.611 | 1.000 | 0.768 | I, S, V    |       |

| SUBSTATION                                                                              | PROVINCE | R_FINAL | BAND    | C     | V     | I     | E     | S     | T     | RE<br>v4.2 | ALERT |
|-----------------------------------------------------------------------------------------|----------|---------|---------|-------|-------|-------|-------|-------|-------|------------|-------|
| Crete Substation 537                                                                    | Crete    | 1.058   | Extreme | 1.000 | 1.000 | 1.000 | 0.611 | 1.000 | 0.768 | I, S, V    |       |
| Crete Substation 533                                                                    | Crete    | 1.058   | Extreme | 0.774 | 1.000 | 0.754 | 0.611 | 1.000 | 0.768 | S, V       |       |
| Crete Substation 525                                                                    | Crete    | 1.058   | Extreme | 0.922 | 1.000 | 0.754 | 0.611 | 1.000 | 0.768 | S, V       |       |
| Crete Substation 429                                                                    | Crete    | 1.058   | Extreme | 0.875 | 1.000 | 0.754 | 0.611 | 1.000 | 0.768 | S, V       |       |
| Crete Substation 528                                                                    | Crete    | 1.057   | Extreme | 0.805 | 1.000 | 0.754 | 0.611 | 1.000 | 0.768 | S, V       |       |
| Crete Substation 531                                                                    | Crete    | 1.056   | Extreme | 1.000 | 1.000 | 0.754 | 0.611 | 1.000 | 0.768 | S, V       |       |
| Crete Substation 529                                                                    | Crete    | 1.055   | Extreme | 1.000 | 1.000 | 1.000 | 0.611 | 1.000 | 0.768 | I, S, V    |       |
| ... 10 additional substations — <a href="#">explore full corridor in Digital Twin →</a> |          |         |         |       |       |       |       |       |       |            |       |

D.3 Component Analysis

COMPONENT AVERAGES — CRETE VS FLEET



MODIFIER AVERAGES — CRETE VS FLEET



The dominant risk driver across the Crete corridor is **T (Transition)**, averaging 0.768 against a fleet average of 0.314 — occupying 1536% of its weight ceiling (w = 0.05). The second contributor is **V (Voltage)** at 1.000 vs fleet 0.204 (1000% of ceiling). Among modifiers, the R3 consequence multiplier averages 0.992 (fleet: 0.807), reflecting the socio-economic

exposure of the corridor. The R6b seismic modifier averages 1.200, capturing the local seismic exposure — a dimension invisible to every competing framework.

## D.4 Province Breakdown

REGION RISK PROFILE — SORTED BY MEAN R

Longer bar = lower R = better resilience.

Crete

20 subs · avg R = 1.055 · H:0 E:20 M:0

The region regions-level breakdown reveals significant intra-regional variation. **Crete** leads with a mean R of 1.055 across 20 substations, while **Crete** scores 1.055 — a spread of 0.000 within a single corridor. The SSI's substation-level granularity reveals that the Crete is not uniformly stressed but contains distinct sub-corridors of concentrated risk — precisely the kind of spatial pattern that investment planning requires.

## D.5 Implications

**20 Crete substations** score  $R \geq 0.650$ , placing them in the upper quartile of national risk. For NEPN / national digital plan / RRP investment prioritisation, this analysis identifies the Crete sub-corridor as the highest-priority target — where DER deployment is accelerating against ageing infrastructure with above-average continuity deficits and significant socio-economic exposure. The SSI's silo-breaking approach reveals what no single-discipline framework can: that these substations matter not only because of their engineering condition, but because the communities they serve are disproportionately vulnerable to disruption. This is precisely the anticipatory grid planning capability that the SSI was built to provide.


SECTION E — RECURRING MODULE

## OECD Context Card

**How this works:** Each edition includes one OECD Context Card drawn from the §16 Peer Benchmarking framework. The card is selected to complement the month's deep-dive theme. This month: **SAIDI comparison** — because the Southern Coastal corridor analysis hinges on Greece's continuity performance relative to OECD peers. Future editions rotate through: VoLL comparison (Ed. 002), DER saturation vs Germany (003), CMIP6 climate hazard vs Nordic peers (004), etc. The underlying data updates annually with the CEER Benchmarking Report release.

## Unplanned SAIDI (min/customer/year) — Selected OECD Countries

Longer bar = lower SAIDI = better reliability. Values in min/customer/year.




Source: CEER 7th Benchmarking Report (2022); Bundesnetzagentur (2024); ARERA (2023). · See §16 Peer Benchmarking for full methodology and caveats. · Updated annually with CEER BR release. · OECD-wide expansion (USA, Japan, Canada, Australia) pending IEA/OECD reliability bulletin release.

**This month's key insight:** The Crete corridor deep-dive shows **20 substations** (of 20) with C-component above 70% of its weight ceiling — indicating continuity-of-supply performance consistent with rural territory classification. The corridor's average C of 0.949 is **2.6× the fleet average** of 0.360. The SSI reveals what aggregate national statistics conceal: that the country's mid-tier European position is not a uniform condition but a statistical average of urban-quality performance and rural-tier performance — and the corridor concentrates the worst of the latter.

## Regions Risk Ranking — All 13 Greek Regions

Where does this corridor sit within the national landscape? Regions sorted by mean R<sub>median</sub>, with band distribution and fleet comparison.

Longer bar = lower R = better resilience. Sorted worst → best.



|                                  |                                     |
|----------------------------------|-------------------------------------|
| #9 Epirus                        | 28 subs · avg R = 0.539 · H:19 C:1  |
| #10 Western Macedonia            | 17 subs · avg R = 0.537 · H:12 C:1  |
| #11 Eastern Macedonia and Thrace | 30 subs · avg R = 0.530 · H:25      |
| #12 Central Macedonia            | 81 subs · avg R = 0.524 · H:23 C:11 |
| #13 Central Greece               | 68 subs · avg R = 0.503 · H:20 C:4  |

The Crete ranks **#1 of 13 region regions** by mean R\_median, placing it among the upper tier of national risk. The three most stressed are Crete, North Aegean, Ionian Islands, while the three most resilient are Central Greece, Central Macedonia, Eastern Macedonia and Thrace. 13 of 13 score above the fleet average of 0.497. This ranking — possible only because the SSI scores every substation individually rather than relying on aggregate DSO or national statistics — reveals the true spatial distribution of grid stress. It is precisely this substation-level granularity that positions the SSI as a tool for investment prioritisation: not treating entire regions as monoliths, but identifying the specific corridors within each that demand attention.


## SECTION F — RECURRING MODULE

# SSI Enhanced Neural Network — Monthly Topic

**From grid intelligence to BESS valuation platform.** The SSI Index answers *"How healthy is this substation?"* The SSI Enhanced Neural Network (SSI-ENN) extends this into: *"What is a BESS worth at this substation — to the DNO and to the community?"* Each edition of this report explores one building block of the SSI-ENN's five-layer architecture, showing how the SSI Index data feeds directly into investment-grade grid analytics.

SSI-ENN value-articulation radar — 5-lens stakeholder taxonomy

The SSI-ENN's commercial-tier value articulation answers "what is a BESS worth at this substation — and to whom?" through five stakeholder lenses (architecture memo §5 Decision #12): **V<sub>Community</sub>** (welfare avoided outages, energy-poverty relief, employment) · **V<sub>Grid</sub>** (V\_DSO — avoided reinforcement, reliability, voltage, congestion, frequency, black-start, hosting capacity) · **V<sub>Owner</sub>** (NPV / IRR / payback per asset class) · **V<sub>Investor</sub>** (risk-adjusted equity return at the financing tier) · **V<sub>LP</sub>** (limited-partner cash-on-cash + DPI / TVPI portfolio metrics). The pentagon shape below is an editorial reference profile, not per-substation commercial data — per-substation evaluation requires the SSI-ENN engines (L2-21 SupplyChainDD · L4-05 Stakeholder Decomposition · L2-SYN Synergy). Foundation contact: [ssi\\_index@ikenga.eu](mailto:ssi_index@ikenga.eu).



Editorial reference shape —  $V_{Grid}$  dominates ( $V_{DSO}$  captures avoided reinforcement + reliability + voltage support + congestion relief + frequency + black-start + hosting capacity, the bulk of measurable BESS value at the substation locus per architecture memo §5).  $V_{Community}$  +  $V_{Owner}$  are co-secondary.  $V_{Investor}$  +  $V_{LP}$  reflect the financing-tier waterfall above  $V_{Owner}$  NPV. Per-substation commercial decomposition lives in the SSI-ENN — mail to [ssi\\_index@ikenga.eu](mailto:ssi_index@ikenga.eu) for analytics.

Layer 1 — Data

SSI v4.0 component taxonomy, normalisation, MC engine

Layer 2 — Valuation

DSO/TSO + Community value stacks, TCO, real options

Layer 3 — Neural Net

GBT+DNN ensemble, transfer learning, SHAP

Layer 4 — Coverage

Country prioritisation, DCI, registry, calibration

Layer 5 — Platform

Products, API, revenue model, unit economics

LAYER 2 §0.4.3 · August 2026

Total Cost of Ownership Model

Stochastic cost modelling — because BESS economics are not deterministic



CAPEX follows a learning-curve distribution calibrated to Bloomberg NEF projections. OPEX is modelled as a mean-reverting process with seasonal components reflecting temperature-dependent degradation. Battery degradation follows a non-linear capacity fade model: each cycle reduces usable capacity, with rate depending on depth-of-discharge, temperature, and C-rate. The SSI data feeds this: substations with high I1 (temperature trajectory) face faster degradation. The Monte Carlo engine propagates cost uncertainty alongside revenue uncertainty.

KEY CONCEPTS

→ CAPEX learning curve calibrated to BNEF

→ Non-linear battery degradation:  $f(\text{DoD}, \text{temperature}, \text{C-rate})$

→ SSI I1 (climate trajectory) drives degradation forecast

→ Full NPV distribution, not point estimate

LIVE SSI DATA CONNECTION

Across the 719-substation fleet, the average consequence multiplier (R3) is 0.807, indicating significant socio-economic exposure. 372 substations (51.7%) are classified High or Critical — these are the highest-priority candidates for BESS deployment.

Coming next month: 

LAYER 1

 Gaussian Copula Monte Carlo Engine — *How 10,000 simulations per substation capture the correlation structure across grid risk factors*

SECTION F.5 — V4.2 ANTI-MALADAPTATION GOVERNANCE GATE

## Radar 2 — W1–W10 Substation Community Value

**Wall 1 — Public W1–W10 framework.** The 10-axis Radar 2 expresses per-substation community-value baseline pre-intervention: *W1 Reliability · W2 Carbon · W3 Local Economic · W4 Climate Resilience · W5 Digital Inclusion · W6 Sovereignty · W7 Local Value Retention · W8 Communications · W9 Supply Security · W10 Compute Multiplier*. The discipline floor that the anti-maladaptation governance gate protects: *"no W axis worse off after intervention."*

## 5/1/1/3 4-tier audit-state classification (mesh resolution per Convention #6 §5.6)

### Published (5) — solid fill

W1 · W2 · W3 · W4 · W8

*Peer-reviewed methodology operational at fleet scale.*

### Baseline-only (1) — striped fill

W5 — Digital Inclusion

*Foundation methodology under development; baseline value defensible at v4.2.*

### Published-baseline (1) ▲ — solid fill + chevron corner marker

W9 — Supply Security

*Peer-reviewed academic basis (Albert/Holme topology-only baseline) with acknowledged scope limit (Buldyrev/IEEE 493 — N-1 contingency dynamics not captured at baseline).*

### Commercial (3) — dashed-faded

W6 · W7 · W10

*Commercial deliverables — please contact the Foundation.*


Per Convention #6 §5.6.7 academic-defensibility: the 4-tier classification aligns with IPCC AR6 + JRC COIN + Reckien (2021) continuum literature. The Published-baseline tier (W9) is the principled mesh resolution that honors both peer-review status + acknowledged scope limit without forcing a false binary.

## v4.2 methodology disclosure — per-country normalisation

Across Greece, the substation fleet's component scores (C / V / I / E / S / T) and the Re composite have been normalised to [0, 1] via the canonical **P5/P95 percentile** method, using *per-country empirical bounds*. This is the same procedure Italy's v4.0.2 deployment applied at the scoring stage (SSI\_v4\_0 Italy/.../scoring-it/normalise.py); for v4.2 we apply it country-by-country so each fleet's within-country ranking is interpretable on its own terms. Convention #56 (visibly-honest) is preserved — no values are invented, the same canonical procedure is applied uniformly. Italy's pilot fleet keeps its native spread (0.17 – 0.64) because its empirical modifier producers (d10–d15) are already wired; per-country empirical modifier producers for the other 38 countries are queued for v4.5 and will refine the absolute risk ranking. Within-fleet relative comparisons (low-exposure vs high-exposure exemplars below) remain accurate by construction.

Radar 2 visualization — anti-maladaptation governance gate

Two worked examples overlaid: **Attica Substation 2** (low-exposure reference, Re\_norm 0.000) and **Epirus Substation 5** (high-exposure reference, Re\_norm 1.000). Axis labels are colour-coded per the 5/1/1/3 mesh resolution; the ▲ chevron marks W9 as Published-baseline. Hover any axis label for the methodology tooltip.



Attica Substation 357 polygon (sage): the low-exposure reference for this country — compact footprint reflects the fleet floor on the W-axis baselines. Thessaly Substation 190 polygon (terracotta): the high-exposure reference — larger footprint where this country's fleet's W-axis values reach the upper percentile. Commercial-tier axes (W6 data sovereignty, W7 local value retention, W10 compute multiplier) display at zero per Convention #6 §5.6 mesh design — no public-data computation. W2 carbon uses EU-average MEF fallback (0.36) per v4.2 calibration.

## W1–W10 axis enumeration with audit-state classification

5/1/1/3 4-TIER · V4.2 MESH RESOLUTION · LIVE VALUES VIA  
COMPUTE\_W\_BASELINES.PY

| AXIS | NAME                  | AUDIT STATE          | METHODOLOGY BASIS                                                                                                                                                        |
|------|-----------------------|----------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| W1   | Reliability           | Published            | $C \times E2\_local \times population (SAIDI + + -POV)$                                                                                                                  |
| W2   | Carbon                | Published            | $T1 \times zonal\ MEF \times (V \cdot deg / 100) (+ EEA)$                                                                                                                |
| W3   | Local Economic        | Published            | $norm(R10\_just) - EU-SILC + OIPE\ energy-poverty$                                                                                                                       |
| W4   | Climate Resilience    | Published            | $(R6d - 1) + (R6e - 1) + (R6c - 1) + \frac{1}{2}(R9 - 1) - v4.2$<br>resilience modifier family                                                                           |
| W5   | Digital Inclusion     | Baseline-only        | $norm(R8\_adapt) - bulk\ SM + + DESI$                                                                                                                                    |
| W6   | Sovereignty           | Commercial           | Foundation contact ( <a href="mailto:ssi_index@ikenga.eu">ssi_index@ikenga.eu</a> )                                                                                      |
| W7   | Local Value Retention | Commercial           | Foundation contact ( <a href="mailto:ssi_index@ikenga.eu">ssi_index@ikenga.eu</a> )                                                                                      |
| W8   | Communications        | Published            | $C \times p\_crit\_10yr \times population$ (Markov 10-yr critical probability)                                                                                           |
| W9 ▲ | Supply Security       | Published-baseline ▲ | $0.60 \times BC\_pct + 0.30 \times bridge + 0.10 \times (1 - deg / 20)$<br>— OSM power-graph betweenness centrality +<br>bridge identification + degree-based redundancy |
| W10  | Compute Multiplier    | Commercial           | Foundation contact ( <a href="mailto:ssi_index@ikenga.eu">ssi_index@ikenga.eu</a> )                                                                                      |

### ▲ W9 Published-baseline — mandatory transparency tooltip

W9 — Supply Security (Published-baseline). Public-tier methodology: betweenness centrality + bridge identification + degree-based redundancy, computed deterministically from OpenStreetMap power-graph data. Peer-reviewed academic basis: Albert et al. (2000) *Nature*; Holme et al. (2002); broad power-grid centrality literature. Acknowledged scope limit (per Buldyrev et al. (2010) *Nature* + IEEE 493): topology-only baseline does not capture N-1 contingency dynamics or interdependent-network cascades. Richer methodology — N-1 contingency simulation + flexibility-services valuation — lives in SSI-ENN L2-22 / L2-23 commercial deliverables. Mail to [ssi\\_index@ikenga.eu](mailto:ssi_index@ikenga.eu) for extended analysis.

**Worked examples.** The W1-W10 per-substation baseline values for two anchor cases — Attica Substation 357 (low-exposure reference) and Thessaly Substation 190 (high-exposure reference) — are computed live by `_audit-snapshot/scripts/d3_radar2_per_country.py` against the country's `ssi-data.json`. Per Convention #6

§2.3.6 Path B refactor (11 Jun 2026), this country's exemplars are now algorithmically selected (min/max Re\_norm) rather than named picks. See the FC v2 reference for W-axis methodology + commercial-tier rationale.

**Anti-maladaptation discipline.** The 10-axis Radar 2 baseline is the per-substation floor that any post-intervention scenario must protect. No W axis may degrade after a BESS deployment, line upgrade, or operational change. The discipline is enforced per axis (not in aggregate), and per substation (not in fleet average). This is the v4.2 governance gate that ensures grid-modernisation projects deliver net community value without hidden trade-offs.

SECTION G

Looking Ahead

NEXT MONTH — EDITION 04

Alpine Valleys

Deep-dive into Region 05's grid risk profile — substation map, component analysis, region regions breakdown. European Context Card: Narrow valleys, long restoration MTTR.

NEXT DATA REFRESH

Q4 2026 — o Quarterly Sources

**none** are due for refresh in Q4. Impact: DER registry (T1), business fabric indicators (E2), macro-economic data. Highest-impact annual source pending: **HEPI (Hellenic Energy Policy Index)** (3 variables → E2 energy transition metrics).

FLEET SPOTLIGHT

196 Bridge Substations — Single Points of Failure

**196 substations** are topological bridges — their failure disconnects part of the network. Of these, **183** are classified High or Critical. These are the fleet's single points of failure: high graph centrality (R4) combined with elevated risk makes them priority candidates for both grid reinforcement and BESS deployment.

Edition 04 will be published on the second Thursday of September 2026. Deep-dive region: **Region 05**. To ensure you receive it, confirm your subscription segment (General / Institutional / Academic) by email to [ssi\\_index@ikenga.eu](mailto:ssi_index@ikenga.eu).

**Feedback welcome.** The SSI Index is designed to evolve through stakeholder dialogue. If you represent an Greek utility,, municipal energy company, or academic institution and would like to contribute data or methodology feedback, please contact us at [ssi\\_index@ikenga.eu](mailto:ssi_index@ikenga.eu). The SSI's credibility depends on open scrutiny.

**Foundation contact**

The SSI Index is a non-profit foundation project, please mail to [ssi\\_index@ikenga.eu](mailto:ssi_index@ikenga.eu) for more details.