Derating Curves Based on Temperature and Altitude

Prepared By		**Date**	
Reviewed By		**Date**	
Approved By		**Date**	

Revision History

Date	Version	Description		Prepared By
		Original	Update	
April 2, 2025	V1.0	New		

Contents

1. Derating Curves Based on Temperature and Altitude 4

1.1 1725 kW PCS Derating Curves Based on Temperature and Altitude 4
1.2 2510 kW PCS Derating Curves Based on Temperature and Altitude 4

1. Derating Curves Based on Temperature and Altitude

1.1 1725 kW PCS Derating Curves Based on Temperature and Altitude

Current Derating Standard (I_0 = Rated)					
Altitude	**25°C**	**30°C**	**35°C**	**40°C**	**45°C**
2000 m	110%	110%	110%	105%	100%
2500 m	110%	110%	105%	100%	95%
3000 m	110%	105%	100%	95%	90%
3500 m	105%	100%	95%	90%	85%
4000 m	100%	95%	90%	85%	80%
4500 m	95%	90%	85%	80%	75%
5000 m	90%	85%	80%	75%	70%

1.2 2510 kW PCS Derating Curves Based on Temperature and Altitude

Current Derating Standard (I_0 = Rated)						
Altitude	**25°C**	**30°C**	**35°C**	**40°C**	**45°C**	**50°C**
2000 m	110%	110%	110%	110%	105%	100%
2500 m	110%	110%	110%	105%	100%	95%
3000 m	110%	110%	105%	100%	95%	90%
3500 m	110%	105%	100%	95%	90%	85%
4000 m	105%	100%	95%	90%	85%	80%
4500 m	100%	95%	90%	85%	80%	75%
5000 m	95%	90%	85%	80%	75%	70%