

Totally Integrated Automation Portal

Dynamic Setpoint Profiles / PLC_1 [CPU 1212C DC/DC/DC] / Program blocks

FB_TempRamp_Gen_DB [DB1]

FB_TempRamp_Gen_DB Properties

General

Name	FB_TempRamp_Gen_DB	Number	1	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					

FB_TempRamp_Gen_DB

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Input									
Start_Temp	Real	0.0	False	True	True	True	False		
Target_Temp	Real	0.0	False	True	True	True	False		
Ramp_Time_Min	Real	0.0	False	True	True	True	False		
Enable	Bool	false	False	True	True	True	False		
Reset	Bool	false	False	True	True	True	False		
dt_sec	Real	0.0	False	True	True	True	False		
▼ Output									
Output_Value	Real	0.0	False	True	True	True	False		
Ramp_Complete	Bool	false	False	True	True	True	False		
InOut									
▼ Static									
Elapsed_Time_sec	Real	0.0	False	True	True	True	False		
Ramp_Rate	Real	0.0	False	True	True	True	False		