

400W LED FLOOD LIGHT

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

400W Energy Efficient LED Flood Light

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 09/17/2019

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Test Report

Report Number: 17-09-2019	9 -002		Date:	17-09-2019	
Product Description: 400W Energy Efficient LED Flood Light					
Product Catalogue Reference:	HLFLD-ML06-400-C	WL-HL2-29D	Brand:	HALONIX	
Construction:					
Pressure die casted aluminum housing,	Glass front visor, SN	1D LED, Electronic driver	etc.		
Test Details:		Document	References	s/Standard:	
 Light intensity distribution Measurement Total Lumen output Measurement Electrical Parameters Measurement 		Measurements Products" IS: 16106-2012 Photometric solution Products" IS: 16105-2012	Measurements of Solid-State Lighting Products" IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products" IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light		
Enclosures:					
Prepared By:		A	pproved B	y:	
Sanjay Sharma		Ra	ijeev Chhal	ora	

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Electrical & Photometric Test Report

Photometric Test Report: (As Pe	r IES LM 79-08)				
Sample ID: 17-09-2019 -002					
Catalogue Reference:	HLFLD-ML0	HLFLD-ML06-400-CWL-HL2-29D Testing Date: 1			
Testing Agency:	HTPL Labor	HTPL Laboratory		HALONIX	
Equipment Used:		EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe Photometer (Type: PMS – 50/80) with Power Meter			
	•	· ,			
Ambient Temperature:	25±2°C	Relative Humidity:	65%		
Test Voltage:	240V	Frequency:	50Hz		
a					

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	Total Operating Time:	1.30Hours

Rated Performance Parameters:			
Rated Wattage :	400W	Rated Input Current:	1.842A
Nomical CCT :	5700K	Nominal CRI:	>70

Measured Electrical Parameters:				
Supply Voltage:	240V	Input Current :	1.704A	
Frequency:	50Hz			
Total Power :	399.95W	Power Factor :	0.978	

Photometric Measurement Data:				
Total Measured Lumen :	48773.9lm	Luminaries Efficacy:	121.95lm/W	
CCT:	5796K	CRI:	71.8	
Light Intensity Distribution:		Attached (Refer to Page No. 4)		
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma		

HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

Light intensity Distribution Diagram



Catalogue Reference	HLFLD-ML06-400-CWL-HL2-29D	Sample ID	17-09-2019 -002