

### **10W LED BULK HEAD CW**

Photometric & Electrical Measurement (As per IES LM 79-08 / IS 16106-12)

**10W Energy Efficient LED Light** 

Issued by: Halonix Technologies Private Limited (NABL Certification No: TC-7634) 12/28/2019

## HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Test Report**

<b>Report Number:</b> 28-12-2019 -001	Date	: 28-12-2019	
<b>Product Description:</b> 10W Energy Efficient LED Bulk Head			
Product Catalogue Reference: HLBH-03-10-CW	Bran	d: HALONIX	
Engineering plastic housing, Opal diffuser, etc.			
Test Details:	Document Refere	nces/Standard:	
<ul> <li>Light intensity distribution Measurement</li> <li>Total Lumen output Measurement</li> <li>Electrical Parameters Measurement</li> </ul>	<ul> <li>IES-LM-79-08 "Electrical and Photometric Measurements of Solid-State Lighting Products"</li> <li>IS: 16106-2012 "Method of Electrical and Photometric solid state lighting (LED) Products"</li> <li>IS: 16105-2012 "Method of measurement of Lumen maintenance of solid state light sources"</li> </ul>		
Enclosures:			
Prepared By:	Approve	d By:	
Sanjay Sharma Rajeev Chhabra		habra	

# HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India

Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

### **Electrical & Photometric Test Report**

Photometric Test Report: (As	Per IES LM 79-08)				
<b>Sample ID:</b> 28-12-2019 -001					
Catalogue Reference:	HLBH-03-10	HLBH-03-10-CW		28-12-2019	
Testing Agency:	HTPL Labora	HTPL Laboratory		HALONIX	
Equipment Used:	EVERFINE B	EVERFINE Brand Gonio Photometer (Type: GO - 2000B V1) and Globe			
	Photometer	Photometer (Type: PMS – 50/80) with Power Meter			
Ambient Temperature:	25±2°C	Relative Humidity:	65%		

Ambient Temperature:	25±2°C	Relative Humidity:	65%
Test Voltage:	240V	Frequency:	50Hz
Stabilization Time:	30Min	<b>Total Operating Time:</b>	1.30Hours

Rated Performance Parameters:				
Rated Wattage :	10W	Rated Input Current:	0.048A	
Nomical CCT :	6500K	Nominal CRI:	>80	

Measured Electrical Parameters:				
Supply Voltage:	240V	Input Current :	0.042A	
Frequency:	50Hz			
Total Power :	9.89W	Power Factor :	0.981	

Photometric Measurement Data:			
Total Measured Lumen :	822.06lm	Luminaries Efficacy:	83.12lm/W
CCT:	6415K	CRI:	82.3
Light Intensity Distribution:		Attached (Refer to Page No. 4)	
Approved By: Rajeev Chhabra		Tested By: Sanjay Sharma	

### HALONIX TECHNOLOGIES PRIVATE LIMITED HTPL LABORATORY (NABL Certificate No: TC-7634)

Plot-5, Sector-12, IIE, SIDCUL

Haridwar (Uttarakhand), PIN-249403, India


Contact:

Email: customercare@halonix.co.in

Fax:

Web: http://www.halonix.co.in

#### **Light intensity Distribution Diagram**



Catalogue Reference	HLBH-03-10-CW	Sample ID	28-12-2019 -001